



ELECTROCHEMICAL CARBON DIOXIDE CONCENTRATOR SUBSYSTEM MATH MODEL

FINAL REPORT
by
R.D. Marshall, J.N. Carlson
and F.H. Schubert

September, 1974



MATH MODEL SOLUTION SEQUENCE



Prepared Under Contract No. NAS2-6478

by

Life Systems, Inc.
Cleveland, Ohio 44122

for

AMES RESEARCH CENTER
National Aeronautics & Space Administration

ER-220-6

ELECTROCHEMICAL CARBON DIOXIDE
CONCENTRATOR SUBSYSTEM
MATH MODEL

FINAL REPORT

By

R. D. Marshall, J. N. Carlson
and F. H. Schubert

September, 1974

Distribution of this report is provided in the interest
of information exchange. Responsibility for the contents
resides in the authors or organization that prepared it.

Prepared Under Contract No. NAS2-6478

by

LIFE SYSTEMS, INC.
Cleveland, Ohio 44122

for

AMES RESEARCH CENTER
NATIONAL AERONAUTICS & SPACE ADMINISTRATION

FOREWORD

The development activity described herein was conducted by Life Systems during the period November, 1973 to September, 1974 as part of NASA Contract NAS2-6478. The Program Manager was Richard D. Marshall. Technical support was provided as follows:

Jan Carlson - Computer simulation model

Tim Hallick - Test program

Franz Schubert - Model analyses

Direct technical monitorship was provided at NASA Johnson Space Center, Houston, Texas, by Mr. W. E. Ellis, Chief, Environmental and Thermal Systems Section, Crew Systems Division, and Mr. L. D. Kissinger. The program Technical Monitor was P. D. Quattrone, Chief, Environmental Control Research Branch, NASA Ames Research Center, Moffett Field, California.

TABLE OF CONTENTS

	<u>PAGE</u>
LIST OF FIGURES	iii
LIST OF TABLES	iv
SUMMARY	1
INTRODUCTION	1
CS-6 SUBSYSTEM	2
Process Streams	2
Hardware Description	6
Electrochemical Modules	6
Process Air Blowers	10
Cooling Air Blowers	10
Hydrogen Flow Sensor and Distribution Mounting	10
Primary Controller	11
Emergency Controller	11
Load Transistor Mounting	12
CS-6 MATH MODEL TEST PROGRAM	12
Electrochemical Modules	12
Process Air Inlet pCO ₂	12
Current Density	12
Cathode Air Flow Rate	15
Process Air Blowers	17
Cooling Air Blowers	17
Primary Controller	17
Emergency Controller	24
CS-6 Subsystem	24
Hydrogen Flow Sensor and Distribution Mounting	24
CS-6 BASE PROGRAM	24
Model Analyses	29
Process Air Correlations	29
Process Hydrogen Correlations	39
EDC Module Correlations	40
Computer Program	43
Program Description	43
Program Assumptions	45
Program Features	46

-continued-

Table of Contents - continued

	<u>PAGE</u>
Model Results	47
CS-6 CABIN pCO ₂ SIMULATION PROGRAM	47
Model Analysis	47
Mode B Definition	47
Cabin pCO ₂ Integration	55
Computer Program	57
Program Description	57
Program Assumptions	58
Program Features	59
Model Results	59
CONCLUSIONS	71
REFERENCES	80
APPENDIX A CS-6 BASE PROGRAM DOCUMENTATION	A-1
APPENDIX B CS-6 BASE PROGRAM SAMPLE OUTPUTS	B-1
APPENDIX C CS-6 CABIN pCO ₂ SIMULATION PROGRAM DOCUMENTATION	C-1
APPENDIX D CS-6 CABIN pCO ₂ SIMULATION PROGRAM SAMPLE OUTPUTS	D-1

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	CS-6 Schematic	3
2	Simplified CS-6 Functional Block Diagram	5
3	CS-6 Subsystem (Front)	8
4	CS-6 Subsystem (Back)	9
5	Comparison of CS-6 Performance Data and Math Model Simulation Curve for Transfer Index Versus Inlet pCO ₂	13
6	Comparison of CS-6 Performance Data and Math Model Simulation Curves for Transfer Index Versus Current Density	14
7	Comparison of CS-6 Performance Data and Math Model Simulation Curves for Transfer Index Versus Air Flow Rate	16
8	EDC Module Process Air Pressure Drop Versus Air Flow Rate	18
9	System Process Air Pressure Drop Versus Air Flow Rate	19
10	Process Air Blower Power Versus Air Flow Rate (Section 1)	20
11	Process Air Blower Power Versus Air Flow Rate (Section 2)	21
12	Cooling Air Pressure Drop Versus Air Flow Rate	22
13	Cooling Air Blower Power Versus Air Flow Rate	23
14	Location of Gas Sampling Ports	25
15	H ₂ Distribution Block Pressure Drop for Process H ₂ and N ₂ Purge	27
16	H ₂ Pressure Drop Across Modules	28
17	Process Stream Identification Numbers	35
18	Effect of Moisture Conditions on Transfer Index	44
19	Control Mode B (Typical)	54
20	Graphic Representation of Convergence Scheme	56
21	Cabin CO ₂ Generation Rate Profile	60
22	Cabin pCO ₂ Simulation Profile for Control Mode A(1)	61
23	Cabin pCO ₂ Simulation Profile for Control Mode A(2)	62
24	Cabin pCO ₂ Simulation Profile for Control Mode A(3)	63
25	Cabin pCO ₂ Simulation Profile for Control Mode B(1)	66
26	Cabin pCO ₂ Simulation Profile for Control Mode B(2)	67
27	Cabin pCO ₂ Simulation Profile for Control Mode B(3)	68
28	Cabin pCO ₂ Simulation Profile for Control Mode B(4)	69
29	Steady-State Daily Equivalent Weight Profile for Control Mode B(1)	72
30	Steady-State Daily Equivalent Weight Profile for Control Mode B(2)	73
31	Steady-State Daily Equivalent Weight Profile for Control Mode B(3)	74
32	Steady-State Daily Equivalent Weight Profile for Control Mode B(4)	75
33	Steady-State Daily O ₂ Consumption Profile for Control Mode B(1)	76
34	Steady-State Daily O ₂ Consumption Profile for Control Mode B(2)	77
35	Steady-State Daily O ₂ Consumption Profile for Control Mode B(3)	78
36	Steady-State Daily O ₂ Consumption Profile for Control Mode B(4)	79

LIST OF TABLES

<u>Table</u>		<u>Page</u>
1	CS-6 Design Specifications	4
2	CS-6 Line Replaceable Units	7
3	CS-6 Intercomponent Interface Parameters for Baseline Operating Conditions	26
4	CS-6 Base Program Input Variable Ranges	30
5	CS-6 Base Program Input and Output Variables	31
6	Anode Gas Outlet Dew Point Temperature Correlation Data	41
7	CS-6 Cabin pCO ₂ Simulation Program Input Variable Ranges	48
8	CS-6 Cabin pCO ₂ Simulation Program Input and Output Variables	50
9	Input Variables for Sample Mode A Problems	64
10	Control Mode B Parameters	65
11	Input Variables for Sample Mode B Problems	70

SUMMARY

A steady-state computer simulation model has been developed to describe the performance of the total Six-Man, Self-Contained Electrochemical Carbon Dioxide Concentrator Subsystem, referred to as CS-6, as built for the Air Revitalization Group (ARG) of Space Station Prototype (SSP). The math model combines expressions describing the performance of the Electrochemical Depolarized Carbon Dioxide Concentrator (EDC) cells and modules previously developed with expressions describing the performance of the other major CS-6 components. The model is capable of accurately predicting CS-6 performance over EDC operating ranges and the computer simulation results agree with experimental data obtained over the prediction range.

Two computer programs were written utilizing the mathematical expressions developed to describe CS-6 performance. The first computer program, referred to as the CS-6 Base Program, calculates the steady-state performance characteristics of the CS-6 subsystem and its components, including intercomponent and subsystem fluid interface parameters, component and subsystem power and heat generation, and subsystem equivalent weight. The second program, referred to as the CS-6 Cabin pCO_2 Simulation Program, utilizes the CS-6 Base Program with minor modifications as a subroutine to describe the daily cabin partial pressure of carbon dioxide (pCO_2) profile that would result from using the CS-6 as the carbon dioxide (CO_2) removal subsystem in a simulated spacecraft air revitalization application. The program takes a daily CO_2 generation profile and cabin volume, and calculates and subtracts the CO_2 removal rate to arrive at the daily cabin pCO_2 profile.

Seven experiments were conducted in support of the math model to (1) establish the performance characteristics of the CS-6 and of the individual CS-6 subsystem components and (2) verify the predictability of the two computer programs. The experiments performed characterized the electrochemical modules, the process air blowers, the cooling air blowers, the hydrogen (H_2) flow sensor and distribution mountings, the primary controller, the emergency controller, and the steady-state CS-6 intercomponent interface parameters.

INTRODUCTION

In parallel to the development of an Electrochemical Carbon Dioxide Concentrator Subsystem, Life Systems, Inc. had developed a steady-state computer simulation model to predict the performance of the Electrochemical Depolarized Carbon Dioxide Concentrator (EDC) cells and modules over a wide range of operating conditions.⁽¹⁾ The objectives of the present program were to (1) expand this existing model to predict the performance characteristics of the total Six-Man, Self-Contained Electrochemical Carbon Dioxide Concentrator Subsystem, referred to as the CS-6, as built for the Air Revitalization Group (ARG) of Space Station Prototype (SSP), and (2) develop two computer programs using the expanded model to predict the steady-state performance characteristics of the CS-6 (first program) and to determine the daily partial pressure of carbon dioxide (pCO_2).

⁽¹⁾ All references cited are listed at the end of the report.

profile for a given spacecraft cabin volume and carbon dioxide (CO_2) generation profile (second program).

To accomplish the objectives of the program, the program was organized into three tasks and a program management function. The specific objectives of these tasks were to:

1. Perform supporting experimentation to characterize subsystem components and to verify the performance predictions of the expanded math model.
2. Prepare the CS-6 Base Program by expanding the EDC computer simulation model to enable predicting the steady-state performance characteristics of the CS-6 as a total subsystem.
3. Prepare the CS-6 Cabin pCO_2 Simulation Program to predict CS-6 response to a specified, repetitive CO_2 generation profile for a given time period and a specified cabin volume. The pCO_2 Simulation Program allows CS-6 performance to be characterized as a function of time for constant input parameters, current and process air flow rate (Control Mode A), and variable input control parameters for current and air flow rates as a function of cabin pCO_2 (Control Mode B).

The CS-6 Subsystem and component testing was completed and the results were used to develop the mathematical expressions describing CS-6 performance. These experimentally obtained correlations were then combined with subsystem and component mass and energy balances to write the CS-6 Base Program. The CS-6 Cabin pCO_2 Simulation Program was then prepared using the Base Program as a subroutine to calculate CS-6 performance parameters as a function of time.

CS-6 SUBSYSTEM

The CS-6 was designed specifically as the Carbon Dioxide Collection Subsystem (CCS) for the SSP program. The function of the CS-6 is to remove 6.0 kg (13.2 lb)/day) of CO_2 from the cabin atmosphere and deliver the CO_2 premixed with hydrogen (H_2) to the CO_2 Reduction Subsystem. The major components of the CS-6 are the electrochemical modules that actually perform the CO_2 removal function and the supporting hardware required to manifold the process gas streams (blowers, valves, ducting, etc.) and control the CO_2 removal process. The detailed schematic of the CS-6 subsystem is presented in Figure 1. The design specifications for the CS-6 are presented in Table 1. A detailed description of the operation and components of the CS-6 has been documented previously in literature.(2,3,4) The description of the CS-6 subsystem that follows details how the subsystem process streams and hardware were viewed for math modeling purposes.

Process Streams

A simplified functional schematic of the CS-6 subsystem is given in Figure 2. The actual arrangement of the CS-6 hardware is in two identical process loops.

REPRODUCIBILITY OF THE
ORIGINAL PAGE IS POOR

3




FIGURE 1 CS-6 SCHEMATIC

TABLE I CS-6 DESIGN SPECIFICATIONS

Number of Crew (Continuous)	6
CO ₂ Removal Requirements	
Nominal (48-Hr Average), kg/d (Lb/Day)	6.0 (13.2)
Maximum (4-Hr Duration), kg/d (Lb/Day)	9.3 (20.4)
Cabin Atmosphere	
Total Pressure, kN/m ² (Psia)	101-105 (14.7-15.2)
Temperature, K (F)	291-297 (65-75)
Dew Point Temperature, K (F)	281-287 (46-57)
O ₂ Partial Pressure, kN/m ² (Psia)	21.0-22.6 (3.04-3.28)
CO ₂ Partial Pressure	
Nominal, N/m ² (mm Hg)	<400 (<3)
Operating Range, N/m ² (mm Hg)	200-400 (1.5-3)
Diluent	Air Constituents
Process Air	
Total Pressure, N/m ² (Inch Water)	Ambient + 1495 (+ 6)
Temperature, K (F)	Dew Point + 3.34 (+ 6)
Dew Point Temperature, K (F)	281-283 (46-50)
O ₂ Partial Pressure, kN/m ² (Psia)	21.0-22.6 (3.04-3.28)
CO ₂ Partial Pressure	
Nominal, N/m ² (mm Hg)	381 (2.86)
Operating Range, N/m ² (mm Hg)	200-385 (1.5-2.89)
Diluent	Air Constituents
Cooling Air	
Total Pressure, N/m ² (Inch Water)	Ambient + 1495 (+ 6)
Temperature, K (F)	Process Air Dew Point + 3.34 (+ 6)
H ₂ Supply	
Total Pressure, kN/m ² (Psia)	<138 (<20)
Temperature, K (F)	291-297 (65-75)
Dew Point Temperature, K (F)	283-289 (50-60)
H ₂ + CO ₂ Exhaust	
Total Pressure	Ambient
Electrical Power	106-122 VRMS, 400 ±40 Hz, 3Ø, 5 Wire
Purge Supply	
Type Gas	N ₂
Pressure, kN/m ² (Psia)	310 (45)
Packaging	Self-Contained
Gravity	0-1 g
Allowable Downtime	8-12 Hr
Duty Cycle	Variable ^(a)

(a) The SSP Specification cites potential orbital On/Off cyclic operation.




FIGURE 2 SIMPLIFIED CS-6 FUNCTIONAL BLOCK DIAGRAM

Each loop has its own process air blower, cooling air blower, H₂ flow sensor and distribution mounting, and three EDC modules. For math modeling purposes, both process loops have the same performance characteristics. The simplification of the subsystem hardware shown in Figure 2 reduces the number of computer program outputs (and computer running time) required to describe CS-6 performance without sacrificing model accuracy.

Process air is drawn from the inlet portion of the plenum through the cathode compartments of the electrochemical cells by the process air blowers. Carbon dioxide is removed from the flowing air stream as it passes over the cathode of the EDC cells. The CO₂-depleted air stream is then returned to the outlet portion of the plenum. Likewise, cooling air is drawn by the cooling air blowers from the inlet portion of the plenum over the external fin portion of the electrochemical cells. The cooling air, at a higher temperature, is then returned to the outlet portion of the plenum. Excess process air entering the plenum bypasses the subsystem through the plenum air bypass.

Process H₂ used by the electrochemical modules is manifolded to each module through two identical H₂ sensor and flow distribution mounting blocks. Each flow distribution block equally manifolds H₂ flow to each of the three 16-cell modules it serves. The H₂ flows in series through the 16 cells of each module.

Hardware Description

The CS-6 subsystem components were divided into Line Replaceable Units (LRUs). The list of the major subsystem LRUs is presented in Table 2. Front and rear photographs of the CS-6 showing the LRUs are presented in Figures 3 and 4, respectively. Each of the LRUs were analyzed for power required, heat generation, effect on gas stream pressure, temperature and composition, and actual component weight for use in the total subsystem equivalent weight determination. Those components that did not require power(a), generate heat, or affect gas stream parameters during steady-state operation were not modeled. The LRUs not modeled were the process air sensors, the electric shutoff valves, the backpressure regulator, the pressure sensors, the combustible gas sensors, and the manual shutoff valve. The electrical, motor-driven shutoff valves are not actuated during normal operation and hence require no power and generate no heat. Their actuation only occurs during mode transitions (such as normal to shutdown); however, even then the energy requirement is less than 57.5 J (0.016 watt-hours). All other components were characterized for use in the computer simulation model. A brief description of those LRUs that were modeled follows.

Electrochemical Modules

The CS-6 contains six electrochemical modules. Each of the electrochemical modules contains 16 cells. The electrochemical modules perform the actual CO₂ removal process by removing CO₂ from the cathode air stream and concentrating it

(a) All sensor power required is accounted for in the controllers.

TABLE 2 CS-6 LINE REPLACEABLE UNITS

	<u>SSP Item No.</u>	<u>Qty. Req'd</u>
Module, Electrochemical	890	6
Blower, Process Air	543	2
Blower, Cooling Air	345	2
Sensor, Process Air	875	4
Valve, Shutoff, Electric	305	3
Valve, Shutoff, Electric	306	6
Mounting, H ₂ Flow Sensor & Distribution	882	2
Valve, Regulator, Backpressure	310	1
Sensor, Pressure	877	3
Sensor, Combustible Gas	178	4
Controller, Primary	871	1
Controller, Emergency	872	1
Unit, Data Acquisition	970	1
Mounting, Load Transistor	876	1
Valve, Shutoff, Manual	507	1




FIGURE 3 CS-6 SUBSYSTEM (FRONT)




FIGURE 4 CS-6 SUBSYSTEM (BACK)

into the process H₂ stream. Moist air containing CO₂ is fed into the cathode where the electrochemical reaction of oxygen (O₂) in the air, water, and electrons form hydroxyl ions (OH⁻). The CO₂ from the air then reacts with OH⁻ forming carbonate ions. The output from the cathode compartment is moist air at a reduced pCO₂. At the anode side, H₂ is fed into the cell and electrochemically reacts with OH⁻ to form water and electrons. The decrease in the OH⁻ concentration in the electrolyte at the anode produces an equilibrium shift in the electrolyte which causes CO₂ to be released. The output from the anode compartment is CO₂ mixed with unreacted H₂. The overall reaction is exothermic and is accompanied by the formation of electrical energy. The CO₂ removal process is primarily a function of the inlet air pCO₂, air flow rate, cell current, and cell moisture balance. Cell voltage and power production is primarily a function of cell current density and temperature.

Process Air Blowers

The CS-6 contains two centrifugal blowers to draw process air from the plenum through the cathode compartment of the electrochemical cells. One blower is used for each process loop. The process air flows in parallel through the 48 cells of each group of three modules. The blowers are located downstream of the electrochemical modules such that heat generated by the blowers will not have an adverse effect on the moisture balance within the electrochemical cells. The blower power used to control the cathode air flow rate is dissipated as heat into the cathode air stream exhausting the blower.

Cooling Air Blowers

The CS-6 contains two vane axial blowers to draw process air from the plenum over the fins of the electrochemical modules. Each blower draws the air in parallel over the fins of the 48 cells of a group of three modules. All heat dissipated as inefficiencies within the electrochemical module that is not removed by the cathode process air stream and process H₂ streams is removed by the cooling air stream. One cooling air blower is used for each process loop. The cooling air blowers are located downstream of the electrochemical modules. The amount of cooling air required is determined by the temperature differential between the dew point of the incoming process air and the dry bulb temperature of the exiting process air stream from the module. The cooling air blower speed is continuously modulated to vary the cooling air flow rate over the cell cooling fins as required. All power used by the cooling air blowers is dissipated as heat into the cooling air exiting the blowers.

Hydrogen Flow Sensor and Distribution Mounting

The CS-6 contains two H₂ flow sensor and distribution mountings designed to provide equal H₂ flow to each of the six CS-6 submodules. Each flow distribution block is located upstream of the three electrochemical modules it serves. The distribution block consists of three calibrated orifices and three flow sensors. Power required by the flow sensors is accounted for in the controllers and there is no heat generation. The blocks do affect H₂ stream pressure drop.

Primary Controller

The primary controller controls module current, process (cathode) air flow rate, and the process air inlet dew point to module temperature differential. Two control modes can be selected, Mode A and Mode B. In Control Mode A, current and process air flow rate are controlled at a constant level throughout CS-6 operation. In Control Mode B, both parameters are a function of an external 0 to 5 volt DC signal which is assumed to originate from a pCO₂ sensor. The module temperature control is independent of Control Mode A or B and basically is a control of the cooling air blower speed to maintain the process air inlet dew point to module temperature differential constant. The primary controller also sequentially actuates subsystem components to place them in the proper configuration as dictated by an operating mode command or when an out-of-tolerance condition is sensed by the primary controller. Primary controller-initiated shutdowns are those that are time critical and require immediate action. There are four primary controller initiated shutdowns: (1) high H₂ pressure (48 kN/m² (7.0 psig)), (2) low H₂ pressure (<17 kN/m² (2.5 psig)), (3) high H₂-in-air mixture (>1.5%) in the front of the subsystem, and (4) high H₂-in-air mixture (>1.5%) in the back of the subsystem.

Power required to run the controllers, not including the electrochemical power generated by the electrochemical reactions, is dissipated as heat to the surrounding environment and not to any process stream.

Emergency Controller

The emergency controller consists of a shutdown sequencer to provide for proper component sequencing during an emergency controller-initiated subsystem shutdown. Any out-of-tolerance condition for any one of eight subsystem parameters can initiate this shutdown sequence. Those conditions which can cause a shutdown are:

1. High or low module temperature to inlet air dew point temperature differential (12.2K (22F)) above the inlet dew point air temperature or less than 8.9K (16F) above the inlet dew point temperature.
2. High power transistor temperature in the load transistor mounting heat sink assembly (in excess of 366K (200F)).
3. Greater than 2% H₂-in-air mixture sensed by a combustible gas sensor located in the front of the subsystem.
4. Greater than 2% H₂-in-air mixture sensed by a combustible gas sensor located in the rear of the subsystem.
5. High anode gas exhaust pressure in excess of 52 kN/m² (7.5 psig).
6. Loss of primary controller power.
7. A H₂ exhaust pressure less than 14 kN/m² (2.0 psig).

8. Low cell voltage in any one of the 96 cells (less than -0.25V).

Power utilized by the emergency controller is dissipated as heat given off to the surrounding cabin environment.

Load Transistor Mounting

The load transistor mounting is located in the outlet portion of the process air plenum to dissipate the power generated by the electrochemical cell reactions as heat and reject it to the process air stream leaving the plenum.

CS-6 MATH MODEL TEST PROGRAM

Experimentation specifically aimed at supporting the development of the CS-6 computer simulation model was required to establish the performance characteristics of the CS-6 and its individual LRUs. Seven tests were conducted. Six were directly used to characterize the performance of LRUs while the seventh established subsystem performance and intercomponent interface parameters for eventual math model computer program verification. The six LRUs characterized were: (1) the electrochemical modules (to compare predictability of the module math model previously developed), (2) the process air blowers, (3) the cooling air blowers, (4) the H₂ flow sensor and distribution mounting, (5) the primary controller, and (6) the emergency controller. The remaining LRUs consisting of valves and sensors were not characterized since valve power and heat loads are negligible and sensor power and heat load are included under either the primary or emergency controller.

Electrochemical Modules

A series of three experiments were conducted to verify the predictability of the electrochemical modules' performance within the CS-6 to determine if any upgrading of the previously established EDC cell math model was required. The electrochemical modules were characterized as a function of inlet pCO₂, current density, and air flow rate over nominal operating ranges.

Process Air Inlet pCO₂

Module performance, specifically CO₂ removal efficiency, was experimentally characterized for a process air inlet pCO₂ range of 67 to 800 N/m² (0.5 to 6.0 mm Hg). The results of the pCO₂ test and the math model prediction curve for the test parameters are presented in Figure 5. The correlation between math model prediction and experimental data was excellent, thereby verifying the predictability of the electrochemical math model as a function of process air inlet pCO₂.

Current Density

The effect of current density on electrochemical module performance was characterized for 10.8 to 37.7 mA/cm² (10 to 35 ASF). The results of the experiment and the math model prediction curve for the test parameters are presented in Figure 6.




FIGURE 5 COMPARISON OF CS-6 PERFORMANCE DATA AND MATH MODEL SIMULATION CURVE FOR TRANSFER INDEX VERSUS INLET pCO_2




FIGURE 6 COMPARISON OF CS-6 PERFORMANCE DATA AND MATH MODEL SIMULATION CURVES FOR TRANSFER INDEX VERSUS CURRENT DENSITY

The test was conducted at CS-6 baseline interface conditions. At steady-state, moisture-in-balance conditions, the predictions of the math model as previously developed for CO₂ removal efficiencies agreed well with the performance data observed for the CS-6. At the lower current densities, the EDC cell math model predicted out-of-tolerance moisture conditions (wet) due to insufficient module heat generation (module subcooling). Subsystem operation at the lower current densities yielded lower than predicted transfer efficiencies characteristic of operation at wet conditions⁽⁵⁾. The data indicated excessively moist conditions, as correctly predicted by the math model. At the higher current densities, the math model predicted that the cell moisture conditions were removing water from the electrolyte causing the modules to dry out. Subsystem operation at the higher current densities yielded higher than predicted CO₂ removal efficiencies characteristic of operation at dry conditions⁽⁵⁾. The data indicated very dry moisture conditions within the modules, as correctly predicted by the math model. The deviations from in-moisture-balance operation were caused by the variation in cell current density which changes the amount of water and waste heat generated while maintaining the air flow rate and process air inlet moisture conditions constant at SSP baseline conditions without adjustment in module temperature level.

The previously established EDC cell math model predicts CO₂ removal efficiencies based on the assumption that the cells are operating at steady-state conditions and that moisture balance is maintained within a specific, optimum range. Steady-state operation, however, can also be achieved at less than optimum moisture conditions within the electrochemical modules. Since this latter condition is a possible operating mode for the CS-6, a moisture balance correction to allow prediction of CO₂ removal efficiencies as a function of the cell moisture conditions, as indicated by the data, was subsequently incorporated prior to completing the CS-6 subsystem math model.

Cathode Air Flow Rate

The effect of varying cathode air flow rates was characterized for the range of 14.2 to 28.3 dm³/s (30 to 60 scfm). The results of the experiment and the EDC cell math model prediction curve for the test parameters are presented in Figure 7.

Air flow rate has a large effect on the heat and water removal rates and the moisture balance conditions within the electrochemical cells. The data used in the CO₂ removal efficiency correlation of the EDC cell math model was, as stated above, based on cells operating in an optimum moisture balance range and did not take into account the large changes in cell moisture conditions caused by varying the air flow rate, as experienced in the actual subsystem operation. The CO₂ removal efficiency correlation of the initial EDC cell math model was, therefore, not adequate to predict CO₂ removal efficiency as a function of air flow rate. Subsequently, additional data gathered on the CS-6 after the completion of the original EDC cell math model was used to upgrade the air flow correlation for electrochemical modules. This upgraded version was included in the CS-6 Base Program.




FIGURE 7 COMPARISON OF CS-6 PERFORMANCE DATA AND MATH MODEL SIMULATION CURVES FOR TRANSFER INDEX VERSUS AIR FLOW RATE

Process Air Blowers

The two CS-6 process air blowers were characterized to obtain air stream pressure drops and blower power and heat load as a function of process (cathode) air flow rate. The major pressure drop producing components in this air stream are the EDC modules. The results of the module pressure drop versus flow rate experiment are shown in Figure 8. System pressure drop as a function of air flow rate is given in Figure 9. Blower power for the process air blower of Section 1 and Section 2 as a function of air flow rate, at a corresponding system pressure drop, is given in Figures 10 and 11, respectively.

The modules and system pressure drop versus air flow rate curves relate typical pressure drop data as a function of air flow rate. The blower power curve, however, contains a spike at 14.2 to 16.5 cm^3/s (30 to 35 scfm), resulting from the combination of blower motor characteristics and blower speed control circuitry. The spike was verified during all forms of operation and implies that only a small change in air flow rate at flow rates greater than 14.2 dm^3/s (30 scfm) can cause large variations in the blower power requirement.

Cooling Air Blowers

The two CS-6 cooling air blowers were experimentally characterized to establish blower power, heat load, and cooling air passage pressure drop. The results of the cooling air pressure drop versus air flow rate test at two levels of plenum inlet pressure levels are presented in Figure 12. The pressure drop associated with ducting to and from the electrochemical modules did not significantly contribute to the cooling air pressure drop in comparison to the module cooling air pressure drop. The cooling air blower power versus air flow rate curves are shown in Figure 13.

Figure 13 shows that for a plenum inlet air pressure of 286 to 336 N/m^2 (1.15-1.35 in water), a certain amount of cooling air (approximately 10 dm^3/s (21 cfm) flows through the cooling air passages with the cooling blowers off, i.e., blower power equal to zero. The amount of air that bypasses the plenum and flows over the cooling fins of the modules, when the cooling air blowers are off, is determined by the overall system process air flow rate entering the plenum. The higher the total system process air flow the higher the plenum pressure differential and the higher the leakage air flow through the cooling air passages. Dampers were installed in the cooling air passages to prevent this bypass flow from occurring during times when cooling is not required. The dampers, however, were not totally leak-tight and some air flow constantly bypassed through the cooling air passages during cooling blower off operation. This contributed to module subcooling during low current density and high process (cathode) air flow rates.

Primary Controller

The CS-6 primary controller was characterized to determine the heat load and the power required during steady-state CS-6 operation. All blower power, which only passes through the controller, is handled separately and is not included in this




FIGURE 8 EDC MODULE PROCESS AIR PRESSURE DROP
VERSUS AIR FLOW RATE




FIGURE 9 SYSTEM PROCESS AIR PRESSURE DROP VERSUS AIR FLOW RATE




FIGURE 10 PROCESS AIR BLOWER POWER VERSUS AIR FLOW RATE
(SECTION 1)




FIGURE 11 PROCESS AIR BLOWER POWER VERSUS AIR FLOW RATE
(SECTION 2)




FIGURE 12 COOLING AIR PRESSURE DROP VERSUS AIR FLOW RATE




FIGURE 13 COOLING AIR BLOWER POWER VERSUS AIR FLOW RATE

requirement. The amount of power attributed to the primary controller to control the operation of the CS-6 subsystem at steady-state conditions as measured by a wattmeter on the power input was 85 watts. This power requirement is constant and independent of subsystem parameter variations (i.e., current density, cooling blower speed, or process air blower speed).

Emergency Controller

The CS-6 emergency controller was characterized to obtain the heat load and the power required during steady-state operation. The steady-state emergency controller power, as measured by a wattmeter, was 45 watts during normal CS-6 operation. This power requirement is constant and independent of subsystem parameter variations.

CS-6 Subsystem

The CS-6 subsystem was characterized as a function of process air inlet pCO_2 , current density, and process air flow rate to determine intercomponent interface conditions between LRUs within the CS-6. The objective of the testing was to verify CS-6 math model prediction using these various intercomponent temperatures, pressures, etc. The testing consisted of running the CS-6 at steady-state conditions and monitoring pressures and temperatures throughout the system as a function of changes in inlet pCO_2 , cell current density, and process air flow rate. The location of the sampling taps are shown in Figure 14. The results of the tests are presented in Table 3 and were used to verify math model prediction. The subsystem was tested using existing ground support test equipment which was not capable of supplying the total process air requirement to the plenum inlet. Only cooling air was supplied to the plenum. Process air was supplied to the electrochemical modules by a separate Air Supply Unit (ASU) at the required pCO_2 , dew point, and dry bulb temperature. The cooling air stream was at ambient pCO_2 levels, but the temperature and dew point were maintained close to that of the process air from the ASU. Exact temperature and dew point correlation, however, was not obtained. Table 3 represents the data as if the CS-6 had been run in its designed configuration (i.e., all process air entering the plenum). Slight discrepancies in stream temperatures and dew points are present, but they had no affect on the modeling effort.

Hydrogen Flow Sensor and Distribution Mounting

The two H_2 flow sensor and distribution mounting blocks were characterized to obtain the nitrogen (N_2) and H_2 pressure drops as a function of flow rate through the distribution mounting. The results of the N_2 and H_2 pressure drop experiments are given in Figure 15. The H_2 pressure drop through the EDC modules was also characterized and is presented in Figure 16.

CS-6 BASE PROGRAM

The CS-6 Base Program is the computer program that was written to simulate the steady-state performance of the CS-6 as a function of variations in inlet stream composition temperatures and flow rates, outlet stream pressures, and the CS-6




FIGURE 14 LOCATION OF GAS SAMPLING PORTS

TABLE 3 CS-6 INTERCOMPONENT INTERFACE PARAMETERS FOR
BASELINE OPERATING CONDITIONS^(a)

	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>	<u>11</u>	<u>12</u>
Flow Rate, dm ³ /s	210	165	25	19	25	19	25	19	210	0.162	0.162	0.154
Scfm	444	350	54	40	54	40	54	40	444	-	-	-
S1pm	-	-	-	-	-	-	-	-	9.7	9.7	9.7	9.25
Pressure, (b) kN/m ²	0.242	0.075	-0.580	X ^(c)	1.910	0.030	0.062	X	0.060	51.3	34.6	X
In H ₂ O	0.97	0.30	-2.33	X	-7.67	0.12	0.25	X	0.24	-	-	-
Psig	-	-	-	-	-	-	-	-	-	7.4	5.0	X
Temperature, K	284	284	286	284	291	290	299	X	284	297	297	291
F	51.5	51.5	55.8	51.5	64.8	63.0	78.5	X	51.8	76.0	76.0	65.0
Dew Point, K	277	277	282	277	284	277	284	277	279	296	296	286
F	40.0	40.0	48.0	40.0	51.2	40.0	51.2	40.0	43.2	74.0	74.0	56.0

(a) Cell current = 4.88A.

(b) Above ambient.

(c) X indicates data not taken.




FIGURE 15 H₂ DISTRIBUTION BLOCK PRESSURE DROP
FOR PROCESS H₂ AND N₂ PURGE




FIGURE 16 H₂ PRESSURE DROP ACROSS MODULES

control parameters. The CS-6 input variable ranges are given in Table 4. All inputs to the computer program are entered in the engineering units shown in Table 4. Table 5 is a complete list of the program input and output variables and their units. The program also provides various checks to insure that input data is within the model's range of predictability and to identify out-of-tolerance operating conditions.

The program contains previously developed correlations describing the performance of the EDC cells.⁽¹⁾ Additional correlations were developed describing CS-6 subsystem LRUs and process streams. The Base Program combines these correlations with steady-state mass and energy balances, and the program checks to simulate steady-state CS-6 performance. The original EDC math model computer program was not used directly as a subroutine in the Base Program since the assumption of cooling air being delivered at the required rate, optimum moisture balance conditions, and exact control of module temperature were not applicable because of the characteristics of the subsystem hardware. A certain amount of program rearranging was also desired to decrease computer running time by calculating those items that require an iterative solution prior to the gross calculation of stream variables.

Model Analyses

The math model which resulted in the CS-6 Base Program was developed by first defining the inlet and outlet stream characteristics and parameters for the CS-6 at the subsystem level. An initial computer program was written to describe the subsystem interfaces by expanding the math model developed for the EDC cells. The analyses that were used to derive the mathematical expressions describing the CS-6 intercomponent interface parameters were developed and incorporated into the initial program as required to calculate the remaining program outputs.

To clarify variable notation, numerical identifiers were given to the process streams and equation variables. The stream identification numbers are presented in Figure 17.

Process Air Correlations

The inlet process air stream to the CS-6 is divided into three streams: the cooling air stream, the process (cathode) air stream, and the air plenum bypass stream. Mathematical expressions were required and developed to describe the stream flow characteristics and blower power requirements.

Cooling Air Pressure Drop. The pressure drop associated with flow through the cooling air passages is the same as the pressure drop measured across the cooling air fins of the electrochemical modules since the pressure drop associated with the ducting is negligible. The correlation describing the cooling air passage pressure drop was derived by a least squares curve fit of pressure drop data as a function of air flow rate to a general quadratic equation. The equation was forced to pass through the origin so that there would be zero pressure

TABLE 4 CS-6 BASE PROGRAM INPUT VARIABLE RANGES

Cabin Atmosphere

Total Pressure, P0PSA	13.7-15.7 Psia
pCO ₂ , PC0	0.5-10 mm Hg
pO ₂ , PO0PSA	2-4 Psia

Process Air Outlet

Total Pressure, P8PSA	13.7-15.7 Psia
-----------------------	----------------

Process Air Inlet

Temperature, T7	44-80F
Flow Rate, V7	0-600 Scfm (a)
Dew Point Temperature, DW7	41-70F

Anode H₂/CO₂ Outlet

Total Pressure, P4PSA	14.8-21.2 Psia
-----------------------	----------------

System H₂ Inlet

Temperature, T9	65-75F
Flow Rate, V9SL	0-18 Scfm (a)
Dew Point Temperature, DW9	10-75F

Modules

Number of Cells in Current, N	90-96
Current, I	2.44-9.76 A
DELT1 ^(b)	10-25F
Cathode Air Flow Rate, V1	19.2-76.8 Scfm (96 cells)

Penalty Weight Factors

Power, PWOPEN	0-2 Lb/Watt
Heat Rejection to Ambient, HTPEN	0-2 Lb/Btu/Hr
Water Vapor Rejection to Ambient, H2OPEN	0-500 Lb/Lb H ₂ O/Hr
Oxygen Consumption, OXOPEN	0-3000 Lb/Lb O ₂ /Hr

Program Control

NFLAG ^(c)	0-1
----------------------	-----

(a) Reference conditions for standard flow units: 70F, 14.7 Psia

(b) DELT1 = (Module temperature - cathode air inlet dew point temperature)

(c) NFLAG = 0 Out of tolerance moisture conditions do not stop program.

1 Out of tolerance moisture conditions do stop program.

TABLE 5 CS-6 BASE PROGRAM INPUT AND OUTPUT VARIABLES

Input Variables

Cabin Atmosphere	Total Pressure, Psia pCO ₂ , mm Hg pO ₂ , Psia
Process Air Outlet	Total Pressure, Psia
Process Air Inlet	Temperature, F Flow Rate, Scfm Dew Point Temperature, F
Anode H ₂ /CO ₂ Outlet	Total Pressure, Psia
Anode H ₂ Inlet	Temperature, F Flow Rate, Slpm Dew Point Temperature, F
Modules	Number of Cells in Circuit Current, A DELT1 ^(a) , F Cathode Air Flow Rate, Scfm
Penalty Weight Factors	Power Consumption, Lb/Watt Heat Rejection, Lb/Btu/Hr Water Vapor Rejection, Lb/Lb/Hr O ₂ Consumption, Lb/Lb/Hr
Control	NFLAG 0 = ignore out-of-tolerance moisture conditions 1 = abort for out-of-tolerance moisture conditions

Output Variables

Control	Preferred Value of DELT1 ^(a) , F
Module	Transfer Index, Lb CO ₂ /Lb O ₂ Transfer Efficiency, % Cell Voltage, V Module Voltage, V CO ₂ Removal Rate, Lb/Hr O ₂ Consumption Rate, Lb/Hr H ₂ Consumption Rate, Lb/Hr Water Production Rate, Lb/Hr Current Density, A/Ft ² Heat Load of Modules, Btu/Hr Power Production of Modules, Watt

(a) DELT1 = Module Temperature - Inlet Cathode Air Dew Point Temperature

-continued-

Table 5 - continued

Cathode Air Inlet	Total Pressure, mm Hg pCO ₂ , mm Hg pH ₂ O, mm Hg CO ₂ Flow Rate, Lb/Hr Water Flow Rate, Lb/Hr CO ₂ Flow Rate, Scfm Water Flow Rate, Scfm O ₂ Flow Rate, Scfm N ₂ Flow Rate, Scfm Temperature, F Dew Point Temperature, F Relative Humidity, %
Cathode Air Outlet	Total Pressure, mm Hg Module Cathode Air Pressure Drop, mm Hg pCO ₂ , mm Hg pH ₂ O, mm Hg Total Flow Rate, Scfm CO ₂ Flow Rate, Scfm Water Flow Rate, Scfm O ₂ Flow Rate, Scfm N ₂ Flow Rate, Scfm CO ₂ Flow Rate, Lb/Hr Water Flow Rate, Lb/Hr Temperature, F Dew Point Temperature, F Relative Humidity, % Cathode Air Blower Outlet Total Pressure, mm Hg Cathode Air Blower Outlet Flow Rate, Scfm Cathode Air Blower Outlet Temperature, F
Process Air Inlet	Total Pressure, mm Hg pH ₂ O, mm Hg pN ₂ , mm Hg CO ₂ Flow Rate, Scfm Water Flow Rate, Scfm O ₂ Flow Rate, Scfm N ₂ Flow Rate, Scfm Dew Point Temperature, F Relative Humidity, %
Process Air Outlet	Total Pressure, mm Hg pCO ₂ , mm Hg Plenum Bypass Flow Rate, Scfm Plenum Bypass Pressure Drop, mm Hg Total Flow Rate, Scfm Water Flow Rate, Scfm CO ₂ Flow Rate, Scfm

Table 5 - continued

Process Air Outlet	O ₂ Flow Rate, Scfm pH ₂ O, mm Hg Temperature, F Dew Point Temperature, F Relative Humidity, %
H ₂ Inlet	Total Pressure, mm Hg Water Vapor Pressure, mm Hg Distribution Block Pressure Drop, mm Hg Module Inlet Total Pressure, mm Hg Module Inlet pH ₂ O, mm Hg Module Inlet pH ₂ , mm Hg Total Flow Rate, Scfm H ₂ Flow Rate, Scfm Water Flow Rate, Scfm H ₂ Flow Rate, Lb/Hr Minimum Required Flow Rate, Slpm
H ₂ Outlet	Total Pressure, mm Hg Module Anode Gas Pressure Drop, mm Hg Water Vapor Pressure, mm Hg Flow Rate, Scfm CO ₂ Flow Rate, Scfm H ₂ Flow Rate, Scfm Water Flow Rate, Scfm Flow Rate, Slpm CO ₂ Flow Rate, Slpm H ₂ Flow Rate, Slpm Total Flow Rate, Lb/Hr CO ₂ Flow Rate, Lb/Hr H ₂ Flow Rate, Lb/Hr Water Flow Rate, Lb/Hr Dew Point Temperature, F CO ₂ -H ₂ Weight Ratio, Lb CO ₂ /Lb H ₂ H ₂ -CO ₂ Volume Ratio, Slpm H ₂ /Slpm CO ₂
Heat Balance, Modules	Modules Heat Load, Btu/Hr Cathode Air Heat Pickup, Btu/Hr Anode Gas Heat Pickup, Btu/Hr Cooling Air Heat Pickup, Btu/Hr
Cooling Air	Inlet Pressure, mm Hg Coolant Channel Pressure Drop, mm Hg Outlet Pressure, mm Hg Flow Rate, Scfm Inlet Temperature, F Outlet Temperature, F

Table 5 - continued

Cooling Air	Heat Transfer Coefficient, Btu/Hr/Ft ² /F Fin Efficiency, % Flow Rate Over Cells in Circuit, Scfm In Circuit Outlet Temperature, F Cooling Blower Outlet Pressure, mm Hg Cooling Blower Outlet Flow Rate, Scfm Cooling Blower Outlet Temperature, F Cooling Damper Pressure Drop, mm Hg Minimum Leakage Flow Rate, Scfm
Actual Volumetric Flow Rates	Modules Cathode Air Inlet, Cfm Modules Cathode Air Outlet, Cfm Modules H ₂ Inlet, Cfm Modules H ₂ -CO ₂ Outlet, Cfm Modules Cooling Air Inlet, Cfm Modules Cooling Air Outlet, Cfm Modules Cooling Air Outlet From Cells in Circuit, Cfm Process Air Inlet, Cfm Process Air Outlet, Cfm System H ₂ Inlet, Cfm Process Air Plenum Bypass Outlet, Cfm Cathode Air Blowers Outlet, Cfm Cooling Blowers Outlet, Cfm Cooling Dampers Outlet, Cfm
Equivalent Weight	Cooling Blower Power, Watt Cathode Blower Power, Watt Primary Controller Power, Watt Emergency Controller Power, Watt Data Acquisition Unit Power, Watt Total System Power, Watt Total Heat Rejection, Btu/Hr Power Consumption Penalty Weight, Lb Heat Rejection Penalty Weight, Lb Water Vapor Rejection Penalty Weight, Lb O ₂ Consumption Penalty Weight, Lb Hardware Weight, Lb Total Equivalent Weight, Lb




FIGURE 17 PROCESS STREAM IDENTIFICATION NUMBERS

drop at zero air flow rate. The correlation derived for the pressure drop as a function of cooling air flow rate was

$$\Delta P_{56} = 0.0101 V_5 + 1.303 \times 10^{-5} V_5^2 \text{ (a)} \quad (1)$$

where

ΔP_{56} = the cooling air pressure drop, mm Hg

V_5 = the cooling air flow rate, scfm

Plenum Bypass Pressure Drop. Air that is not drawn through the electrochemical modules or over the cooling fins bypasses the subsystem hardware through the air plenum bypass. A correlation describing the pressure drop as a function of the air plenum bypass flow rate was derived from experimental data. The experimental data was curve-fitted to a general equation describing the pressure drop as a function of the plenum bypass air flow rate squared. The mathematical expression obtained is

$$\Delta P_{78} = 2.25 \times 10^{-5} V_{10}^2 \quad (2)$$

where

ΔP_{78} = the air plenum bypass pressure drop, mm Hg

V_{10} = the air plenum bypass flow rate, scfm

The pressure drop was expressed as the square of the flow rate because of the high turbulent flow characteristics and the dominance of entrance and exit effects within the plenum bypass. The turbulence and entrance and exit effects both lead to a second power relationship^(6,7).

Cooling Air Damper Leakage Pressure Drop. Pressure drop associated with the cooling air dampers occurs when the cooling air blowers are off and cooling air leaks around the dampers. The geometry of the closed dampers is such that a slot flow correlation was indicated. The correlation derived from experimental data is

$$\Delta P_{1213} = 8.6117 \times 10^{-4} V_5^2 \quad (3)$$

where

ΔP_{1213} = the cooling air damper pressure drop, mm Hg

V_5 = the cooling air flow rate, scfm

The cooling air damper correlation presented only applies when the cooling air blowers are off. The dampers are weighted such that when the cooling air

(a) All variables used in the equation presented in the Model Analyses section use the common engineering units since the equations were derived for direct use in the computer program.

blowers start, the dampers open. The cooling damper leakage pressure drop is assumed to remain constant as the dampers open.

Flow Rate Through the Cooling Air Dampers. When the cooling air blowers are off, it is necessary to determine the cooling air flow rate caused by cooling air damper leakage. Air that is not drawn through the cathode compartments of the EDC cells must either flow through the cooling air dampers or the air plenum bypass during cooling air blower off operation. The air flow division is given by the equation

$$V7 = V10 + V5 + V1 \quad (4)$$

where

$V7$ = the inlet plenum air flow rate, scfm

$V1$ = the process (cathode) air flow rate, scfm

The pressure drop through the air plenum bypass and the cooling air dampers must be equal, and the air flow will therefore divide to obtain the equal pressure drops. The pressure drop equality is given by the equation

$$\Delta P78 = P56 + \Delta P1213 \quad (5)$$

The division of air flow rate between the air plenum bypass and the cooling air cavities can be calculated by solving equations (1-5) simultaneously for $V5$, given $V1$ and $V7$. The resulting equation is

$$V5 = \frac{-QB + [QB^2 - 4(QA)(QC)]^{1/2}}{2QA} \quad (6)$$

where

$$QA = -8.517 \times 10^{-4}$$

$$QB = (4.5 \times 10^{-5})(V7 - V1) + 0.0101$$

$$QC = -2.25 \times 10^{-5} (V7 - V1)^2$$

Substitution of $V1$, $V7$, and $V5$ into equations (2-5) yields $V10$, $\Delta P78$, $\Delta P56$, and $\Delta P1213$, respectively.

Process Air Inlet Pressure. The process air inlet pressure is calculated after the heat balance is done and all flow rates have been established through the three air passages. The inputs to the math model are the outlet pressure at the plenum as would be specified by the subsystem interfacing downstream of the CS-6. The process air inlet pressure then is equal to the outlet pressure plus the pressure drop across the plenum bypass, as given by the equation

$$P7 = P8 + \Delta P78 \quad (7)$$

where

P_7 = the process air inlet pressure, mm Hg

P_8 = the process air outlet pressure, mm Hg

EDC Module Pressure Drop. The expression for the process air drawn through the cathode compartment of the EDC cells was derived from experimental data. A general quadratic equation passing through the origin was least squares fit to the experimental data. The equation obtained is

$$\Delta P_{12} = 0.04877V_1 + 0.001903V_1^2 \quad (8)$$

where

ΔP_{12} = the EDC module pressure drop, mm Hg

Process Air Blower Power. The expression for the process air blower power as a function of air flow rate was derived from the experimental data gathered on both blowers. Because of the spike in the power curve caused by the blower speed controller, the total power curve was modeled by three straight line segments. The equations derived were

$$PWRCTB = 2.8V_1 + 153.8; \text{ for } V_1 \leq 62 \quad (9)$$

$$PWRCTB = 40V_1 - 2150; \text{ for } 62 < V_1 \leq 65 \quad (10)$$

$$PWRCTB = -34V_1 + 2660; \text{ for } 65 < V_1 \leq 70 \quad (11)$$

where

$PWRCTB$ = the process (cathode) air blower power, W

Cooling Air Blower Power. The cooling air blower power is a function of the cooling air flow rate and the air plenum bypass pressure drop. As air plenum bypass pressure drop increases (higher bypass flow rates), cooling air blower power was observed to decrease for a given cooling requirement. This decrease is caused by the increased leakage flow rate through the cooling air dampers at the higher plenum bypass pressure drop. Cooling blower power as a function of air flow rate was measured experimentally for two air plenum pressure drops. The correlations obtained through curve fitting for the two power curves are given by the equations

$$PWH = 410 - 0.00396 (V_5 - 368)^2 \quad (12)$$

$$PWL = 410 - 0.00178 (V_5 - 306)^2 \quad (13)$$

where

PWH = the power at ΔP_{78} of 1.25 in water, W

PWL = the power at ΔP_{78} of 0.05 in water, W

An empirically derived interpolation parameter, TR, is used to calculate the cooling air blower power at different plenum bypass pressure drops. The interpolation equation obtained was

$$\text{PWRCLB} = (\text{TR})(\text{PWH}) + (1-\text{TR})(\text{PWL}) \quad (14)$$

where

PWRCLB = the cooling blower power, W

$$\text{TR} = \left(\frac{\Delta P78}{2.4297} + 0.0385 \right)^A \quad (15)$$

$$A = 0.128 + 0.0546\Delta P78 \quad (16)$$

Process Hydrogen Correlations

Correlations for the process H₂ stream were required to calculate the EDC module H₂ pressure drop as a function of H₂ flow rate, H₂ pressure drop across the H₂ flow and sensor distribution mounting, and to upgrade the anode gas outlet dew point correlation used in the EDC cell math model.

EDC Module Hydrogen Pressure Drop. The pressure drop through the anode compartment of the 16 series connected EDC cells as a function of H₂ flow rate was derived from experimental data. The two equations describing the anode compartment pressure drop are

$$\Delta P34 = 0.3822 \left(\frac{14.1}{P4} \right)^{0.8} V3; \text{ for } V3 < 22 \quad (17)$$

$$\Delta P34 = \left(\frac{14.1}{P4} \right)^{0.8} [8.3183 + 0.4187 (V3 - 21.5801)^{1.75}] \text{ for } V3 \geq 22 \quad (18)$$

where

$\Delta P34$ = the anode pressure drop, mm Hg

$V3$ = the H₂ flow rate, slpm

$P4$ = the anode gas outlet pressure, psia

Hydrogen Distribution Mounting Pressure Drop. The pressure drop associated with H₂ flow through the H₂ distribution mounting was derived from experimental data. The two equations obtained are

$$\Delta P93 = 10.64 \left(\frac{14.1}{P3} \right)^{0.8} V3; \text{ for } V3 \leq 6.2 \quad (19)$$

$$\Delta P_{93} = \left(\frac{14.1}{P_3}\right)^{0.8} [35.14V_3 - 195.25 + e^{(7.75-0.6537V_3)}] ; \text{ for } V_3 > 6.2 \quad (20)$$

where

ΔP_{93} = the H_2 distribution mounting pressure drop, mm Hg

P_3 = module H_2 inlet pressure, psia

Anode Gas Dew Point Correlation. The anode gas dew point can be estimated from the module temperature and the inlet and outlet cathode air dew points. The correlation derived from experimental data is given by the equation

$$DW_4 = 0.77 \left(\frac{DW_1 + DW_2}{2}\right) + 0.23 (T_2) \quad (21)$$

where

DW_4 = anode gas outlet dew point, F

DW_1 = cathode air inlet dew point, F

DW_2 = cathode air outlet dew point, F

T_2 = module temperature, F

The data that was used to derive the correlation is presented in Table 6.

EDC Module Correlations

The EDC cell and module math model previously developed required upgrading in three areas: the module temperature and heat balance, the effect of process (cathode) air flow rate on CO_2 removal efficiency, and the effect of cell moisture conditions on CO_2 removal efficiency.

Module Temperature Correlation. The process (cathode) air out temperature, defined as the module temperature, is controlled to a set level above the process air inlet dew point temperature. The module temperature is maintained by controlling the cooling air blower speed to give the desired process air outlet to inlet air dew point temperature differential. Four conditions exist which prevent the module temperature control from maintaining the temperature differential:

1. Insufficient blower capacity.
2. Excessive cooling air damper leakage.
3. Insufficient cooling air temperature.
4. Insufficient module heat generation.

TABLE 6 ANODE GAS OUTLET DEW POINT TEMPERATURE CORRELATION DATA^(a)

Inlet Cathode Air Dew Point Temperature, K	280.9	281.4	280.3	281.4
Inlet Cathode Air Dew Point Temperature, F	46.0	47.0	45.0	47.0
Outlet Cathode Air Dew Point Temperature, K	284.2	284.0	283.8	284.3
Outlet Cathode Air Dew Point Temperature, F	52.0	51.6	50.0	52.2
Outlet Cathode Air Temperature, K	299.2	299.7	297.0	299.5
Outlet Cathode Air Temperature, F	79.0	79.8	75.0	79.5
Outlet Anode Gas Dew Point Temperature				
Observed, K	286.4	286.7	285.2	286.8
Observed, F	56.0	56.5	53.8	56.6
Calculated, K	286.4	286.6	285.2	286.7
Calculated, F	55.9	56.3	53.8	56.5

(a) CS-6 anode gas dew point data obtained during math model testing.

Should one of these four conditions occur, it is necessary to calculate what temperature the module will reach with the cooling air blowers in operating range (off to maximum capacity). The new module temperature is iteratively determined by solving the heat balance equations for cell voltage, heat generated, fin heat transfer coefficient, fin efficiency, heat removal by the gas streams, and the log mean temperature driving force for heat removal until the following two equations are satisfied:

$$DTREQ = DTAVA \quad (22)$$

$$HEATLOAD = \Delta H_{air} + \Delta H_{H_2} + \Delta H_{cool} \quad (23)$$

where

DTREQ = the required log mean ΔT driving force

DTAVA = the available log mean ΔT driving force

HEATLOAD = the heat generated

ΔH_{air} = the heat removed by the process (cathode) air

ΔH_{H_2} = the heat removed by the anode gas

ΔH_{cool} = the heat removed by the cooling air

Air Flow Correlation. Experimental data indicated that the correlation originally developed to predict CO_2 removal as a function of process (cathode) air flow rate required upgrading. The air flow correlation was therefore upgraded based on CS-6 performance data⁽²⁾. The new correlation that was obtained is given by the equations

$$PA = (pCO_2) (V1/0.44N)^f(pCO_2) \quad (24)$$

$$f(pCO_2) = [1 + 0.84 (pCO_2)] e^{-0.84 (pCO_2)} \quad (25)$$

where

PA = the normalized pCO_2 for air flow rate, mm Hg

N = the number of EDC cells

The normalized pCO_2 , PA, is then used in place of the actual pCO_2 in the CO_2 removal efficiency correlations.

Moisture Balance-Carbon Dioxide Removal Efficiency Correlation. The original EDC cell math model assumed that moisture was maintained within a preferred

operating range. The CO₂ removal efficiency correlation did not account for changes in CO₂ removal efficiency for moisture conditions outside the preferred range. Moisture conditions outside the preferred range occur since the module temperature to process air inlet dew point temperature differential (DELT1) control does not vary with changes in current and air flow rate. Hardware limitations in controlling DELT1 and improper setting of DELT1 also cause nonpreferred moisture balance conditions to occur. A correlation was therefore developed to account for changes in CO₂ removal efficiency as a function of moisture balance. The correlations derived from experimental data⁽⁵⁾ are given by the equation

$$TI^1 = TI [1 + 0.03536(DELT1 - 18.33)] \quad (26)$$

where

TI^1 = the Transfer Index corrected for moisture balance

TI = the noncorrected Transfer Index

The data that was used to derive the correlation is presented in Figure 18.

Computer Program

The CS-6 Base Program consists of a main program and eight subroutines. The main program manages input and output, directs calculation of heat and mass balances, checks for cooling and cathode air blower operation within range, checks for sufficient H₂ flow, checks plenum bypass flow, checks cell moisture conditions within tolerance, completes all stream definitions, and calculates total subsystem equivalent weight. The subroutines are called by the main program and by each other to calculate water vapor pressure from dew point temperature (PHTO), to calculate the dew point temperature from water vapor pressure (DEWT), to calculate TI (TICOR), to find the root of a function (ROOT), to calculate module temperature offset (TDRIFT), to calculate required and actual module cooling air temperature drops dependent upon module temperature (ERT1), to calculate required and actual module-cooling air temperature drops dependent upon cooling air flow rate (ERT), and to check input variable ranges(T).

Program Description

A detailed description of the program is presented in the main program flow chart and the subroutine flow charts, Appendix A. The program can be represented by ten major divisions for simplicity.

1. Read in and playback input data.
2. Check input ranges.
3. Check for sufficient H₂ flow and cathode blowers within range.




FIGURE 18 EFFECT OF MOISTURE CONDITIONS ON TRANSFER INDEX

4. Perform the heat balance including iterative solution governing module's heat load, cooling fin efficiency and heat transfer coefficient, cooling air flow rate, and module temperature.
5. Check the plenum bypass flow rate.
6. Calculate only stream parameters required for moisture balance checks.
7. Check module moisture conditions.
8. Complete all stream definitions.
9. Calculate subsystem equivalent weights.
10. Output results.

Also contained in Appendix A are the CS-6 Base Program Listing, the checks and messages performed by the program, and the nomenclature and units' definitions.

Program Assumptions

The following assumptions were made in developing the CS-6 Base Program:

1. Gas pressures are governed by the Ideal Gas Law and Dalton's Law.
2. Inlet H_2 flow rate greater than 1.3 times the stoichiometric amount does not affect TI.
3. Cabin air contains only N_2 , O_2 , CO_2 , and water in significant amounts.
4. Heat losses, leaks, and pressure drops in intercomponent lines are negligible.
5. The number of allowable cells in CS-6 is 90-96.
6. Pressure drops depend upon standard flow rates only, except in the H_2 sensor block and anode passages, where absolute pressure may differ significantly from atmospheric.
7. Transfer Index is proportional to a power of cathode air flow which approaches 1 as pCO_2 approaches 0, and diminishes to 0 as pCO_2 increases.
8. The dependence of TI upon moisture conditions is approximated by a linear function of the difference between module temperature and inlet cathode air dew point temperature.
9. Steady-state exists in the subsystem.
10. At least 5% of the inlet process air must pass through the plenum bypass to prevent backmixing of the outlet stream with the inlet stream.

11. The outlet H₂ dew point temperature is approximated by a weighted average of the module temperature, the inlet cathode air dew point, and the outlet cathode air dew point. Cathode air removes the remaining moisture produced.
12. Cooling air dampers remain closed when the cooling blowers are off.
13. When open, cooling dampers' pressure drop remains constant.
14. Heat loss of modules and blowers to the ambient air is negligible.
15. Primary controller, emergency controller, and data acquisition unit (DAU) reject waste heat only to the ambient.
16. Activation of valves is brief (less than one second) and adds no significant power penalty.
17. Cooling air blower power depends upon flow rate reaching a plateau and declining slightly at maximum flow. At lower flow rates, the power depends increasingly upon the plenum bypass pressure drop.
18. Cathode air blower power depends upon flow rate. The prediction range does not extend to very low flow rates, and the effect of differential pressure is neglected.
19. Cooling fin efficiency and heat transfer coefficient depend on cooling air flow rate only.
20. Differences between cells, modules, and sections are insignificant.
21. Inlet cooling air and inlet cathode air have the same temperature and pressure.

Program Features

The following features were incorporated into the CS-6 Base Program.

1. The program checks each set of input data to insure that each parameter is within its prediction range.
2. Cooling air flow rate is calculated for the set point module temperature. Under certain conditions, however, the subsystem hardware is unable to provide the required cooling air flow rate to control module temperature at the set point. These conditions are (1) insufficient blower capacity, (2) excessive cooling damper leakage, (3) insufficient cooling air temperature, and (4) insufficient module heat generation. For these conditions program logic calculates the temperature to which the modules would drift with the cooling blowers in range, and proceeds.
3. All significant pressure drops are calculated based on flow rates and, where appropriate, absolute pressure.

4. Inlet stream pressures are calculated based on outlet stream pressures and system pressure drops.
5. All significant component power consumptions and heat rejections are calculated. All intermediate streams are completely specified regarding temperature, pressure, composition, and flow rate.
6. Total subsystem equivalent weight is calculated from adjustable penalty factors for heat rejection, power consumption, O_2 consumption, and water rejection.
7. Input data may be entered directly from a terminal or from a previously prepared data file for convenience when a large number of problems are to be done during the same run.

Model Results

Sample problems were run using the CS-6 Base Program to verify the model's predictability for subsequent incorporation into the CS-6 Cabin pCO₂ Simulation Program. Output data from the program was checked against experimental data and the model upgraded throughout the development phase. Several sample outputs are presented in Appendix B. The results corresponded well to experimental data as expected since the major math model correlations (i.e., CO₂ removal efficiency, blower power, gas stream pressure drop, etc.) are empirically based.

CS-6 CABIN pCO₂ SIMULATION PROGRAM

The CS-6 Cabin pCO₂ Simulation Program is the computer program that was developed to simulate the steady-state spacecraft cabin pCO₂ profile resulting from the interaction of a repeating daily metabolic CO₂ generation profile and the CS-6 as the spacecraft CCS for a given cabin volume.

The program calculates and outputs cabin pCO₂, CO₂ removal rate and efficiency, cell voltage, subsystem power requirements, subsystem equivalent weight, and other subsystem parameters as a function of time for a given CO₂ generation profile. A list of the input variable ranges and their units are presented in Table 7. The complete list of input and output variables and their units are presented in Table 8.

Model Analysis

The specific functions performed by the pCO₂ simulation program are to define Mode B (if required) from the input parameters and perform the integration over each time interval to calculate the change in cabin pCO₂ (for both Mode A and Mode B).

Mode B Definition

A typical Mode B control scheme is presented in Figure 19. Current and air flow vary linearly with cabin pCO₂. Two sets of input data are used to define Mode B; the minimum and maximum pCO₂ levels and their corresponding current and air

TABLE 7 CS-6 CABIN $p\text{CO}_2$ SIMULATION PROGRAM
INPUT VARIABLE RANGES

Cabin Atmosphere

Total Pressure, P0PSA	13.7-15.7 Psia
$p\text{CO}_2$, PC0	0.0001-10 mm Hg
$p\text{O}_2$, PO0PSA	2-4 Psia
Temperature, T0	44-80F
Volume, VOLUME	10^2 - 10^5 Ft ³

Process Air Outlet

Total Pressure, P8PSA	13.7-15.7 Psia
-----------------------	----------------

Process Air Inlet

Temperature, T7	44-80F
Flow Rate, V7	0-600 Scfm ^(a)
Dew Point Temperature, DW7	41-70F

Anode H₂/CO₂ Outlet

Total Pressure, P4PSA	14.8-21.2 Psia
-----------------------	----------------

System H₂ Inlet

Temperature, T9	65-75F
Flow Rate, V9SL	0-18 Scfm ^(a)
Dew Point Temperature, DW9	10-75F

Modules

Number in Circuit, N	90-96
Current ^(b) I	2.44-9.76 A
DELT1	10-25F
Cathode Air Flow Rate, V1	5.0-76.8 Scfm (96 cells)

Penalty Weight Factors

Power, PWOPEN	0-2 Lb/Watt
Heat Rejection to Ambient, HTPEN	0-2 Lb/Btu/Hr
Water Vapor Rejection to Ambient, H2OPEN	0-500 Lb/Lb H ₂ O/Hr
Oxygen Consumption, OXOPEN	0-3000 Lb/Lb O ₂ /Hr

Program Control

KMODE ^(c)	0-1
NFLAG ^(d)	0-1
Minimum Current, BK(1)	2.44-9.76 A

(a) Reference conditions for standard flow units: 70F, 14.7 Psia

(b) DELT1 = Module temperature - cathode air inlet dew point temperature

(c) KMODE = 0 Mode A

1 Mode B

(d) NFLAG = 0 Out of tolerance moisture conditions do not stop program.

1 Out of tolerance moisture conditions do stop program.

Table 7 - continued

pCO ₂ for Minimum Current, BK(2)	0.0001-10 mm Hg
pCO ₂ for Maximum Current, BK(3)	0.0001-10 mm Hg
Maximum Current, BK(4)	2.44-9.76 A
Minimum Cathode Air Flow Rate, BK(5)	5.0-76.8 Scfm
pCO ₂ at Minimum Cathode Air Flow Rate, BK(6)	0.0001-10 mm Hg
pCO ₂ at Maximum Cathode Air Flow Rate, BK(7)	0.0001-10 mm Hg
Maximum Cathode Air Flow Rate, BK(8)	5.0-76.8
Number of Days to be Simulated, DAYS	0-10 Days (a) 1-15 Minutes (b)
Integration Time Increment, DT	
Output Table Time Increment, DPRINT	1-100 Minutes

(a) DT must be chosen so that the length of each time step in the CO₂ generation rate table is a whole multiple of DT.

(b) DPRINT must be a whole multiple of DT.

TABLE 8 CS-6 CABIN pCO_2 SIMULATION PROGRAM
INPUT AND OUTPUT VARIABLES

Input Variables

Cabin Atmosphere	Total Pressure, Psia pCO_2 , mm Hg pO_2 , Psia Temperature, F Volume, Ft ³
Process Air Outlet	Total Pressure, Psia
Process Air Inlet	Temperature, F Flow Rate, Scfm Dew Point Temperature, F
Anode H_2/CO_2 Outlet	Total Pressure, Psia
Anode H_2 Inlet	Temperature, F Flow Rate, Slpm Dew Point Temperature, F
Modules	Number of Cells in Circuit Current, A DELT1, F Cathode Air Flow Rate, Scfm
Penalty Weight Factors	Power Consumption, Lb/Watt Heat Rejection, Lb/Btu/Hr Water Vapor Rejection, Lb/Lb/Hr O_2 Consumption, Lb/Lb/Hr
Control	KMODE 0 = Mode A, 1 = Mode B NFLAG 0 = ignore out-of-tolerance moisture conditions 1 = abort for out-of-tolerance moisture conditions
Mode B	Minimum Current, A pCO_2 for Minimum Current, mm Hg pCO_2 for Maximum Current, mm Hg Maximum Current, A Minimum Cathode Airflow, Scfm pCO_2 for Minimum Airflow, mm Hg pCO_2 for Maximum Airflow, mm Hg Maximum Cathode Airflow, Scfm Maximum Number of Days to be Integrated, Day Integration Increment, Min Printing Increment, Min

Output Variables

Control	Preferred Value of DELT1 ^(a) , F
---------	---

-continued-

(a) DELT1 = Module Temperature - Inlet Cathode Air
Dew Point Temperature

Table 8 - continued

Module	Transfer Index, Lb CO ₂ /Lb O ₂ Transfer Efficiency, % Cell Voltage, V Module Voltage, V CO ₂ Removal Rate, Lb/Hr O ₂ Consumption Rate, Lb/Hr H ₂ Consumption Rate, Lb/Hr Water Production Rate, Lb/Hr Current Density, A/Ft ² Heat Load Modules, Btu/Hr Power Production of Modules, Watt
Cathode Air Inlet	Total Pressure, mm Hg pCO ₂ , mm Hg pH ₂ O, mm Hg CO ₂ Flow Rate, Lb/Hr Water Flow Rate, Lb/Hr CO ₂ Flow Rate, Scfm Water Flow Rate, Scfm O ₂ Flow Rate, Scfm N ₂ Flow Rate, Scfm Temperature, F Dew Point Temperature, F Relative Humidity, %
Cathode Air Outlet	Total Pressure, mm Hg Module Cathode Air Pressure Drop, mm Hg pCO ₂ , mm Hg pH ₂ O, mm Hg Total Flow Rate, Scfm CO ₂ Flow Rate, Scfm Water Flow Rate, Scfm O ₂ Flow Rate, Scfm N ₂ Flow Rate, Scfm CO ₂ Flow Rate, Lb/Hr Water Flow Rate, Lb/Hr Temperature, F Dew Point Temperature, F Relative Humidity, % Cathode Air Blower Outlet Total Pressure, mm Hg Cathode Air Blower Outlet Flow Rate, Scfm Cathode Air Blower Outlet Temperature, F
Process Air Inlet	Total Pressure, mm Hg pH ₂ O, mm Hg pN ₂ , mm Hg CO ₂ Flow Rate, Scfm Water Flow Rate, Scfm

Table 8 - continued

	O ₂ Flow Rate, Scfm
	N ₂ Flow Rate, Scfm
	Dew Point Temperature, F
	Relative Humidity, %
Process Air Outlet	Total Pressure, mm Hg
	pCO ₂ , mm Hg
	Plenum Bypass Flow Rate, Scfm
	Plenum Bypass Pressure Drop, mm Hg
	Total Flow Rate, Scfm
	Water Flow Rate, Scfm
	CO ₂ Flow Rate, Scfm
	O ₂ Flow Rate, Scfm
	pH ₂ O, mm Hg
	Temperature, F
	Dew Point Temperature, F
	Relative Humidity, %
H ₂ Inlet	Total Pressure, mm Hg
	Water Vapor Pressure, mm Hg
	Distribution Block Pressure and Drop, mm Hg
	Module Inlet Total Pressure, mm Hg
	Module Inlet pH ₂ O, mm Hg
	Module Inlet pH ₂ , mm Hg
	Total Flow Rate, Scfm
	H ₂ Flow Rate, Scfm
	Water Flow Rate, Scfm
	H ₂ Flow Rate, Lb/Hr
	Minimum Required Flow Rate, Slpm
H ₂ Outlet	Total Pressure, mm Hg
	Module Anode Gas Pressure Drop, mm Hg
	Water Vapor Pressure, mm Hg
	Flow Rate, Scfm
	CO ₂ Flow Rate, Scfm
	H ₂ Flow Rate, Scfm
	Water Flow Rate, Scfm
	Flow Rate, Slpm
	CO ₂ Flow Rate, Slpm
	H ₂ Flow Rate, Slpm
	Total Flow Rate, Lb/Hr
	CO ₂ Flow Rate, Lb/Hr
	H ₂ Flow Rate, Lb/Hr
	Water Flow Rate, Lb/Hr
	Dew Point Temperature, F
	CO ₂ -H ₂ Weight, Lb CO ₂ /Lb H ₂
	H ₂ -CO ₂ Volume Ratio, Slpm H ₂ /Slpm CO ₂

Table 8 - continued

Heat Balance, Modules	Modules Heat Load, Btu/Hr Cathode Air Heat Pickup, Btu/Hr Anode Gas Heat Pickup, Btu/Hr Cooling Air Heat Pickup, Btu/Hr
Cooling Air	Inlet Pressure, mm Hg Coolant Channel Pressure Drop, mm Hg Outlet Pressure, mm Hg Flow Rate, Scfm Inlet Temperature, F Outlet Temperature, F Heat Transfer Coefficient, Btu/Hr/Ft ² /F Fin Efficiency, % Flow Rate Over Cells in Circuit, Scfm In Circuit Outlet Temperature, F Cooling Blower Outlet Pressure, mm Hg Cooling Blower Outlet Flow Rate, Scfm Cooling Blower Outlet Temperature, F Cooling Damper Pressure Drop, mm Hg Minimum Leakage Flow Rate, Scfm
Actual Volumetric Flow Rates	Modules Cathode Air Inlet, Cfm Modules Cathode Air Outlet, Cfm Modules H ₂ Inlet, Cfm Modules H ₂ -CO ₂ Outlet, Cfm Modules Cooling Air Inlet, Cfm Modules Cooling Air Outlet, Cfm Modules Cooling Air Outlet From Cells in Circuit, Cfm Process Air Inlet, Cfm Process Air Outlet, Cfm System H ₂ Inlet, Cfm Process Air Plenum Bypass Outlet, Cfm Cathode Air Blowers Outlet, Cfm Cooling Blowers Outlet, Cfm Cooling Dampers Outlet, Cfm
Equivalent Weight	Cooling Blower Power, Watt Cathode Blower Power, Watt Primary Controller Power, Watt Emergency Controller Power, Watt Data Acquisition Unit Power, Watt Total System Power, Watt Total Heat Rejection, Btu/Hr Power Consumption Penalty Weight, Lb Heat Rejection Penalty Weight, Lb Water Vapor Rejection Penalty Weight, Lb O ₂ Consumption Penalty Weight, Lb Hardware Weight, Lb Total Equivalent Weight, Lb




FIGURE 19 CONTROL MODE B (TYPICAL)

flow rates. The program takes the two sets of inputs, determines the slope and intercept for each set of inputs, and defines the equations for current and air flow as a function of pCO_2 . These equations are then used in the pCO_2 integration when control Mode B is requested.

Cabin pCO_2 Integration

To obtain the cabin pCO_2 as a function of time, the main program performs a mass balance on CO_2 in the cabin for each of the integration intervals. Each mass balance yields the pCO_2 value at the end of the interval. The pCO_2 at the end of the interval depends upon the average net CO_2 removal rate during the interval, but the average removal rate depends upon the pCO_2 at the end of the interval. Neither value is known initially, therefore an iterative solution is necessary.

The equations which must be satisfied in the mass balance are:

$$P(t) = P(t-\Delta t) + \frac{1}{2}(\left.\frac{dp}{dt}\right|_t + \left.\frac{dp}{dt}\right|_{t-\Delta t}) \Delta t \quad (27)$$

$$\left.\frac{dp}{dt}\right|_t = k [G(t) - R(P(t))] \quad (28)$$

where

P = cabin pCO_2

t = time

Δt = integration increment

k = proportionality constant between net removal rate of CO_2 and cabin pCO_2

G = CO_2 generation rate, a function of time only, calculated by the main program

R = CO_2 removal rate, a function of cabin pCO_2 only, calculated by the CS-6 BASE subroutine

The use of the arithmetic average derivative in Equation 27 is the same approximation used in Simpson's Rule Integration. The error vanishes when the function $P(t)$ is parabolic over the interval.

All variables are known for time $t-\Delta t$ when the integration begins. An approximation for $P(t)$ is substituted into Equation 28 and solved using the CS-6 BASE subroutine. The result is substituted into Equation 27 to recalculate $P(t)$. The correct $P(t)$ is found when the approximate and the recalculated values of $P(t)$ agree. For the first approximation labeled "1" in Figure 20, it is assumed that $P(t)$ equals $P(t - \Delta t)$.




FIGURE 20 GRAPHIC REPRESENTATION OF CONVERGENCE SCHEME

The first trial value is substituted into Equations 27 and 28, giving a recalculated value. This value is then used as the second trial value of $P(t)$, labeled "2" in Figure 20. The relation between trial and recalculated $P(t)$ is close to linear when the time increments are 15 minutes or less. The final P value, labeled "3" in Figure 20, is at the intersection of the secant through points 1 and 2, and the 45 degree line.

The BASE subroutine is called for the second and third values of P only. It is not necessary for the first trial, which assumes constant pCO_2 , since the CO_2 removal rate would then also be constant. Each integration increment requires only two subroutine calls with the convergence scheme used, compared to ten or more with schemes such as interval halving.

Computer Program

The CS-6 Cabin pCO_2 Simulation Program consists of the main program and a number of subroutines. The main program manages input and output and performs integration of net CO_2 removal to calculate the cabin pCO_2 profile. The BASE subroutine (the CS-6 Base Program adapted with minor modifications) provides all the CS-6 parameters to the main program, including CO_2 removal rate. Subroutines are utilized primarily by the BASE subroutine to relate water vapor pressure and dew point temperature, to calculate the CO_2 Transfer Index (TI), to find the root of a function, to calculate temperatures and flow rates, to satisfy subsystem heat balance, to check input parameters against their allowable ranges, and to calculate current and cathode air flow rate for Mode B CS-6 operation.

Program Description

A detailed description of the CS-6 Cabin pCO_2 Simulation Program is presented in the main program flow chart and the subroutine flow charts, Appendix C. The program can be divided into 14 major subdivisions for simplicity.

1. Determine input/output devices.
2. Read and write problem identifier.
3. Read in and print out (if desired) CO_2 generation table.
4. Read inputs for CS-6 BASE subroutine, Mode B parameters, integration and print out parameters.
5. Determine whether table describing CS-6 at time zero is to be printed, and input subscripts for selected variables to be printed as they vary with time.
6. Calculate Mode B parameters.
7. Print out input data.
8. Check inputs and print names of any that are outside the prediction ranges.

9. Print description at time zero if desired.
10. Print headings for table.
11. Call BASE to perform pCO₂ integration over one or more intervals until printing interval is reached.
12. Print a line in the table.
13. Continue from Step 11 unless it is the end of the day.
14. Continue from Step 2 if steady-state has been reached or if the maximum number of days has been integrated, otherwise continue from Step 10 to integrate pCO₂ for an additional day.

Appendix C also contains the program listing, program checks and messages, nomenclature and units, and the key to select output variables.

Program Assumptions

The following assumptions were made in the development of the CS-6 Cabin pCO₂ Simulation Program.

1. The CO₂ generation profile is a step function of time only.
2. Each step in the CO₂ generation profile is an integer number of minutes.
3. Module set point temperature, an input, does not change during the day. It is not a function of current density or air flow in either Mode A or B.
4. Cabin air is uniform in composition at any time.
5. The Ideal Gas Law applies to the cabin air.
6. The cabin air contains O₂, N₂, CO₂, and water vapor only.
7. Cabin pH₂O, pO₂, and total pressure are constant; pN₂ and pCO₂ vary.
8. The pCO₂ integration time increment, an integer number of minutes, is chosen so that each CO₂ generation step contains an integer number of increments.
9. In Mode B operation, current density and cathode air flow are linear functions of cabin pCO₂ but are bounded by minimum and maximum values.
10. The graph of cabin pCO₂ versus time can be represented by a series of parabolic segments.

Program Features


The following features were incorporated into the CS-6 Cabin pCO₂ Simulation Program:

1. The input items are checked by the program to insure that all are within the prediction ranges.
2. Input may be entered directly from a terminal to take full advantage of operator-program interaction, or from a previously prepared data file for convenience when a large number of runs are to be done at once.
3. Output may be printed directly at the terminal or written in one or more data files for convenience when a large amount of data is involved.
4. A program option allows a table containing all subsystem parameters, both constant and time dependent, to be either printed or omitted at time zero of the simulation.
5. Any number of the subsystem parameters may be selected for printing as they vary at simulated time intervals.
6. The pCO₂ integration performed by the main program combines maximum usage of past values of pCO₂ with an interpolation algorithm so that the BASE subroutine is required only twice during each simulated time interval. The first time, only enough of the BASE subroutine is executed to yield a trial CO₂ removal rate and check for achievement of steady-state in the CS-6.² The second call of the BASE subroutine is extended only enough to calculate the final CO₂ removal rate, the other selected subsystem parameters, and to verify steady-state in the CS-6. These techniques have caused the calculation portion of the program to consume less computing time than the printing of results. Integration accuracy is four significant figures, minimum.

Model Results

The CS-6 Cabin pCO₂ Simulation Program was used to predict the cabin pCO₂ profile and selected CS-6 performance parameters for control Modes A and B. The CO₂ generation profile used for the runs is presented in Figure 21. Sample outputs for the pCO₂ Simulation Program are presented in Appendix D.

Sample cases for control Mode A were run to obtain the steady-state pCO₂ profile that would result, given initial cabin pCO₂ levels of 0 and 1333 N/m² (0 and 10 mm Hg). The results of three typical runs are presented in Figures 22, 23, and 24 for 4.88A, Mode A (1), 3.66A, Mode A (2), and 7.32A, Mode A (3), respectively. The remaining input parameters are presented in Table 9. Similar sample cases for control Mode B were run for initial pCO₂ levels of 0 and 1333 N/m² (0 and 10 mm Hg). The pCO₂ profiles for four typical sets of Mode B parameters (Table 10) are presented in Figures 25 through 28. The remaining Mode B inputs are presented in Table 11.

FIGURE 21 CABIN CO₂ GENERATION RATE PROFILE





FIGURE 22 CABIN $p\text{CO}_2$ SIMULATION PROFILE FOR CONTROL MODE A(1)

FIGURE 23 CABIN $p\text{CO}_2$ SIMULATION PROFILE FOR CONTROL MODE A(2)




FIGURE 24 CABIN $p\text{CO}_2$ SIMULATION PROFILE FOR CONTROL MODE A(3)

TABLE 9 INPUT VARIABLES FOR SAMPLE MODE A PROBLEMS

Cabin Atmosphere	
Total Pressure, P ₀ PSA	14.7 Psia
pCO ₂ , PC ₀	0.001, 10 mm Hg
pO ₂ , PO ₀ PSA	3.1 Psia
Temperature, T ₀	70F
Volume, VOLUME	8000 Ft ³
Process Air Outlet	
Total Pressure, P8PSA	14.75 Psia
Process Air Inlet	
Temperature, T ₇	55F
Flow Rate, V ₇	500 Scfm ^(a)
Dew Point Temperature, DW ₇	50F
Anode H₂/CO₂ Outlet	
Total Pressure, P4PSA	20 Psia
System H₂ Inlet	
Temperature, T ₉	72F
Flow Rate, V _{9SL}	10 Scfm ^(a)
Dew Point Temperature, DW ₉	69F
Modules	
Number in Circuit, N	96
Current, I	4.00, 3.66, 7.32 A
DELT1 ^(b)	22F
Cathode Air Flow Rate, V ₁	54, 30.7, 70 Scfm (96 cells)
Penalty Weight Factors	
Power, PWOPEN	0.591 Lb/Watt
Heat Rejection to Ambient, HTPEN	0.128 Lb/Btu/Hr
Water Vapor Rejection to Ambient, H2OPEN	134 Lb/Lb H ₂ O/Hr
Oxygen Consumption, OXOPEN	1536 Lb/Lb O ₂ /Hr
Program Control	
KMODE ^(c)	0
NFLAG ^(d)	1
Number of Days to be Simulated, DAYS	4 Days ^(e)
Integration Time Increment, DT	15 Min ^(f)
Output Table Time Increment, DPRINT	60 Min

(a) Reference conditions for standard flow units: 70F, 14.7 Psia

(b) DELT1 = Module temperature - cathode air inlet dew point temperature

(c) KMODE = 0 - Mode A; 1 - Mode B


(d) NFLAG = 0 - Out-of-tolerance moisture conditions do not stop program
1 - Out-of-tolerance moisture conditions do stop program


(e) DT must be chosen so that the length of each time step in the CO₂ generation rate table is a whole multiple of DT


(f) DPRINT must be a whole multiple of DT

TABLE 10 CONTROL MODE B PARAMETERS

<u>Control Parameter</u>	<u>B(1)</u>	<u>B(2)</u>	<u>B(3)</u>	<u>B(4)</u>
Minimum Current, BK(1), A	2.586	2.586	2.586	2.586
pCO ₂ for Minimum Current, BK(2), mm Hg	2.5	1.0	1.0	2.5
pCO ₂ for Maximum Current, BK(3), mm Hg	2.8	2.8	10.0	10.0
Maximum Current, BK(4), A	6.6	6.6	6.6	6.6
Minimum Cathode Air Flow Rate, BK(5), Scfm	20	20	20	20
pCO ₂ at Minimum Cathode Air Flow Rate, BK(6), mm Hg	2.5	1.0	1.0	2.5
pCO ₂ at Maximum Cathode Air Flow Rate, BK(7), mm Hg	2.8	2.8	10.0	10.0
Maximum Cathode Air Flow Rate, BK(8), Scfm	60	60	60	60

FIGURE 25 CABIN $p\text{CO}_2$ SIMULATION PROFILE FOR CONTROL MODE B(1)

FIGURE 26 CABIN $p\text{CO}_2$ SIMULATION PROFILE FOR CONTROL MODE B(2)

FIGURE 27 CABIN pCO_2 SIMULATION PROFILE FOR CONTROL MODE B(3)




FIGURE 28 CABIN $p\text{CO}_2$ SIMULATION PROFILE FOR CONTROL MODE B(4)

TABLE 11 INPUT VARIABLES FOR SAMPLE MODE B PROBLEMS

Cabin Atmosphere	
Total Pressure, P0PSA	14.7 Psia
pCO ₂ , PC0	0.001, 10 mm Hg
pO ₂ , PO0PSA	3.1 Psia
Temperature, T0	70F
Volume, VOLUME	8000 Ft ³
Process Air Outlet	
Total Pressure, P8PSA	14.75 Psia
Process Air Inlet	
Temperature, T7	55F
Flow Rate, V7	265 Scfm (a)
Dew Point Temperature, DW7	50F
Anode H ₂ /CO ₂ Outlet	
Total Pressure, P4PSA	20 Psia
System H ₂ Inlet	
Temperature, T9	72F
Flow Rate, V9SL	10 Scfm (a)
Dew Point Temperature, DW9	69F
Modules	
Number in Circuit, N	96
Current, I	N/A (b)
DELT1 ^(c)	22F
Cathode Air Flow Rate, V1	N/A
Penalty Weight Factors	
Power, PWOPEN	0.591 Lb/Watt
Heat Rejection to Ambient, HTPEN	0.128 Lb/Btu/Hr
Water Vapor Rejection to Ambient, H2OPEN	134 Lb/Lb H ₂ O/Hr
Oxygen Consumption, OXOPEN	1536 Lb/Lb O ₂ /Hr
Program Control	
KMODE ^(d)	1
NFLAG ^(e)	1
Number of Days to be Simulated, DAYS	4 Days (f)
Integration Time Increment, DT	15 Min (g)
Output Table Time Increment, DPRINT	60 Min

(a) Reference conditions for standard flow units: 70F, 14.7 Psia

(b) N/A = Not Applicable

(c) DELT1 = Module temperature - cathode air inlet dew point temperature

(d) KMODE = 0 - Mode A; 1 - Mode B

(e) NFLAG = 0 - Out-of-tolerance moisture conditions do not stop program
1 - Out-of-tolerance moisture conditions do stop program

(f) DT must be chosen so that the length of each time step in the CO₂ generation rate table is a whole multiple of DT

(g) DPRINT must be a whole multiple of DT

In control Mode A, subsystem equivalent weight and O_2 consumption remain constant. In control Mode B, however, these two parameters vary with time. The steady-state daily equivalent weight and O_2 consumption profiles for the four control Mode B runs are presented in Figures 29 through 36. Subsystem power consumption profiles and any other subsystem performance variable profiles can likewise be predicted, depending upon the specific interests of the program user. In this manner, control Mode A and control Mode B can then be compared on the basis of the important performance parameters for a given application.

CONCLUSIONS

The following conclusions were reached as a direct result of the math model development effort:

1. The CS-6 Base Program developed accurately predicts the performance characteristics of the CS-6 as a subsystem over its typical range in operating conditions.
2. The Cabin pCO_2 Simulation Program developed predicts cabin pCO_2 as a function of a given CO_2 generation profile and spacecraft cabin volume for the CS-6 as the CCS.
3. The Cabin pCO_2 Simulation Program provides a tool for the system designer for use in trade studies to determine subsystem equivalent weight, O_2 consumption, power consumption, and cabin pCO_2 as a function of a CO_2 generation profile for both control Mode A and control Mode B.
4. The CS-6 Base Program and Cabin pCO_2 Simulation Program can be upgraded for use as a hardware design tool. Hardware limitations such as cooling air damper leakage and blower capacity could be eliminated from the program. The result of the upgrading would be a hardware design tool specifically aimed at sizing and designing an EDC CO_2 removal subsystem for general spacecraft application.
5. The experimental work completed provided the necessary data to model the performance of the CS-6 and to verify the model's predictability.




FIGURE 29 STEADY-STATE DAILY EQUIVALENT WEIGHT PROFILE FOR CONTROL MODE B(1)




FIGURE 30 STEADY-STATE DAILY EQUIVALENT WEIGHT PROFILE FOR CONTROL MODE B(2)




FIGURE 31 STEADY-STATE DAILY EQUIVALENT WEIGHT PROFILE FOR CONTROL MODE B(3)







FIGURE 32 STEADY-STATE DAILY EQUIVALENT WEIGHT PROFILE FOR CONTROL MODE B(4)

9L

FIGURE 33 STEADY-STATE DAILY O_2 CONSUMPTION PROFILE FOR CONTROL MODE B(1)

FIGURE 34 STEADY-STATE DAILY O₂ CONSUMPTION PROFILE FOR CONTROL MODE B(2)

FIGURE 35 STEADY-STATE DAILY O₂ CONSUMPTION PROFILE FOR CONTROL MODE B(3)




FIGURE 36 STEADY-STATE DAILY O₂ CONSUMPTION PROFILE FOR CONTROL MODE B(4)

REFERENCES

1. Marshall, R. D., Schubert, F. H. and Carlson, J. N., "Electrochemical Carbon Dioxide Concentrator: Math Model," Final Report, ER-134G-6, NASA CR 114639, Contract NAS2-6478, Life Systems, Inc., Cleveland, Ohio, August, 1973.
2. Kostell, G. D., Schubert, F. H., Shumar, J. W., Hallick, T. M. and Jensen, F. C., "Six-Man, Self-Contained Carbon Dioxide Concentrator Subsystem for Space Station Prototype (SSP) Application," Final Report, ER-170-34, NASA CR 114742, Contract NAS2-6478, Life Systems, Inc., Cleveland, Ohio, May, 1974.
3. "CS-6 Operation and Maintenance Manual," ER-170-36, Life Systems, Inc., Cleveland, Ohio, Contract NAS2-6478, April, 1974.
4. Shubert, F. H. and Quattrone, P. D., "Development of a Six-Man, Self-Contained Carbon Dioxide Collection Subsystem for Spacecraft Application," ASME Publication 74-ENAS-16, presented at the Inter-society Conference on Environmental Systems, Seattle, Washington, July 29-August 1, 1974.
5. Schubert, F. H. and Schneider, J. J., "Six-Man, Self-Contained CO₂ Concentrator Extension: New Technology Tasks," First Quarterly Report, ER-170E-2a, Contract NAS2-6478, Life Systems, Inc., Cleveland, Ohio, December, 1973.
6. Bird, R. Byron, Stewart, Warren E. and Lightfoot, Edwin N., "Transport Phenomena," John Wiley & Sons, Inc., New York, 1960.
7. Welty, James R., Wicks, Charles E. and Wilson, Robert E., "Fundamentals of Momentum, Heat and Mass Transfer," John Wiley & Sons, Inc., New York, 1969.

APPENDIX A CS-6 BASE PROGRAM DOCUMENTATION

<u>TABLE</u>	<u>PAGE</u>
1 Main Program Flow Chart	A-2
2 Water Vapor Pressure Function	A-18
3 Dew Point Temperature Function	A-19
4 Transfer Index Function	A-20
5 Root Function	A-22
6 Module Temperature Subroutine	A-24
7 Heat Balance Function with Variable Module Temperature	A-25
8 Heat Balance Function with Variable Cooling Air Flow Rate	A-27
9 Range Test Subroutine	A-29
10 Base Program Listing	A-30
11 Checks and Messages	A-42
12 Nomenclature and Units	A-44

TABLE 1 MAIN PROGRAM FLOW CHART

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
		START	
	190	CPA = 1.0765	Initialize Constant Btu/Hr/Scfm-F
	190	CPH = 1.0666	Initialize Constant Btu/Hr/Scfm-F
	200	U1 = 51.7	Initialize Constant mm Hg/Psi
	200	U2 = 386.7	Initialize Constant Scfm/Lb-Mol/Hr
	200	U3 = 3.419	Initialize Constant Btu/Hr/Watt
	200	U4 = 28.32	Initialize Constant 1/Ft ³
	210	C782 = 2.25 x 10 ⁻⁵	
	210	C562 = 1.303 x 10 ⁻⁵	Initialize Constants For Pressure Drop Equations
	210	C561 = 1.01 x 10 ⁻²	
	210	C6132 = 8.611 x 10 ⁻⁴	
	220	C5132 = C562 + C6132	
	230	C5131 = C561	
	240	QA = C5132 - C782	
	250	IOUT = 1	Initialize output file device code
	260	PRINT, "FILE INPUT (T OR F)	
	270	READ, QFIN	
	280	INP = 50	

-continued-

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	290	IF (QFIN) INP=2	Open input file if desired
	300	IF (QFIN) OPEN INPUT FILE	
	310	PRINT, "FILE OUTPUT (T OR F)"	
	320	READ, QFOUT	
	330	IF (NOT QFOUT) IOUT = 66	
	360	IF (NOT QFOUT) BRANCH	
	370	IF (NOT QFIN) PRINT, "FILE FOR OUTPUT"	If file output was used, read in the file name. If the file is completed, close it and assign the name to it.
	380-390	READ (INP, 48) FNAME	
	400	IF (FNAME = "WAIT") BRANCH	
	410-430	END, CLOSE AND REWIND FILE	
	450-470	READ: POPSA, PCO, POOPSA, P8PSA, T7, V7, DW7, P4PSA, T9, V9SL, DW9, N, I, DELT1, V1, PWOPEN, HTPEN, H2OPEN, OXOPEN, NFLAG	Read in and write out input variables
	510-750	WRITE INPUT VARIABLES	
	790	IR=0	Initialize out of range input variable counter
	800	CALL T ("POPSA," POPSA, 13.7, 15.7, IR)	Subroutine T checks each input variable against its allowable range. Out of range variables are printed and cause IR to be incremented.
	810-990		

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	1000	CALL T ("NFLAG,", FLAG, 0, 1, IR)	
	1010	IF (IR > 0) BRANCH	If the counter shows that one or more input variables is out-of-range, abort the simulation and read in next set of data.
	1050	$V9MSL = (1.3)(N)(I)(7.058 \times 10^{-3})$	Calc. required H_2 flow
	1060	IF V9MSL < V9SL THEN BRANCH	Check for sufficient H_2 Flow
	1070-1080	WRITE "INSUFFICIENT H_2 ," V9MSL, "IS REQUIRED"	Write error message and required H_2 flow Return for new inputs
	1140	IF V1 ≤ 70 THEN BRANCH	Check that V1 is less than the process air blower capacity
	1150	V1 = 70	Set V1 to maximum blower capacity
	1160-1180	WRITE "AIRFLOW CHANGE TO 70 SCFM"	Print error message
	1220	$V7M1 = V7 - V1$	
	1230	$QB = C5131 + 2(V7M1)^2$	
	1240	$QC = C782 (V7M1)^2$	
	1250	$V5MIN = \frac{-QB + \sqrt{QB^2 + 4(QA)(QC)}}{2(QA)}$	Calculate bypass cooling air flow with cooling blowers off; i.e., calculate minimum cooling air flow rate
	1290	DW1 = DW7	

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	1300	T2 = DW1 + DELT1	Calculate cell temperature
	1310	T2INP = T2	Store input T2
	1320	E = 0.729 - 0.22 lnI + 0.008I + 0.005 (T2-78)	Calculate cell voltage
	1330	HEATLD = (1.25-E)(N)(I)(U3)	Calculate modules' heatload
	1340	T1 = T7	
	1350	T3 = T9	
	1360	V3 = V9SL/U4	
	1370	T5 = T1	
	1380	DHA = V1 (CPA)(T2 - T1)	Calculate heat removed by cathode air flow
	1390	DHH = V3 (CPH)(T2-T3)	Calculate heat removed by H ₂
	1400	DHC = HEATLD-DHA-DHH	Calculate heat removed by cooling air
(4) ⑤	1440	If DHC > 0 THEN BRANCH	Check to see if cooling air is required
	1490	V5 = V5MIN	Set cooling air flow to minimum
	1500	V5A = (N)(V5MIN)/96	Calculate flow thru active cells
	1510	CALL TDRIFT	Calculate T2 for subcooled condition

A-5

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	1520	DROP = T2INP-T2	Calculate temperature, T2, drop
	1530-1560	WRITE "V5MIN," V5MIN "COOLING BLOWERS OFF," "MODULE TEMPERATURE FALLS," DROP, "NEW T2," T2	Print out new conditions
	1630	IF $T2-T5 \geq \frac{(0.376)DHC}{N}$ THEN BRANCH	Check if there is sufficient ΔT to conduct heat up fins
	1680	V5 = 440	Set V5 to maximum blower capacity
	1690	V5A = V5(N)/96	Calculate flow thru active cells
	1700	Call TDRIFT	Calculate T2
	1710	RISE = T2-T2INP	Call rise in module temperature
	1720-1740	WRITE "COOLING BLOWERS ON FULL," "MODULE TEMPERATURE RISES," RISE, "NEW T2," T2	Print out new conditions
	1800	VA = 1.01 x DHC/CPA (N)(T2-T5)	Calculate minimum and maximum cooling air flow to set range for iterative subroutine "ROOT"
	1810	VB = 2(VA)	
	1820	V5A = (N) · ROOT (VA, VB, ERT, 0, 0.005, 0.001, 20)	Calculate cooling air flow past active cell
	1830	V5 = 96(V5A)/N	Calculate total cooling air flow
	1880	If $V5 < V5MIN$ THEN BRANCH	Check for subcooling

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
(8) ↗	1890	If V5 > 440 THEN BRANCH	Check for heatup
↓	1900-1920	WRITE "COOLING BLOWERS IN RANGE"	Print clarifying statement
(6) ↗	1970	V10 = V7-V1-V5	Calculate plenum bypass flow
↓	2020	IF V10 ≥ 0.005 (V8) THEN BRANCH	Check for sufficient plenum bypass
↓	2030-2060	WRITE "INSUFFICIENT AIR FLOW, RECIRCULATION OF AIR FROM OUTLET TO INLET"	Print error message
A ↴	2120	COR34 = $\frac{(14.1)}{P4PSA}^{0.8}$	Calculate module H ₂ cavity pressure drop
↓	2130	P4 = P4PSA (V1)	
↓	2140	V3SL = V9SL	
↓	2150	DP34 = (0.3822) (COR34) (V3SL)	
↓	2150	IF V3SL ≤ 22 THEN BRANCH	
↓	2150	DP 34 = COR34 (8.3183 ₁₊₇₅) ^{0.4187} (V3SL-21.5801) ^{1.75}	
↓	2170	P3 = P4 + DP34	Calculate module H ₂ inlet pressure
↓	2180	P3PSA = P3/U1	
↓	2190	COR93 = $\frac{(14.1)}{P3PSA}^{0.8}$	
↓	2200	DP93 = (COR93) (10.64) (V3SL)	Calculate H ₂ distribution block pressure drop

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	2210	IF V3SL < 6.2 THEN BRANCH	
	2210	DP93 = COR93 [35.64 V3SL - 195.25 + e^(7.75 - 0.6537V3SL)]	
	2220	P9 = P3 + DP93	Calculate H ₂ inlet pressure
	2230	P9PSA = P9/U1	
	2240	DP78 = 2.25 x 10 ⁻⁵ (V10) ²	Calculate process air inlet pressure using plenum pressure drop correlation
	2250	P8 = P8PSA(U1)	
	2260	P7 = P8 + DP78	
	2270	P7PSA = P7/U1	
	2280	DP12 = 0.001903(V1) ² + 0.04877(V1)	Calculate cathode air pressure drop
	2290	P1 = P7	
	2300	P2 = P1-DP12	Calculate cathode air out pressure
	2310	PC1 = PCO $\frac{P7PSA}{POPSSA}$	Calculate cathode inlet pCO ₂
	2320	CURDEN = I/0.244	Calculate current density
	2330	DELT1E = T2-DW1	Calculate actual humidity ΔT
	2340	TI = TICOR (PC1, V1/96, CURDEN, DELTIE)	Calculate TI
	2350	OCON = 6.5803 x 10 ⁻⁴ (N)(I)	Calculate O ₂ consumed

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	2360	$CTRANS = TI(OCON)$	Calculate CO_2 transferred
	2370	$HCON = OCON \frac{2.016}{16}$	Calculate H_2 consumed
	2380	$WPROD = HCON + OCON$	Calculate water produced
	2390	$VC4 = CTRANS \frac{V2}{44.01 \times 60}$	
	2400	$PW9 = PHTO(DW9)$	
	2410	$PW3 = P3 \frac{PW9}{P9}$	Calculate anode gas stream parameters
	2420	$VH3 = V3(1 - \frac{PW3}{P3})$	
	2430	$VH4 = VH3 - HCON \frac{U2}{2.016 \times 60}$	
	2450	$PW4 = PHTO(T2-6)$	
	2460	$VW4 = \frac{PW4}{P4-PW4} (VC4 + VH4)$	
	2470	$DW1 = DW7$	
	2480	$PW1 = PHTO(DW1)$	Calculate cathode air water balance parameters
	2490	$VW1 = V1 \frac{PW1}{P1}$	
	2500	$VW3 = V3 - VH3$	
	2510	$VWPROD = WPROD \frac{V2}{18.01 \times 60}$	
	2520	$VW2 = VW1 + VW3 - VW4$	
	2530	$POO = POOPSA/U1$	
	2540	$PO7 = POO(P7/PO)$	

A-9

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	2550	P01 = P07	Calculate cathode air inlet stream parameters
	2560	PN1 = P1-P01-PW1-PC1	
	2570	VN1 = V1 (PN1/P1)	
	2580	VO1 = V1 (P01/P1)	
	2590	VC1 = V1 (PC1/P1)	
	2600	VN2 = VN1	
	2610	VO2 = VO1 - OCON (U2/32 x 60)	
	2620	VC2 = VC1 - VC4	Calculate cathode air outlet stream parameters
	2630	V2 = VO2 + VN2 + VW2 + VC2	
	2640	PW2 = $\frac{VW2}{V2} P2$	
	2650	DW2 = DEWT (PW2)	
	2710	IF T1-DW1 = 11.25 ± 1.75 AND T2-DW2 = 11.25 ± 1.75 THEN BRANCH	
	2720	IF T1-DW1 ≥ 4 THEN BRANCH	
	2850-2860	WRITE "INLET AIR HUMIDITY OUT-OF-RANGE"	
	2730	IF T1-DW1 ≤ 14 THEN BRANCH	

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	2740	IF T2-DW2 ≥ 7 THEN BRANCH	Perform moisture balance checks
	2880-2890	WRITE "OUTLET AIR HUMIDITY OUT-OF-RANGE"	
	2750	IF T2-DW2 ≤ 19 THEN BRANCH	
	2760	DPTDAV = $\frac{1}{2}$ (T1-DW1+T2-DW2)	
	2770	IF DPTDAV = 11±1.5 AND EITHER T2-DW2 ≥ 13 OR DPTDAV ≥ 0 THEN BRANCH	
	2780-2790	WRITE "AVE DEW PT DEPRESSION OUT-OF-RANGE"	
	2800-2820	WRITE "ELECTROLYTE MOISTURE BALANCE NOT MAINTAINED"	
	2830	IF NFLAG = 1 THEN BRANCH	Check NFLAG for program abort
	2950	DELT1P = 22-T1 + DW2	Calculate preferred ΔT
	2960	T2P = DP1 + DELT1P	
	2970	PW7 = PW1	
	2980	PN7 = PN1	
	2990	PC7 = PC1	Complete definition of process air inlet stream
	3000	VC7 = $\frac{PC7}{P7}$ (V7)	
	3010	VW7 = $\frac{PW7}{P7}$ (V7)	

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	3020	$P07 = P01$	
	3030	$V07 = \frac{P07}{P7} (V7)$	
	3040	$VN7 = \frac{PN7}{P7} (V7)$	
	3050	$RH7 = 100 \left(\frac{PW7}{PHTO(T7)} \right)$	
	3060	$FC1 = VC1 \left(\frac{44.01 \times 60}{U2} \right)$	
	3070	$FW1 = VW1 \left(\frac{18.01 \times 60}{U2} \right)$	
	3080	$RH1 = RH7$	Complete cathode air inlet stream definition
	3090	$PH3 = P3 - PW3$	
	3100	$FH3 = VH3 \left(\frac{2.016 \times 60}{U2} \right)$	Complete definition of H_2 inlet
	3110	$EMOD = 16(E)$	
	3120	$POWER = (N)(I)(E)$	Calculate remaining module parameters
	3130	$TE = TI/0.0275$	
	3140	$PC2 = VC2 \left(\frac{P2}{V2} \right)$	
	3150	$FC2 = FC1 - CTRANS$	
	3160	$FW2 = VW2 \left(\frac{18.01 \times 60}{U2} \right)$	
	3170	$RH2 = 100 \left(\frac{PW2}{PHTO(T2)} \right)$	Complete definition of cathode air outlet
	3180	$T4 = T2$	

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	3190	$V9 = V3$	
	3200	$DW4 = 0.77 \left(\frac{DW1 + DW2}{2} \right) + 0.23T2$	Refined H_2 dew point correlation
	3210	$PW4 = PHTO(DW4)$	
	3220	$VW4 = \frac{PW4}{P4-PW4} (VH4 + VC4)$	Complete definition of anode gas outlet
	3230	$V4 = VH4 + VC4 + VW4$	
	3240	$V4SL = V4(U4)$	
	3250	$VC4SL = VC4(U4)$	
	3260	$VH4SL = VH4(U4)$	
	3270	$FC4 = CTRANS$	Complete definition of anode gas outlet
	3280	$FH4 = VH4 \left(\frac{2.016 \times 60}{U2} \right)$	
	3290	$FW4 = VW4 \left(\frac{18.01 \times 60}{U2} \right)$	
	3300	$F4 = FC4 + FH4 + FW4$	
	3310	$CHWRTO = FC4/FH4$	
	3320	$HCVRTO = VHR/VC4$	
	3330	$P5 = P7$	
	3340	$DP56 = (V5)^2 C562 + V5(C561)$	Calculate cooling air pressure drop
	3350	$P6 = P5-DP56$	Calculate cooling air outlet pressure
	3360	$T6 = \frac{(V5A)T6A + (V5-V5A)T5}{V5}$	Calculate cooling air out temperature

A-13



Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	3370	IF VI \leq 62 THEN PWRCTB = 2.8V + 153.8	
	3380	IF 62 < VI \leq 65 THEN PWRCTB = 40VI - 2150	Calculate cathode air blower power
	3390	IF 65 < VI \leq 70 THEN PWRCTB = -34V \pm + 2660	
	3400	T11 = T2 + $\frac{\text{PWRCTB(U3)}}{VI \cdot CPA}$	
	3410	V11 = V2	Define stream after cathode blower
	3420	P11 = P8	
	3430-3450	IF V5-V5MIN < 0.001(V5MIN) THEN PWRCLB = 0, DP1213=C12132(V5) ² AND BRANCH	Check if cooling blower is off
	3460	DP1213 = C12132 (V5MIN) ²	
	3470	TR = $\left(\frac{DP78}{1.869} + 0.05 \right) / 1.3$	
	3480	TR = TR $\left(0.128 + 0.102 \left(\frac{DP78}{1.869} \right) \right)$	Calculate cooling blower power
	3490	PWH = 410 - 0.00396 (V5-368) ²	
	3500	PWL = 410 - 0.00178 (V5 - 306) ²	
	3510	PWRCLB = TR (PWH) + (1-TR)(PWL)	
	3530	P12 = P8 + DP1213	
	3540	+12 = T6 + $\frac{\text{PWRCTB(U3)}}{V5(CPA)}$	
	3550	T13 = T12	Define cooling blower exit stream

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	3560	$V12 = V5$	
	3570	$P13 = P8$	
	3580	$V13 = V5$	
	3590	$V8 = V10 + V2 + V5$	
	3600	$VW8 = VW7 + VW2 - VW1$	
	3610	$VC8 = VC7 - VC4$	
	3620	$PC8 = \left(\frac{VC8}{V8} \right) P8$	Calculate plenum exit conditions
A-15	3630	$VN8 = VN7$	
	3640	$PN8 = \left(\frac{VN8}{V8} \right) P8$	
	3650	$VO8 = VO7 - \frac{1}{2}(VH3 - VH4)$	
	3660	$PW8 = \left(\frac{VW8}{V8} \right) P8$	
	3670	$DW8 = DEWT(PW8)$	
	3680	$T8 = \frac{T11(V11) + T13(V13)}{V8} +$ $\frac{T7(V10) + POWER \frac{U3}{CPA}}{V8}$	
	3690	$RH8 = \frac{100 \times PW8}{PHTO(T8)}$	
	3700	$AV7 = \frac{V7(T7 + 460)}{P7} \left(\frac{760}{530} \right)$	

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	3710	$AV1 = V1 (AV7/V7)$	
	3720	$AV2 = \frac{V2(T2 + 460)}{P2} \times 1.434$	
	3730	$AV11 = \frac{V11(T11 + 460)}{P11} (1.434)$	
	3740	$AV9 = \frac{V9(T9 + 460)}{P9} (1.434)$	
	3750	$AV3 = \frac{V3(T3 + 460)}{P3} (1.434)$	
	3760	$AV4 = \frac{V4(T4 + 460)}{P4} (1.434)$	
	3770	$AV5 = V5 AV7/V7$	Calculate actual stream flow rates
	3780	$AV6 = \frac{V6(T6 + 460)}{P6} (1.434)$	
	3790	$V6A = V5A$	
	3800	$AV6A = \frac{V6A(T6A + 460)}{P6} (1.434)$	
	3810	$AV12 = \frac{V12(T12 + 460)}{P12} (1.434)$	
	3820	$AV13 = \frac{V13(T13 + 460)}{P13} (1.434)$	
	3830	$AV10EX = \frac{V10(T7 + 460)}{P8} (1.434)$	
	3840	$AV8 = \frac{V8(T8 + 460)}{P8} (1.434)$	
	3880	$HRDWGT = 817.9$	
	3890	$PWRPC = 136$	Calculate equivalent weight penalty
	3900	$PWREC = 45$	
	3910	$PWRDAU = 100$	

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	3920	PWRTOT = PWRPC + PWREC + PWRCLB + PWRCTB + PWRDAU	
	3930	HTTOT = HEATLD + U3(PWRTOT + POWER)	
	3940	PWRWGT = PWPEN(PWRTOT)	Calculate equivalent weight penalty
	3950	HTWGT = HTPEN(HTTOT)	
	3960	H2OWGT = H2OPEN(WPROD)	
	3970	OXWGT = OXPEN(OCON)	
	3980	EQWGT = PWRWGT + HTWGT + H ₂ OWGT + OXWGT + HRDWGT	
	3990-4710	WRITE OUT ALL OUTPUTS END OF PROGRAM	

TABLE 2 WATER VAPOR PRESSURE FUNCTION

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	4750	FUNCTION PHTO(TF)	The input parameter is the Fahrenheit dew point temperature. The output parameter is pH ₂ O, in millimeters of mercury.
	4760-4770		Initialize constants A-G.
	4780	TC=(TF-32) 1.8	Calculate Centigrade dew point temperature.
A-18	4790	X = 374.11 - TC	Calculate the temperature span from the dew point to the critical temperature.
	4800	PHTO=10 ^(EE-X/TC+F) x $\frac{A+BX+CX^3}{1+DX}$	Calculate water vapor pressure
	4810	RETURN	

TABLE 3 DEW POINT TEMPERATURE FUNCTION

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	4840	FUNCTION DEWT(P)	The input parameter P is the water vapor pressure in millimeters of mercury. The output parameter DEWT is the Fahrenheit dew point temperature
	4850	EXTERNAL ROOT, PHTO	Functions ROOT and PHTO are used by function DEWT
A-19	4860	X=ALOG(P)	Calculate two trial values for the dew point temperature
	4870	TA=-2.4 + 20.25X + 1.522X ²	
	4880	TB=TA + 0.1	
	4890	DEWT=ROOT(TA,TB,PHTO,P,0.005,0.005, 5)	Function ROOT will call function PHTO starting with dew points equal to TA and TB until the water vapor pressure is equal to P with temperature and vapor pressure tolerances of point .005 but not exceeding five trials.
	7700	RETURN	

TABLE 4 TRANSFER INDEX FUNCTION

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	4930	FUNCTION TICOR(PC,AF,CD,DEL)	Input parameters are CO ₂ partial pressure in millimeters of mercury, cathode air flow in Cfm/cell, current density in Amp/Ft ² , and module temperature - inlet cathode air dew point temperature. The output parameter is TICOR in Lb CO ₂ /Lb O ₂ .
	4940-5010		Initialize the correlation parameters in array S.
	5020	PA=PC $(\frac{AF}{.44})^{(1+.84P)^{-84P}}$	PA is the effective inlet pCO ₂ corrected for nonbaseline cathode air flow.
	5030	J= $\frac{CD}{5} - 1$	Calculate the J index which corresponds to current density.
	5040	IF(J < 1)J=1	For current densities less than 10 ASF, extrapolate from 15 and 10 ASF.
	5050	TI1= $\sum_{i=1}^5 S_{ij} PA^i$	Calculate TI at the current density just below the actual current density.
	5060	If (J < 7) BRANCH	Current density should not exceed 40 ASF.
	5070	TICOR = TI1	
	5090	J = J + 1	Calculate TI at the current density just above the actual current density.
	5100	TI2 = $\sum_{i=1}^5 S_{ij} PA^i$	
	5110	AII=J	Interpolate between the two current densities.

-continued-

Table 4 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5120	TERP = $\frac{CD}{5}$ - AII	
	5130	TICOR=TI2xTERP+TI1(1-TERP)	
	5140	TICOR=TICOR(1+.03536(DEL-18.33)) Correct TI for moisture conditions.	
	5050	RETURN	

TABLE 5 ROOT FUNCTION

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5180	FUNCTION ROOT(X1,X2,YFCN,W,XTOL, YTOL,K)	Input parameters are the first and second trial root values, the function to be called which returns the function of X, the value of the function at the desired root, X tolerance, Y tolerance, and maximum trials. The output value, ROOT, is the value of X when the function equals W.
	5190-5200		Initialize common and external statements.
	5210	XA=X1	Isolate X1 and X2.
A-22	5220	XB=X2	
	5230	FA=YFCN(XA) - W	Find the error values at XA and XB.
	5240	FB=YFCN(XB)-W	
	5250	BEGIN LOOP	
	5260	XN= $\frac{FA \cdot XB - FB \cdot XA}{FA - FB}$	Extrapolate from the previous two trial values.
	5270	FN=YFCN(XN)-W	Calculate the error at the next X value.
②	5280-5290	IF(FN < YTOL and XN-XB < XTOL) BRANCH	BRANCH when the X and Y values are within tolerance.
	5300-5320	IF(Kth TIME THRU LOOP) DUMP VARIABLES & PRINT MESSAGE "NONCONVERGENCE IN LOOP"	If the root has not been found within K trials, print a message.
	5330	XA=XB	Drop the oldest trial value and add the new trial value.

-continued-

Table 5 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5340	XB=XN	
	5350	FA=FB	
	5360	FB=FN	
	5370	IF(<Kth TIME THRU LOOP) BRANCH	
	5380	ROOT = XN	The root of the function returned is the latest trial value.
	5390	RETURN	

TABLE 6 MODULE TEMPERATURE SUBROUTINE

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5420	SUBROUTINE TDRIFT	Subroutine TDRIFT calculates the module temperature when the cooling air flow rate is specified. All inputs are through common storage. All outputs except P2 are also through common storage.
	5430-5460		Initialize type, common, and external statements.
	5470	ENTHPR=VI·CPA·T1+V3·CPH·T3	Calculate enthalpy entering the modules in the cathode air and inlet hydrogen streams.
A-24	5480	T2HIGH= $\frac{\text{ENTHPR} + .99 \cdot \text{HEATLD}}{\text{V1} \cdot \text{CPA} + \text{V3} \cdot \text{CPH}}$	Calculate maximum possible module temperature. This is the temperature the module would rise to with no cooling air.
	5490	T2LOW= $\frac{\text{ENTHPR} + \text{V5A} \cdot \text{CPA} \cdot \text{T5} + \text{HEATLD}}{\text{V1} \cdot \text{CPA} + \text{V3} \cdot \text{CPA} + \text{V5A} \cdot \text{CPA}}$	Calculate the minimum module temperature which would occur with no heat transfer resistance.
	5500	T2=T2HIGH	Call subroutine ERT to determine values of the heat transfer coefficient and the cooling fin efficiency, neither of which depends upon module temperature but only upon cooling air flow rate which is constant when subroutine TDRIFT is called.
	5510	DUMMY=ERT(V5 A/N)	
	5520	T2=ROOT(T2HIGH, T2LOW, ERT1, 0, 0.005, 0.005, 0.20)	Start with trial values T2HIGH and T2LOW and use function ERT1 to find the module temperature which yields a heat balance for the specified cooling air flow rate.
	5530	RETURN	

TABLE 7. HEAT BALANCE FUNCTION WITH VARIABLE MODULE TEMPERATURE

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
(U)	5560	FUNCTION ERT1(T)	The input parameter is the module temperature. The output parameter, ERT1, is the difference between the available module cooling air temperature drop and the required module cooling air temperature drop.
(H)	5570-5590		Initialize type, common statements.
(L)	5600	$E = 0.729 - 0.221nI + 0.0081 + 0.005(T-78)$	Calculate module voltage and heat load at the given temperature.
(P)	5610	HEATLD=N·I·(1.25-E)·3.419	
(A)	5620	DHA=V1(CPA)(T-T1)	
(C)	5630	DHH=V3(CPH)(T-T3)	Calculate the enthalphy change for the cathode air process hydrogen and cooling air flow, respectively, at the given module temperature.
(D)	5640	DHC=HEATLD-DHA-DHH	
(E)	5650	$T6A=T5 + \frac{DHC}{V5A(CPA)}$	Calculate the outlet cooling air temperature from the inlet cooling air temperature and the enthalpy increase.
(F)	5660	$DTREQ=DHC(0.376 + 3.876\frac{HC \cdot ETA}{N})$	The required module cooling air temperature difference depends upon the cooling air enthalpy change x the resistance in the fin roots + the gas film resistance.
(1)	5670	IF(T6A < T)BRANCH	If the cooling air temperature at the exit is less than the module temperature, then the log mean temperature difference can be calculated.

-continued

Table 7 - continued




<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5680	ERT1 = -DTREQ	If it is not, then assume that the available temperature difference is zero and the error is equal to the required temperature difference.
	5690	RETURN	
	5700	DTAVA = $\frac{T_6A - T_5}{\ln \frac{T_5}{T_6A}}$	The available temperature drop is the log mean of the module cooling air temperature difference at the inlet and the outlet of the cooling air passages.
	5710	ERT1 = DTAVA-DTREQ	
	5720	RETURN	

TABLE 8 HEAT BALANCE FUNCTION WITH VARIABLE COOLING AIR FLOW RATE

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5750	FUNCTION ERT(V)	The input parameter is the cooling air flow rate, Cfm/cell. The output parameter ERT is the difference between the available and required module-cooling air temperature differences. Inputs taken from common storage include the inlet cooling air and cathode air temperature, the cooling air heat load, the cooling air specific heat, the number of active cells, and the module temperature. Outputs through common storage include the heat transfer coefficient, the fin efficiency, the outlet cooling air temperature, the available temperature difference, and the required temperature difference.
	5760-5780		
	5790	IF ($V \leq 1$) HC=1.97 $V^{0.3333}$	Calculate the heat transfer coefficient.
	5800	IF ($1 < V < 2.9883$) HC=1.21 + 0.34 V^2 + 0.42 V	
	5810	IF ($2.9883 \leq V \leq 4$) HC=2 V	
	5820	IF ($4 < V$) HC=2.639016 V^8	
	5830	ETA=1	Calculate the fin efficiency.
	5840	IF ($0.32194 < V \leq 24.72$) ETA= 1.0644 - 0.1135 $V^{0.5}$	
	5850	IF ($24.72 \leq V$) ETA=2.486 $V^{-0.5}$	
	5860	T6A=T5 + $\frac{DHC}{V(CPA)N}$	

A-27

-continued-

Table 8 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5870	$DTREQ = \frac{DHC}{N} (0.376 + \frac{3.876}{HC(ETA)})$	Calculate the required temperature difference from the cooling air heat load, resistance in the fins, and resistance in the stagnant air film.
	5880	IF ($T_{6A} < T_2$) BRANCH	Branch and calculate the log mean temperature difference only if the outlet cooling air temperature is less than the module temperature
	5890	$ERT = -DTREQ$	There is no available temperature difference. The error ERT is minus the required temperature difference.
	5900	RETURN	
	5910	$DTAVA = \frac{T_{6A}-T_5}{\ln \frac{T_2-T_5}{T_2-T_{6A}}}$	Log mean module cooling air temperature difference.
	5920	$ERT = DTAVA - DTREQ$	
	5930	RETURN	

TABLE 9 RANGE TEST SUBROUTINE

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5960	SUBROUTINE T(VARNAM, VAR, BOT, TOP, I)	Subroutine input parameters are the variable, value, the lower and upper limits, and the out-of-range counter. The subroutine simply prints a message containing the first four parameters when the variable is out-of-range.
	5970	COMMON IOUT	The message is printed on output device IOUT.
	5980	IF (BOT <= VAR <= TOP) BRANCH	The subroutine ends immediately if the variable is in range.
	5980	RETURN	
	5990	WRITE, VARNAM, VAR, BOT, TOP	
	6000	I=I+1	
	6010	RETURN	

TABLE 10 BASE PROGRAM LISTING

BASE

```

100C
110C      *** CS-6 MATH MODEL BASE PROGRAM ***
120C
130$TTY,84
140$NDM
150 REALN,I
160 COMMON IOUT,CPA,CPH,DHC,DHA,DHH,HEATLD,DTREQ,DTAVA,N,I,E,
170&HC,ETA,V1,V3,V5A,T6A,T5,T3,T1,T2
180 EXTERNAL ERT,ERT1,PHTO
190 DATA CPA,CPH/1.0765,1.0666/
200&,U1,U2,U3,U4/51.7007,386.7,3.419,28.32/
210&,C782,C562,C561,C12132/2.25E-5,1.303E-5,.0101,8.6118E-4/
220 C5132=C562+C12132
230 C5131=C561
240 OA=C5132-C782
250 IOUT=1
260 PRINT,"FILE INPUT (T OR F)",:*
270 READ,?FIN
280 INP=50
290 IF( ?FIN)INP=2
300 IF( ?FIN)CALL OPENF(2,"MATHIN")
310 PRINT,"FILE OUTPUT (T OR F)",:*
320 READ,?FOUT
330 IF(.NOT.?FOUT)IOUT=66
340 GOT06
350 1 CONTINUE
360 IF(.NOT.?FOUT)GOT06
370 IF(.NOT.?FIN)PRINT,"FILE FOR OUTPUT",:*
380 READ(INP,48)FNAME
390 48 FORMAT(A6)
400 IF(FNAME.EQ."WAIT")GOT06
410 END FILE 1
420 CALL CLOSEF(1,FNAME,?)
430 REWIND 1
440 6 CONTINUE
450 IF(.NOT.?FIN)PRINT,"INPUT DATA",:*
460 READ(INP,)POPSA,PC0,POOPSA,P8PSA,T7,V7,DW7,P4PSA,T9,V9SL,D#9,
470&N,I,DELT1,V1,PWPEN,HTPEN,H2OPEN,QXOPEN,NFLAG
480C
490C      INPUT DATA PLAYBACK:
500C
510 WRITE(IOUT;4)
520 WRITE(IOUT;230)
530 4 FORMAT(////)
540 230FORMAT(" *****INPUT DATA*****")
550 WRITE(IOUT;1017)
560 1017FORMAT(" CABIN ATMOSPHERE:")
570 WRITE(IOUT;944)"POPSA",POPSA,"PC0",PC0,"POOPSA",POOPSA
580 WRITE(IOUT;1032)
590 1032FORMAT(" PROCESS AIR OUTLET/INLET:")

```

REPRODUCIBILITY OF THE
ORIGINAL IS POOR

Table 10 - continued

```

600 WRITE(IOUT;944)"P8PSA",P8PSA,"T7 ",T7,"V7 ",V7,"DW7",DW7
610 WRITE(IOUT;1031)
620 1031FORMAT(" H2 OUTLET/INLET:")
630 WRITE(IOUT;944)"P4PSA",P4PSA,"T9 ",T9,"V9SL",V9SL,"DW9",DW9
640 WRITE(IOUT;1020)
650 1020FORMAT(" MODULES:")
660 WRITE(IOUT;944)"N ",N,"I ",I,"DELT1",DELT1,"V1 ",V1
670 WRITE(IOUT;1021)
680 1021FORMAT(" PENALTY WEIGHT FACTORS:")
690 WRITE(IOUT;944)"PWPN",PWPN,"HTPN",HTPN,"H2OPEN",H2OPEN,
700&"OXPN",OXPN
710 WRITE(IOUT;1022)
720 1022FORMAT(" PROGRAM CONTROL:")
730 WRITE(IOUT;944)"NFLAG",NFLAG
740 WRITE(IOUT;220)
750 220 FORMAT(" *****RESULTS*****")
760C
770C   CHECK INPUTS:
780C
790 IR=0
800 CALLT("POPSA ",POPSA,13.7,15.7,IR)
810 CALLT("PCO ",PCO,.5,10.,IR)
820 CALLT("POOPSA",POOPSA,2..4.,IR)
830 CALLT("P8PSA ",P8PSA,13.7,15.7,IR)
840 CALLT("T7 ",T7,44.,80.,IR)
850 CALLT("V7 ",V7,0.,600.,IR)
860 CALLT("DW7 ",DW7,41.,70.,IR)
870 CALLT("P4PSA ",P4PSA,14.8,21.2,IR)
880 CALLT("T9 ",T9,65.,75.,IR)
890 CALLT("V9SL ",V9SL,0.,18.,IR)
900 CALLT("DW9 ",DW9,10.,75.,IR)
910 CALLT("N ",N,90.,96.,IR)
920 CALLT("I ",I,2.44,9.76,IR)
930 CALLT("DELT1 ",DELT1,10.,25.,IR)
940 CALLT("V1 ",V1,19.2,76.8,IR)
950 CALLT("PWPN ",PWPN,0.,2.,IR)
960 CALLT("HTPN ",HTPN,0.,2.,IR)
970 CALLT("H2OPEN",H2OPEN,0.,500.,IR)
980 CALLT("OXPN ",OXPN,0.,3000.,IR)
990 FLAG=NFLAG
1000 CALLT("NFLAG ",FLAG,0.,1.,IR)
1010 IF(IR.GT.Q)GOTO1
1020C
1030C   CHECK FOR SUFFICIENT H2:
1040C
1050 V9MSL=1.3*N*I*7.508E-3
1060 IF(V9SL.GE.V9MSL)GOTO1213
1070 WRITE(IOUT;213)V9MSL
1080 213 FORMAT(" INSUFFICIENT H2.",G10.4," SLPM IS REQUIRED")
1090 GOTO1

```

REPRODUCIBILITY OF THE
ORIGINAL PAGE IS POOR

Table 10 - continued

```
1100 1213 CONTINUE
1110C
1120C    CHECK CATHODE AIR CAPACITY:
1130C
1140 IF(V1.LE.70)GOT09001
1150 V1=70.
1160 WRITE(IOUT;9000)
1170 9000FORMAT(" V1 HAS BEEN CHANGED TO 70 SCFM, BLOWER CAPACITY.")
1180 9001 CONTINUE
1190C
1200C    CALC. COOLING AIR FLOW WITH COOLING BLOWERS OFF:
1210C
1220 V7M1=V7-V1
1230 QB=C5131+2.*C782*V7M1
1240 QC=C782*V7M1**2
1250 V5MIN=(-QB+SQRT(QB*QB+4.*QA*QC))/(2.*QA)
1260C
1270C    CALC. COOLING AIR HEAT LOAD, ETC. FOR INPUT MODULE TEMP:
1280C
1290 DW1=DW7
1300 T2=DW1+DELT1
1310 T2INP=T2
1320 E=.729-.22* ALOG(I)+.008*I+.005*(T2-78.)
1330 HEATLD=N*I*(1.25-E)*U3
1340 T1=T7
1350 T3=T9
1360 V3=V9SL/U4
1370 T5=T1
1380 DHA=V1*CPA*(T2-T1)
1390 DHH=V3*CPH*(T2-T3)
1400 DHC=HEATLD-DHA-DHH
1410C
1420C    CHECK NEED FOR COOLING:
1430C
1440 IF(DHC.GT.0)GOT0898
1450C
1460C    CALC. NEW MODULE TEMP IF COOLING BLOWERS ARE OFF:
1470C
1480 888 CONTINUE
1490 V5=V5MIN
1500 V5A=N*V5MIN/96.
1510 CALL TDRIFT
1520 DROP=T2INP-T2
1530 WRITE(IOUT;944)*V5MIN*,V5MIN
1540 WRITE(IOUT;469)DROP,T2INP,T2
1550 469 FORMAT(" COOLING BLOWERS ARE OFF."// " MODULE TEMPERATURE FALLS",
1560&F6.2,"F BELOW THE DESIRED",F6.2,"F TO",F6.2,"F.")
1570 GOT0766
1580C
1590C    CHECK THAT MODULE TEMP IS HIGH ENOUGH TO TRANSFER HEAT
```

Table 10 - continued

1600C AT LEAST TO COOLING FIN ROOTS:
 1610C
 1620 898 CONTINUE
 1630 IF(T2-T5.GE..376*DHC/N)GOT0765
 1640C
 1650C CALC. NEW MODULE TEMP IF COOLING BLOWERS ARE ON FULL:
 1660C
 1670 896 CONTINUE
 1680 V5=440.
 1690 VSA=V5*N/96.
 1700 CALL TDRIFF
 1710 RISE=T2-T2INP
 1720 WRITE(IOUT;479)RISE,T2INP,T2
 1730 479 FORMAT(" COOLING BLOWERS ARE ON FULL."// " MODULE TEMPERATURE RISES",
 1740F6.2,"F ABOVE THE DESIRED",F6.2,"F TO",F6.2,"F.")
 1750 GOT0766
 1760C
 1770C CALC. COOLING AIR FLOW FOR INPUT MODULE TEMPERATURE:
 1780C
 1790 766 CONTINUE
 1800 VA=1.01*DHC/(CPA*N*(T2-T5))
 1810 VB=2.*VA
 1820 VSA=N*ROOT(VA,VB,ERT,0.,.005,.001,20)
 1830 V5=96.*VSA/N
 1840 V5INP=V5
 1850C
 1860C ARE COOLING BLOWERS OUT OF RANGE:
 1870C
 1880 IF(V5.LT.V5MIN)GOT0888
 1890 IF(V5.GT.440.)GOT0886
 1900 WRITE(IOUT;3950)
 1910 3950 FORMAT(" DESIRED MODULE TEMPERATURE IS MAINTAINED WITH",
 1920" COOLING BLOWERS AT PARTIAL CAPACITY.")
 1930C
 1940C MODULE HEAT BALANCE IS MAINTAINED WITH COOLING BLOWERS IN RANGE:
 1950C
 1960 766 CONTINUE
 1970 V10=V7-V1-V5
 1980 WRITE(IOUT;944)"V5INP",V5INP
 1990C
 2000C CHECK PLENUM BYPASS FLOW:
 2010C
 2020 IF(V10.GE..05*V7)GOT0244
 2030 WRITE(IOUT;242)
 2040 WRITE(IOUT;944)"V10",V10
 2050 242FORMAT(" INSUFFICIENT INLET PROCESS AIR TO ",
 2060"PREVENT BACKMIXING THROUGH PLENUM BYPASS.")
 2070 GOT01
 2080C
 2090C CALC. STREAM PARAMETERS REQUIRED FOR MOISTURE BALANCE CHECKS:

Table 10 - continued

```

2100C
2110 244 CONTINUE
2120 COR34=(14.1/P4PSA)**.8
2130 P4=P4PSA*U1
2140 V3SL=V9SL
2150 DP34=.3822*COR34*V3SL
2160 IF(V3SL.GT.22.1)DP34=COR34*(8.3183+.4187*(V3SL-21.5801)**1.75)
2170 P3=P4+DP34
2180 P3PSA=P3/U1
2190 COR93=(14.1/P3PSA)**.8
2200 DP93=COR93*10.64*V3SL
2210 IF(V3SL.GT.6.2)DP93=COR93*(35.14*V3SL-195.25+EXP(.7.75-.6537*V3SL))
2220 P9=P3+DP93
2230 P9PSA=P9/U1
2240 DP78=C782*V10*V10
2250 P8=P8PSA*U1
2260 P7=P8+DP78
2270 P7PSA=P7/U1
2280 DP12=V1*(.001903*V1+.04877)
2290 P1=P7
2300 P2=P1-DP12
2310 PC1=PC0*P7PSA/POPSA
2320 CURDEN=I/.244
2330 DELT1E=T2-DW1
2340 TI=TICOR(PC1,V1/96.,CURDEN,DELT1E)
2350 OCON=6.5803E-4*N*I
2360 CTRANS=TI*OCON
2370 HCON=OCON*2.016/16.
2380 WPROD=OCON+HCON
2390 VC4=CTRANS*U2/(44.01*60.)
2400 PW9=PHTO(DW9)
2410 PW3=P3*PW9/P9
2420 VH3=V3*(1.-PW3/P3)
2430 VH4=VH3-HCON*U2/(2.016*60.)
2440C TRIAL VALUE OF H2+CO2 OUTLET WATER VAPOR PRESSURE:
2450 PW4=PHTO(T2-6.)
2460 VW4=PW4*(VC4+VH4)/(P4-PW4)
2470 DW1=DW7
2480 PW1=PHTO(DW1)
2490 VW1=V1*PW1/P1
2500 VW3=V3-VH3
2510 VWPROD=WPROD*U2/(18.01*60.)
2520 VW2=VW1+VW3-VW4+VWPROD
2530 PO0=PO0PSA*U1
2540 PC7=PO0*P7PSA/POPSA
2550 PO1=PO7
2560 PN1=P1-PO1-PW1-PC1
2570 VN1=V1*PN1/P1
2580 VO1=V1*PO1/P1
2590 VC1=V1*PC1/P1

```

Table 10 - continued

```

2600 VN2=VN1
2610 V02=V01-OCON*U2/(32.*60.)
2620 VC2=VC1-VC4
2630 V2=V02+VN2+VW2+VC2
2640 PW2=VW2*P2/V2
2650 DW2=DEWT(PW2)
2660C
2670C   CHECK MODULE MOISTURE BALANCE:
2680C
2690 DDP1=T1-DW1
2700 DDP2=T2-DW2
2710 IF(ABS(DDP1-11.25).LE.1.75 .AND.ABS(DDP2-11.25).LE.1.75)GOT030
2720 IF(DDP1.LT.4.)GOT01210
2730 IF(DDP1.GT.14.)GOT01210
2740 IF(DDP2.LT.7.)GOT01211
2750 IF(DDP2.GT.19.)GOT01211
2760 DPTDAV=.5*(DDP1+DDP2)
2770 IF(ABS(DPTDAV-11.1).LE.1.5 .AND. (DDP2.GE.13. .OR. DPTDAV.GE.10.))GOT030
2780 WRITE(IOUT;654)
2790 654FORMAT(" AVERAGE CATHODE AIR DEWPOINT DEPRESSION OUT OF RANGE.")
2800 28 WRITE(IOUT;543)
2810 WRITE(IOUT;944)"T1 ",T1,"DDP1",DDP1,"T2 ",T2,"DDP2",DDP2
2820 543FORMAT(" ELECTROLYTE MOISTURE BALANCE IS NOT MAINTAINED.")
2830 IF(NFLAG.EQ.1)GOT01
2840 GOT030
2850 1210 WRITE(IOUT;432)
2860 432FORMAT(" INLET CATHODE AIR DEWPOINT DEPRESSION OUT OF RANGE.")
2870 GOT028
2880 1211 WRITE(IOUT;321)
2890 321FORMAT(" OUTLET CATHODE AIR DEWPOINT DEPRESSION OUT OF RANGE.")
2900 GOT028
2910C
2920C   COMPLETE ALL STREAM DEFINITIONS:
2930C
2940 30 CONTINUE
2950 DELT1P=22.-T1+DW2
2960 T2P=DW1+DELT1P
2970 PW7=PW1
2980 PN7=PN1
2990 PC7=PC1
3000 VC7=PC7*V7/P7
3010 VW7=PW7*V7/P7
3020 PC7=P01
3030 V07=P07*V7/P7
3040 VN7=PN7*V7/P7
3050 RH7=100.*PW7/PHT0(T7)
3060 FC1=VC1*44.01*60./U2
3070 FW1=VW1*18.01*60./U2
3080 RH1=RH7
3090 PH3=P3-PW3

```

Table 10 - continued

```

3100 FH3=VH3*2.016*60./U2
3110 EMOD=16.*E
3120 POWER=N*I*E
3130 TE=TI/.0275
3140 PC2=VC2*P2/V2
3150 FC2=FC1-CTRANS
3160 FW2=VW2*18.01*60./U2
3170 RH2=100.*PW2/PHT0(T2)
3180 T4=T2
3190 V9=V3
3200 DW4=.77*(DW1+DW2)/2. + .23*T2
3210 PW4=PHT0(DW4)
3220 VW4=PW4*(VH4+VC4)/(P4-PW4)
3230 V4=VH4+VC4+VW4
3240 V4SL=V4*U4
3250 VC4SL=VC4*U4
3260 VH4SL=VH4*U4
3270 FC4=CTRANS
3280 FH4=VH4*2.016*60./U2
3290 FW4=VW4*18.01*60./U2
3300 F4=FC4+FH4+FW4
3310 CHWRTO=FC4/FH4
3320 HCVRTO=VH4/VC4
3330 P5=P7
3340 DP56=V5*(V5*C562+C561)
3350 P6=P5-DP56
3360 T6=(V5A*T6A+(V5-V5A)*T51)/V5
3370 IF(V1.LE.62.)PWRCTB=2.8*V1+153.8
3380 IF(V1.GT.62. .AND. V1.LE.65.)PWRCTB=40.*V1-2150.
3390 IF(V1.GT.65.)PWRCTB=-34.*V1+2660.
3400 T11=T2+PWRCTB*U3/(V1*CPA)
3410 V11=V2
3420 P11=P8
3430 PWRCLB=0.
3440 DP1213=C12132*V5*V5
3450 IF(V5.LT.1.01*V5MIN)GOTO14
3460 DP1213=C12132*V5MIN*V5MIN
3470 TR=(DP78/1.869+.05)/1.3
3480 TR=TR**(.128+.102*DP78/1.869)
3490 PWH=410.-.00396*(V5-368)**2
3500 PWL=410.-.00178*(V5-306.)**2
3510 PWRCLB=TR*PWH+(1.-TR)*PWL
3520 14CONTINUE
3530 P12=P8+DP1213
3540 T12=T6+PWRCLB*U3/(V5*CPA)
3550 T13=T12
3560 V12=V5
3570 P13=P8
3580 V13=V5
3590 V8=V10+V2+V5

```

continued-

Table 10 - continued

3600 $VW8=VW7+VW2-VW1$
 3610 $VC8=VC7-VC4$
 3620 $PC8=VC8*P8/V8$
 3630 $VN8=VN7$
 3640 $PN8=VN8*P8/V8$
 3650 $V08=V07-.5*(VH3-VH4)$
 3660 $PW8=P8*VW8/V8$
 3670 $DW8=DEWT(PW8)$
 3680 $T8=(T11*V11+T13*V13+T7*V10+POWER*U3/CPA)/V8$
 3690 $RH8=100.*PW8/PHT0(T8)$
 3700 $AV7=V7*(T7+460.)*1.434/P7$
 3710 $AV1=V1*AV7/V7$
 3720 $AV2=V2*(T2+460.)*1.434/P2$
 3730 $AV11=V11*(T11+460.)*1.434/P11$
 3740 $AV9=V9*(T9+460.)*1.434/P9$
 3750 $AV3=V3*(T3+460.)*1.434/P3$
 3760 $AV4=V4*(T4+460.)*1.434/P4$
 3770 $AV5=V5*AV7/V7$
 3780 $AV6=V5*(T6+460.)*1.434/P6$
 3790 $V6A=V5A$
 3800 $AV6A=V6A*(T6A+460.)*1.434/P6$
 3810 $AV12=V12*(T12+460.)*1.434/P12$
 3820 $AV13=V13*(T13+460.)*1.434/P13$
 3830 $AV10EX=V10*(T7+460.)*1.434/P8$
 3840 $AV8=V8*(T8+460.)*1.434/P8$
 3850C
 3860C EQUIVALENT WEIGHT CALCULATIONS:
 3870C
 3880 HRDWG T=817.9
 3890 PWRPC=136.
 3900 PWREC=45.
 3910 PWRDAU=100.
 3920 PWRTOT=PWRPC+PWREC+PWRCLB+PWRCTB+PWRDAU
 3930 HTTOT=HEATLD+U3*(PWRTOT+POWER)
 3940 PWRWGT=PWPEN*PWRTOT
 3950 HTWGT=HTPEN*HTTOT
 3960 H2OWGT=H2OPEN*WPROD
 3970 OXWGT=OXOPEN*OCON
 3980 EQWGT=PWRWGT+HTWGT+H2OWGT+OXWGT+HRDWGT
 3990C
 4000C MAJOR OUTPUT STATEMENTS
 4010C
 4020 WRITE(IOUT,456)DELT1P,T2P,DW1,DELT1P
 4030 456 FORMAT(" PREFERRED VALUE OF DELT1 IS",F6.2,
 4040 "& UNDER THESE CONDITIONS"/* SO THAT",F6.2,
 4050 "& T2 = DW1 + DELT1 =",F6.2," +",F6.2,".")
 4060C
 4070 944FORMAT(5X,A6,G10.4,31" ! ",A6,G10.4))
 4080C
 4090 WRITE(IOUT,1020)

Table 10 - continued

```

4100 WRITE(IOUT;944)"TI ",TI,"TE ",TE,"E ",E,"EMOD",EMOD,
4110&"CTRANS",CTRANS,"OCON",OCON,"HCON",HCON,"WPROD",WPROD,
4120&"CURDEN",CURDEN,"HEATLD",HEATLD,"POWER",POWER
4130C
4140 WRITE(IOUT;1014)
4150 1014FORMAT(" CATHODE AIR INLET:")
4160 WRITE(IOUT;944)"P1 ",P1,"PC1",PC1,
4170&"PW1",PW1,"FC1",FC1,"FW1",FW1,"VC1",VC1,"VW1",VW1,
4180&"V01",V01,"VN1",VN1,"T1 ",T1,"DW1",DW1,"RH1",RH1
4190C
4200 WRITE(IOUT;1024)
4210 1024FORMAT(" CATHODE AIR OUTLET:")
4220 WRITE(IOUT;944)"P2 ",P2,"DP12",DP12,"PC2",PC2,
4230&"PW2",PW2,"V2 ",V2,"VC2",VC2,"VW2",VW2,
4240&"V02",V02,"VN2",VN2,"FC2",FC2,"FW2",FW2,"T2 ",T2,"DW2",DW2,"RH2",RH2
4250&"P11",P11,"V11",V11,"T11",T11
4260C
4270 WRITE(IOUT;1010)
4280 1010FORMAT(" PROCESS AIR INLET:")
4290 WRITE(IOUT;944)"P7 ",P7,"PW7",PW7,"PN7",PN7,"VC7",VC7,"VW7",VW7,"V07",V07,
4300&"VN7",VN7,"DW7",DW7,"RH7",RH7
4310C
4320 WRITE(IOUT;1015)
4330 1015FORMAT(" PROCESS AIR OUTLET:")
4340 WRITE(IOUT;944)"P8 ",P8,"PC8",PC8,"V10",V10,"DP78",DP78,
4350&"V8 ",V8,"VW8",VW8,"VC8",VC8,"V08",V08,"PW8",PW8,"T8 ",T8,
4360&"DW8",DW8,"RH8",RH8
4370C
4380 WRITE(IOUT;1019)
4390 1019FORMAT(" H2 INLET:")
4400 WRITE(IOUT;944)"P9 ",P9,"PW9",PW9,"DP93",DP93,"P3 ",P3
4410&"PW3",PW3,"PH3",PH3,"V3 ",V3,"VH3",VH3,"VW3",VW3,"FH3",FH3,"V9MSL",V9MSL
4420C
4430 WRITE(IOUT;1013)
4440 1013FORMAT(" H2 OUTLET:")
4450 WRITE(IOUT;944)"P4 ",P4,"DP34",DP34,"PW4",PW4,"V4 ",V4,"VC4",VC4,
4460&"VH4",VH4,"VW4",VW4,"V4SL",V4SL,"VC4SL",VC4SL,"VH4SL",VH4SL,"F4 ",F4,
4470&"FC4",FC4,"FH4",FH4,"FW4",FW4,"DW4",DW4,"CHWRTO",CHWRTO,"HCVRTO",HCVRTO
4480C
4490 WRITE(IOUT;1023)
4500 1023FORMAT(" HEAT BALANCE, MODULES:")
4510 WRITE(IOUT;944)"HEATLD",HEATLD,"DHA",DHA,"DHH",DHH,"DHC",DHC
4520C
4530 WRITE(IOUT;1012)
4540 1012FORMAT(" COOLING AIR:")
4550 WRITE(IOUT;944)"P5 ",P5,"DP56",DP56,"P6 ",P6
4560&"V5 ",V5,"T5 ",T5,"T6 ",T6,"HC ",HC,"ETA",ETA
4570&"V5A",V5A,"T6A",T6A
4580&"P12",P12,"V12",V12,"T12",T12,"DP1213",DP1213,"V5MIN",V5MIN
4590C

```

continued-

Table 10 - continued

```

4600 WRITE(IOUT;1041)
4610 1041FORMAT(" ACTUAL VOLUMETRIC FLOW RATES:")
4620 WRITE(IOUT;944)"AV1",AV1,"AV2",AV2,"AV3",AV3,"AV4",AV4,"AV5",AV5,
4630&"AV6",AV6,"AV6A",AV6A,"AV7",AV7,"AV8",AV8,"AV9",AV9,
4640&"AV10EX",AV10EX,"AV11",AV11,"AV12",AV12,"AV13",AV13
4650C
4660 WRITE(IOUT;1016)
4670 1016FORMAT(" EQUIVALENT WEIGHT:")
4680 WRITE(IOUT;944)"PWRCLB",PWRCLB,"PWRCTB",PWRCTB,"PWRPC",PWRPC,
4690&"PWREC",PWREC,"PWRDAU",PWRDAU,"PWRTOT",PWRTOT,"HTTOT",HTTOT,
4700&"PWRWGT",PWRWGT,"HTWGT",HTWGT,"H20WGT",H20WGT,"OXWGT",OXWGT,
4710&"HRDWGT",HRDWGT,"EQWGT",EQWGT
4720 G OT01
4730 END
4740C
4750 FUNCTION PHT0(TF)
4760 DATA A,B,C,D,EE,F,G/3.2437814,.00586826,1.1702379E-8,
4770& .0021878462,5.219603,273.16,2.3025851/
4780 TC=(TF-32.)/1.8
4790 X=374.11-TC
4800 PHT0=EXP(G*(EE-(X/(TC+F)))*(A+B*X+C*X**3)/(1.0+D*X)))
4810 RETURN
4820 END
4830C
4840 FUNCTION DEWT(P)
4850 EXTERNAL ROOT,PHT0
4860 XX= ALOG(P)
4870 TA=-2.4+20.25*XX+1.522*XX**2
4880 TB=TA+.1
4890 DEWT=ROOT(TA,TB,PHT0,P,.005,.005,5)
4900 RETURN
4910 END
4920C
4930 FUNCTION TICOR(P,AF,CD,DEL)
4940 REAL S(5,7)
4950 DATA S/1.75187,--.511449,.0775073,--.00592584,.000179862,
4960& 1.42306,--.271935,.0210187,-.00034839,-1.8475E-5,
4970& 1.08190,--.110821,-.0081408,.00196359,-8.5832E-5,
4980& .90258,--.105068,.0025161,.00028694,-1.3673E-5,
4990& .71551,-.072213,.0024297,9.08E-6,-3.48E-7,
5000& .61612,-.055237,.0003803,.00028605,-1.5623E-5,
5010& .52087,-.035109,-.0014939,.00035115,-1.4808E-5/
5020 PA=P*(AF/.44)**((.84*P+1.)*EXP(-.84*P))
5030 J=CD/5.-1.
5040 IF(J.LT.1)J=1
5050 TI1=PA*(S(1,J)+PA*(S(2,J)+PA*(S(3,J)+PA*(S(4,J)+PA*S(5,J)))))
5060 IF(J.LT.7)GO TO 8
5070 TICOR=TI1
5080 G OT09
5090 S J=J+1

```

Table 10 - continued

```

5100 TI2=PA*(S(1,J)+PA*(S(2,J)+PA*(S(3,J)+PA*(S(4,J)+PA*S(5,J))))))
5110 AII=J
5120 TERP=CD/5.-AII
5130 TICOR=TI2*TERP+TI1*(1.-TERP)
5140 9 TICOR=TICOR*(1.+.03536*(DEL-18.33))
5150 RETURN
5160 END
5170C
5180 FUNCTION ROOT(X1,X2,YFCN,W,XTOL,YTOL,K)
5190 COMMON IOUT
5200 EXTERNAL YFCN
5210 XA=X1
5220 XB=X2
5230 FA=YFCN(XA)-W
5240 FB=YFCN(XB)-W
5250 DO 91 IROOT=1,K
5260 XN=(FA*XB-FB*X)/ (FA-FB)
5270 FN=YFCN(XN)-W
5280 IF(ABS(FN).LT.YTOL .AND.
5290& ABS(XN-XB).LT.XTOL)GO TO 99
5300 IF(IROOT.GE.K)WRITE(IOUT,200)X1,X2,W,XTOL,YTOL,IROOT,
5310& XA,XB,XN,FA,FB,FN
5320 200 FORMAT( " NONCONVERGENCE IN ROOT",5G11.4,I3/7G11.4)
5330 XA=XB
5340 XB=XN
5350 FA=FB
5360 FB=FN
5370 91 CONTINUE
5380 99 ROOT=XN
5390 RETURN
5400 END
5410C
5420 SUBROUTINE TDRIFT
5430 REAL N,I
5440 COMMON IOUT,CPA,CPH,DHC,DHA,DHH,HEATLD,DTREQ,DTAVA,N,I,E,
5450& HC,ETA,V1,V3,V5A,T6A,T5,T3,T1,T2
5460 EXTERNAL ERT,ROOT,ERT1
5470 ENTHPR=V1*CPA*T1+V3*CPH*T3
5480 T2HIGH=(ENTHPR+.99*HEATLD)/(V1*CPA+V3*CPH)
5490 T2LOW=(ENTHPR+V5A*CPA*T5+HEATLD)/( V1*CPA+V3*CPH+V5A*CPA)
5500 T2=T2HIGH
5510 DUMMY=ERT(V5A/N)
5520 T2=ROOT(T2HIGH,T2LOW,ERT1,0.,.005,.005,20)
5530 RETURN
5540 END
5550C
5560 FUNCTION ERT1(T)
5570 REAL N,I
5580 COMMON IOUT,CPA,CPH,DHC,DHA,DHH,HEATLD,DTREQ,DTAVA,N,I,E,
5590& HC,ETA,V1,V3,V5A,T6A,T5,T3,T1,T2

```

continued-

Table. 10 - continued

```

5600 E=-.729-.22*ALOG(I)+.008*I+.005*(T-78.)
5610 HEATLD=N*I*(1.25-E)*3.419
5620 DHA=V1*CPA*(T-T1)
5630 DHH=V3*CPH*(T-T3)
5640 DHC=HEATLD-DHA-DHH
5650 T6A=T5+DHC/(V5A*CPA)
5660 DTREQ=DHC*(.376+3.876/(HC*ETA))/N
5670 IF(T6A.LT.T)GOTO 1086
5680 ERT1=-DTREQ
5690 RETURN
5700 1086 DTAVA=(T6A-T5)/ALOG((T-T5)/(T-T6A))
5710 ERT1=DTAVA-DTREQ
5720 RETURN
5730 END
5740C
5750 FONCTION ERT(V)
5760 REAL N,I
5770 COMMON IOUT,CPA,CPH,DHC,DHA,DHH,HEATLD,DTREQ,DTAVA,N,I,E,
5780&HC,ETA,V1,V3,V5A,T6A,T5,T1,T2
5790 IF(V.LE.1.)HC=1.97*V**(.3333)
5800 IF(V.GT.1..AND.V.LT.2.9983)HC=1.21+V*(.34+.42*V)
5810 IF(V.GE.2.9983..AND.V.LE.4.)HC=2.*V
5820 IF(V.GT.4.)HC=2.639016*V**(.8)
5830 ETA=1.
5840 IF(V.GT..32194..AND.V.LT.24.72)ETA=1.0644-.1135*SQRT(V)
5850 IF(V.GE.24.72)ETA=2.486/SQRT(V)
5860 T6A=T5+DHC/(V*CPA*N)
5870 DTREQ=DHC*(.376+3.876/(HC*ETA))/N
5880 IF(T6A.LT.T2)GO TO 86
5890 ERT=-DTREQ
5900 RETURN
5910 86 DTAVA=(T6A-T5)/ALOG((T2-T5)/(T2-T6A))
5920 ERT=DTAVA-DTREQ
5930 RETURN
5940 END
5950C
5960 SUBROUTINET(VARNAM,VAR,BOT,TOP,I)
5970 COMMON IOUT
5980 IF(VAR.GE.BOT.AND.VAR.LE.TOP)RETURN
5990 WRITE(IOUT;10)VARNAM,VAR,BOT,TOP
6000 I=I+1
6010 RETURN
6020 10FORMAT(1X,A6,"=",G10.4," RANGE: ",2G10.4)
6030 END

```

REPRODUCIBILITY OF THE
ORIGINAL PAGE IS POOR

TABLE 11 CHECKS AND MESSAGES

1. CONDITION: An input variable is out of the prediction range.
MESSAGE: VARIABLE = XX.XX RANGE: XX.XX XX.XX
2. CONDITION: Less than 1.3 times stoichiometric amount of H₂ is supplied.
MESSAGE: INSUFFICIENT HYDROGEN. XXX.XX SLPM IS REQUIRED.
3. CONDITION: Cathode air blowers cannot supply the requested flow rate. Program sets the flow equal to blower capacity.
MESSAGE: V1 HAS BEEN CHANGED TO 70 SCFM, BLOWER CAPACITY.
4. CONDITION: Not enough heat is generated in the modules to attain the setpoint module temperature.
MESSAGE: COOLING BLOWERS ARE OFF. MODULE TEMPERATURE FALLS X.XXF BELOW THE DESIRED XX.XXF TO XX.XXF.
5. CONDITION: Process streams and cooling air cannot remove enough heat to maintain the setpoint module temperature.
MESSAGE: COOLING BLOWERS ARE ON FULL. MODULE TEMPERATURE RISES X.XXF ABOVE THE DESIRED XX.XXF TO XX.XXF.
6. CONDITION: Normal heat balance is attained.
MESSAGE: DESIRED MODULE TEMPERATURE IS MAINTAINED WITH COOLING BLOWERS AT PARTIAL CAPACITY.
7. CONDITION: Process air flow does not exceed cathode air plus cooling air flow by at least 5%.
MESSAGE: INSUFFICIENT PROCESS AIR TO PREVENT BACKMIXING THROUGH PLENUM BYPASS.
8. CONDITION: Inlet process air moisture conditions are out of tolerance and will not support steady state cell operation.
MESSAGE: INLET PROCESS AIR DEW POINT DEPRESSION OUT OF RANGE. ELECTROLYTE MOISTURE BALANCE IS NOT MAINTAINED.
9. CONDITION: Outlet process air moisture conditions are out of tolerance and will not support steady state cell operation.
MESSAGE: OUTLET PROCESS AIR DEW POINT DEPRESSION OUT OF RANGE. ELECTROLYTE MOISTURE BALANCE IS NOT MAINTAINED.

continued-

Table 11 - continued

10. CONDITION: Average of inlet and outlet process air moisture condition is out of tolerance and will not support steady state cell operation.

MESSAGE: AVERAGE PROCESS AIR DEW POINT DEPRESSION OUT OF RANGE.
ELECTROLYTE MOISTURE BALANCE IS NOT MAINTAINED.

11. CONDITION: Convergence subroutine (ROOT) did not approach a solution within the specified number of iterations.

MESSAGE: NONCONVERGENCE IN ROOT (PRINT ROOT PARAMETERS)

TABLE 12 NOMENCLATURE AND UNITS

Composite Variable Names

First Prefix	P - (Partial) Pressure, mm Hg V - Volume Flow Rate, Scfm 70F, 760 mm Hg AV - Volume Flow Rate, Cfm F - Mass Flow Rate, Lb/Hr DP - Pressure Drop DW - Dew Point, F T - Temperature, F RH - Relative Humidity, %
Second Prefix	C - Carbon Dioxide (CO_2) O - Oxygen (O_2) N - Nitrogen (N_2) H - Hydrogen (H_2) W - Water (H_2O) (None) - Total Stream
Stream Number	\emptyset - Cabin Atmosphere 1 - Cathode Air Modules Inlet 2 - Cathode Air Modules Outlet 3 - H_2 Modules Inlet 4 - H_2 Modules Outlet 5 - Cooling Air Inlet 5A - Cooling Air Inlet, Active Cells 6 - Cooling Air Outlet 6A - Cooling Air Outlet, Active Cells 7 - Process Air Inlet 8 - Process Air Outlet 9 - H_2 System Inlet 10 - Pneum Bypass 11 - Cathode Blowers Outlet 12 - Cooling Blowers Outlet 13 - Cooling Dampers Outlet
Units Suffix	(None) - Units of First Prefix PSA - Psia PSG - Psig SL - Slpm
Additional Variable Names	A,B,C,D,EE,F,G - Constants in pH_2O Dew Point Equation A11,J - Indices Determine S Constants CD - Current Density CHWRTO - CO_2/H_2 Weight Ratio, Lb CO_2 /Lb H_2

continued-

Table 12 - continued

CJKN	Coefficient in Pressure Drop Equation
	J = Inlet Stream Subscript
	K = Outlet Stream Subscript
	N = Degree of Term
COR34,COR93	ΔP Correction Factors for Absolute Pressure
CPA	Volumetric Specific Heat, Air, Btu/Hr-Scfm-F
CPH	Volumetric Specific Heat, H_2 , Btu/Hr-Scfm-F
CTRANS	CO_2 Transferred, Lb/Hr
CURDEN	Current Density, A/Ft
DELT1	Input Control Variable = T2-DP1, F
DELT1P	Preferred Value Control Variable = T2-DP1, F
DELIE	Actual Control Variable = T2-DP1, F
DHA	Enthalpy Gain of Inlet Process Air, Btu/Hr
DHC	Enthalpy Gain of Cooling Air, Btu/Hr
DHH	Enthalpy Gain of Inlet H_2 , Btu/Hr
DDP1,DDP2	Dew Point Depression, Stfeams 1 and 2
DPTDAV	Process Air Dew Point Depression, Average, F
DROP,RISE	T2-(DWI + DELT1), Absolute Value of Module Temperature Offset
DTAVA	Log Mean Available Temperature Drop, F
DTREQ	Required Module - Cooling Air Temperature Drop, F
E	Cell Voltage, Volt
EMOD	Module (16 Cells) Voltage
EQWGT	Total System Equation Weight
ERT,ERT1	Difference Between DTREQ and DTAVA
ESTACK	Stack Voltage, Volt
ETA	Cooling Fin Efficiency, Dimensionless, 0-1
FA,FB,FN	Dependent Values Corresponding to XA,XB,XN
?FIN	File Input Indicator
FNAME	Variable Equal to Output File Name
?FOUT	File Output Indicator
HC	Cooling Fin Heat Transfer Coefficient, Btu/Hr-Ft ² -F
HCON	H_2 Consumption, Lb/Hr
HCVRTO	H_2^2/CO_2 Volume Ratio, Scfm H_2^2 /Scfm CO_2
HEATLD	Net Heat Produced, Btu/Hr
HTPEN	Heat Rejection Penalty, Lb/Btu/Hr
HTTOT	Total Heat Rejection
HTWGT	Heat Rejection Penalty Weight
H2OPEN	H_2O Vapor Rejection Penalty, Lb/Lb/Hr
H2OWGT	H_2O Rejection Penalty Weight
I	Current, A
INP	Input Device Code: 2=File, 50=Terminal
IOUT	Output Device Code: 1=File, 66=Terminal
MATHIN	Name of Input Data File
N	Number of Cells in Circuit
NERROR	Check Violation Indicator

0 - No Violation

1 - Violation

continued-

Table 12 - continued

NFLAG,FLAG	Program Option Integer = 0 or 1
OCON	O ₂ Consumption, Lb/Hr
OXPEN	O ₂ Consumption Penalty, Lb/Lb/Hr
OXWGT	O ₂ Consumption Penalty Weight
P	Inlet pCO ₂
PA	Inlet pCO ₂ Corrected for Effect of Air Flow
POWER	Electrical Power Produced, Watt
PWPEN	Power Penalty, Lb/Watt
PWRCLB	Cooling Blower Power, Watt
PWRCTB	Cathode Blower Power, Watt
PWRDAU	Data Acquisition Unit Power, Watt
PWREC	Emergency Controller Power, Watt
PWRPC	Primary Controller Power, Watt
PWRTOT	Total Power, Watt
PWRWGT	Power Penalty Weight
QA,QB,QC	Coefficients of V5 in Quadratic Formula
S	Array containing Coefficients of PA in TI Correlation
TA,TB	Trial Values of Dew Point, F
TC,TF	Dew Point, C, F, respectively
TE	Current Efficiency, %
TERP	Current Density Interpolation Variable
TI	Transfer Index, Lb CO ₂ /Lb O ₂
T2INP	Set Point Value of T2
T2P	Preferred Value of T2
T11	TI at one of the seven current densities just below the desired current density
T12	TI at one of the seven current densities just above the desired current density
U1	Conversion Factor, mm Hg/Psi
U2	Conversion Factor, Scf/Lb Mol
U3	Conversion Factor, Btu/Hr-Watt
U4	Conversion Factor, 1/Ft ³
V,TR	Dummy and Interpolation Variables
VA,VB	Trial Values for V5
V5INP	Cooling Flow for Set Point Module Temperature
V5MIN	Cooling Flow with Blowers Off
V7M1	Plenum Inlet Flow less Cathode Air Flow
V9MSL	Minimum Flow of H ₂ Required
WAIT	Dummy File Name to Prevent Closing Output File
WPROD	Water Production, Lb/Hr
X1,X2,XA,XB,XN	Trial Values of Independent Variable in Subroutine Root

APPENDIX B CS-6 BASE PROGRAM SAMPLE OUTPUTS

<u>TABLE</u>	<u>PAGE</u>
1 Output Examples	B-2

TABLE 1 OUTPUT EXAMPLES

*****INPUT DATA*****

CABIN ATMOSPHERE:

POPSA	14.70	!	PC0	2.800	!	POOPSA	3.100	!
-------	-------	---	-----	-------	---	--------	-------	---

PROCESS AIR OUTLET/INLET:

PSPSA	14.05	!	T7	55.80	!	V7	444.0	!	DW7	48.00
-------	-------	---	----	-------	---	----	-------	---	-----	-------

H2 OUTLET/INLET:

PAPSA	14.80	!	T9	75.00	!	V9SL	9.700	!	DW9	74.00
-------	-------	---	----	-------	---	------	-------	---	-----	-------

MODULES:

N	96.00	!	I	4.880	!	DELT1	19.00	!	V1	54.00
---	-------	---	---	-------	---	-------	-------	---	----	-------

PENALTY WEIGHT FACTORS:

PWFEN	0.5910	!	HTFEN	0.1280	!	H2OPEN	134.0	!	OPEN	163.0
-------	--------	---	-------	--------	---	--------	-------	---	------	-------

PROGRAM CONTROL:

NFLAG	0.0000	!
-------	--------	---

*****RESULTS*****

DESIRED MODULE TEMPERATURE IS MAINTAINED WITH COOLING BLOWERS AT PARTIAL CAPACITY.

V5INP	261.6	!
-------	-------	---

PREFERRED VALUE OF DELT1 IS 18.81 UNDER THESE CONDITIONS

SO THAT 66.81 = T2 = DW1 + DELT1 = 48.00 + 18.81.

MODULES:

TI	2.184	!	TE	79.41	!	E	0.3643	!	EMOD	5.829
CTRANS	0.6732	!	OCON	0.3083	!	HCON	0.3884E-01	!	WPROD	0.3471
CURDEN	20.00	!	HEATLD	1419.	!	POWER	170.7	!		

CATHODE AIR INLET:

P1	726.8	!	PC1	2.678	!	PW1	8.549	!	FC1	1.359
FW1	1.775	!	VC1	0.1989	!	VW1	0.6352	!	VO1	11.39
VN1	41.78	!	T1	55.80	!	DW1	48.00	!	RH1	75.01

CATHODE AIR OUTLET:

P2	718.6	!	DP12	8.183	!	PC2	1.336	!	PW2	10.14
V2	53.97	!	VC2	0.1004	!	VW2	0.7619	!	VO2	11.33
VN2	41.78	!	FC2	0.6853	!	FW2	2.129	!	T2	67.00
DW2	52.61	!	RH2	59.89	!	P11	726.4	!	V11	53.97
T11	84.94	!								

PROCESS AIR INLET:

P7	726.8	!	PW7	8.549	!	PN7	562.3	!	VC7	1.636
VW7	5.223	!	VO7	93.63	!	VN7	343.5	!	DW7	48.00
RH7	75.01	!								

PROCESS AIR OUTLET:

P8	726.4	!	PC8	2.515	!	V10	128.4	!	DP78	0.3711
V8	444.0	!	VW8	5.350	!	VC8	1.537	!	VO8	93.57
PW8	8.753	!	T8	64.85	!	DW8	48.63	!	RH8	55.67

H2 INLET:

P9	912.2	!	PW9	21.49	!	DP93	143.5	!	P3	768.7
PW3	18.11	!	PH3	750.6	!	V3	0.3425	!	VH3	0.3344
VW3	0.8071E-02	!	FH3	0.1046	!	V9MSL	4.573	!		

continued-

Table 1 - continued

H2 OUTLET:

P4	765.2	!	DP34	3.566	!	PW4	10.73	!	V4	0.3132
VC4	0.9859E-01	!	VH4	0.2103	!	VW4	0.4393E-02	!	V4SL	8.871
VC4SL	2.792	!	VH4SL	5.955	!	F4	0.7513	!	FC4	0.0732
FH4	0.6577E-01	!	FW4	0.1227E-01	!	DW4	54.14	!	CHWRTO	10.24
HCVRTO	2.133	!								

HEAT BALANCE, MODULES:

HEATLD	1419.	!	DHA	651.1	!	DHH	-2.923	!	DHC	770.5
COOLING AIR:										
P5	726.8	!	DP56	3.533	!	P6	723.2	!	V5	261.6
T5	55.80	!	T6	58.54	!	HC	5.255	!	ETA	0.8770
V5A	261.6	!	T6A	58.54	!	P12	728.5	!	V12	261.6
T12	63.08	!	DP1213	2.085	!	V5MIN	49.20	!		

ACTUAL VOLUMETRIC FLOW RATES:

AV1	54.96	!	AV2	56.75	!	AV3	0.3418	!	AV4	0.3094
AV5	266.2	!	AV6	268.9	!	AV6A	268.9	!	AV7	451.9
AV8	460.0	!	AV9	0.2381	!	AV10EX	130.8	!	AV11	58.06
AV12	269.3	!	AV13	270.1	!					

EQUIVALENT WEIGHT:

PWRCLB	374.1	!	PWRCTB	305.0	!	PWRPC	136.0	!	PWRREC	45.00
PWRDAU	100.0	!	PWRTOT	960.1	!	HTTOT	5285.	!	PWRHGT	567.4
HWTG	676.5	!	H2OWGT	46.51	!	OXWGT	473.5	!	HRDWGT	817.9
EQWGT	2582.	!								

*****INPUT DATA*****

CABIN ATMOSPHERE:

POPSA	14.70	!	PCO	0.6830	!	POOPSA	3.100	!		
-------	-------	---	-----	--------	---	--------	-------	---	--	--

PROCESS AIR OUTLET/INLET:

P8PSA	14.05	!	T7	55.80	!	V7	444.0	!	DW7	48.00
-------	-------	---	----	-------	---	----	-------	---	-----	-------

H2 OUTLET/INLET:

P4PSA	14.80	!	T9	75.00	!	V9SL	9.700	!	DW9	74.00
-------	-------	---	----	-------	---	------	-------	---	-----	-------

MODULES:

N	96.00	!	I	4.880	!	DELT1	19.00	!	V1	54.00
---	-------	---	---	-------	---	-------	-------	---	----	-------

PENALTY WEIGHT FACTORS:

PPPHM	0.5910	!	HTPM	0.1280	!	H2OPEN	134.0	!	OKPEN	1536.
-------	--------	---	------	--------	---	--------	-------	---	-------	-------

PROGRAM CONTROL:

NFLAG	0.0000	!							
-------	--------	---	--	--	--	--	--	--	--

*****RESULTS*****

DESIRED MODULE TEMPERATURE IS MAINTAINED WITH COOLING BLOWERS AT PARTIAL CAPACITY.

V5INF 261.6 !

PREFERRED VALUE OF DELT1 IS 18.82 UNDER THESE CONDITIONS

SO THAT 66.82 = T2 = DW1 + DELT1 = 48.00 + 18.82.

MODULES:

T1	0.8224	!	TE	29.91	!	E	0.3643	!	EMOD	5.829
CTRANS	0.2535	!	OCON	0.3083	!	HCON	0.3884E-01	!	WPROD	0.3471
CURDEN	20.00	!	HEATLD	1419.	!	POWER	170.7	!		

CATHODE AIR INLET:

P1	726.8	!	PC1	0.6531	!	PW1	8.549	!	FC1	0.3314
FW1	1.775	!	VC1	0.4853E-01	!	VW1	0.6352	!	V01	11.39
VN1	41.93	!	T1	55.80	!	DW1	48.00	!	RH1	75.01

Life Systems, Inc.

Table 1 - continued

CATHODE AIR OUTLET:								
P2	718.6	!	DP12	8.183	!	PC2	0.1516	!
V2	54.03	!	VC2	0.1140E-01	!	VW2	0.7630	!
VN2	41.93	!	FC2	0.7786E-01	!	FW2	2.132	!
DW2	52.62	!	RH2	59.91	!	P11	726.4	!
T11	84.94	!						
PROCESS AIR INLET:								
P7	726.8	!	PW7	8.549	!	PN7	564.3	!
VW7	5.223	!	VO7	93.63	!	VN7	344.7	!
RH7	75.01	!						
PROCESS AIR OUTLET:								
P8	726.4	!	PC8	0.5920	!	V10	128.4	!
V8	444.0	!	VW8	5.351	!	VC8	0.3619	!
PW8	8.753	!	T8	64.85	!	DW8	48.63	!
H2 INLET:								
P9	912.2	!	PW9	21.49	!	DP93	143.5	!
PW3	18.11	!	PH3	750.6	!	V3	0.3425	!
VW3	0.8071E-02	!	FH3	0.1046	!	V9MSL	4.573	!
H2 OUTLET:								
P4	765.2	!	DP34	3.566	!	PW4	10.73	!
VC4	0.3713E-01	!	VH4	0.2103	!	VW4	0.3520E-02	!
VC4SL	1.051	!	VH4SL	5.955	!	F4	0.3291	!
FH4	0.6577E-01	!	FW4	0.9835E-02	!	DW4	54.15	!
HCVRTO	5.663	!						
HEAT BALANCE, MODULES:								
HEATLD	1419.	!	DHA	651.1	!	DHH	-2.923	!
COOLING AIR:								
P5	726.8	!	DP56	3.533	!	P6	723.2	!
T5	55.80	!	T6	58.54	!	HC	5.255	!
V5A	261.6	!	T6A	58.54	!	P12	728.5	!
T12	63.08	!	DP1213	2.085	!	V5MIN	49.20	!
ACTUAL VOLUMETRIC FLOW RATES:								
AV1	54.96	!	AV2	56.82	!	AV3	0.3418	!
AV5	266.2	!	AV6	268.9	!	AV6A	268.9	!
AV8	460.1	!	AV9	0.2881	!	AV10EX	130.8	!
AV12	269.3	!	AV13	270.1	!			
EQUIVALENT WEIGHT:								
PWRCLB	374.1	!	PWRCTB	305.0	!	PWRPC	136.0	!
PWRDAU	100.0	!	PWRTOT	960.1	!	HTTOT	5285.	!
HTWGT	676.5	!	H2OWGT	46.51	!	OXWGT	473.5	!
EQWGT	2582.	!						

OK

APPENDIX C CS-6 CABIN pCO₂ SIMULATION PROGRAM DOCUMENTATIONTABLE

	<u>PAGE</u>
1 Main Program Flow Chart	C-2
2 Base Subroutine Flow Chart	C-11
3 Water Vapor Pressure Function	C-27
4 Dew Point Temperature Function	C-28
5 Transfer Index Function	C-29
6 Root Function	C-31
7 Module Temperature Subroutine	C-33
8 Heat Balance Function With Variable Module Temperature . .	C-34
9 Heat Balance Function With Variable Cooling Air Flow Rate	C-36
10 Range Test Subroutine	C-38
11 Mode B Current and Cathode Air Flow Subroutine	C-39
12 Cyclic Program Listing	C-40
13 Checks and Messages	C-58
14 Nomenclature and Units	C-60
15 Key to Selective Output Variables	C-64

TABLE 1 MAIN PROGRAM FLOW CHART

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
		START	
	150-720		Initialize type, common, equivalence, external and data statements
	760	PRINT, "FILE INPUT (T OR F)"	
	770	READ, QFIN	
	780	INP = 50	
	790	IF (QFIN) INP=2	
	800	IF (QFIN) CALL OPEN F(2, "MATHIN")	
C-2	810	PRINT, "FILE OUTPUT (T OR F)"	
	820	READ, QFOUT	
	830	IF (NOT, QFOUT) IOUT=66	
	850	PRINT, "END OF INPUT DATA FILE"	Program branches to this point and terminates when a file input statement is attempted (usually line 1050) but the input file has been exhausted.
	860	CALL EXIT	
	900	IF (NOT QFOUT) BRANCH	Obtain output file name if file output is in use.
	910	IF (NOT QFIN) PRINT, "FILE FOR INPUT"	

-continued-

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	920-930	READ, FNAME	
	980	IF (FNAME ≠ "SAME") CALL CLOSEF(1, FNAME, 7)	Assign the name to the file and close it unless the name is SAME, indicating that more output will be written into the same file.
(2)	1020-1040	IF (NOT QFIN) PRINT, "PROBLEM IDENTIFIER"	Read and write the problem identifier which may be any comments up to 84 characters long.
	1050	READ, IDENTIFIER	
	1060	IF (QFIN) PRINT, IDENTIFIER	
	1100	PRINT, "NEW CO2 GENERATION TABLE?"	Input and output new CO2 generation table if desired, or use the table stored in the program.
	1110	READ, QCO2GT	
	1120	IF(QCO2GT) READ, CO2 GENERATION TABLE	
	1130-1160	IF (QCO2GT) PRINT, CO2 GENERATION TABLE	
	1210	IF (NOT QFIN) PRINT, "INPUT DATA"	Read inputs for base, Mode B, and time intervals in the order and ranges specified in Table 1.
	1220	READ, POPSA, PCO,...,DT,DPRINT	
	1280	IF (NOT QFIN) PRINT, "PRINT BASE OUTPUT (T OR F)"	Indicate whether the base program output table should be printed (T) or omitted (F).

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	1290	READ, QPRINT	
	1300	KBASE = 4	
	1310	IF (QPRINT) KBASE = 5	
	1320	IF (NOT QFIN) PRINT, "NEW CYCLIC OUTPUT SUBSCRIPTS?"	Read new cyclic table output item subscripts if they are to be changed.
	1330	READ, QSUBS	
	1340	IF (QSUBS) READ, NDEX, INDEX ₁ ,...,INDEX _{NDEX}	
	1350	IF (QFOUT) PRINT, "START PROBLEM"	Print message at terminal indicating that a set of inputs is complete and calculation is beginning.
	1390	$BK_9 = \frac{BK_1 - BK_4}{BK_2 - BK_3}$	
	1400	$BK_{10} = BK_1 - BK_9(BK_2)$	Calculate slopes and intercepts for Mode B current and cathode air flow curves.
	1410	$BK_{11} = \frac{BK_5 - BK_8}{BK_6 - BK_7}$	
	1420	$BK_{12} = BK_5 - BK_{11}(BK_6)$	
	1470	IF(KMODE=1)CALL BMODE	If Mode B is in effect, determine current and cathode air flow for the initial pCO ₂ .
	1480-1780	WRITE,POPSA,PCO,...,DT,DPRINT	Playback base, Mode B and time interval inputs with current and cathode air flow determined by Mode B if it is in effect.
	1820	IR=0	

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	1830	CALL T("POPSA","POPSA,13.7, 15.7,IR)	Initialize out-of-range input variable counter.
	1840-2170		
	2180	CALL T("DPRINT","",DPRINT,1, 100,IR)	Subroutine T checks each input variable against its allowable range. Out-of-range variables are printed and cause IR to be incremented.
(1) 	2190	IF(IR > 0) BRANCH	If the counter shows that one or more inputs is out-of-range, abort the simulations and read in next set of inputs.
C-5 	2230	CALL BASE(KMODE,KBASE,1, KERROR)	Call BASE to determine all system parameters at time zero, to print a base output table if indicated by KBASE=5, and to abort simulation if KERROR value returned by BASE indicates that certain inputs do not support steady-state. Also abort if no. of days to be simulated = 0.
(1) 	2240	IF(KERROR #0 OR DAYS =0) BRANCH	
	2280	NDT=DT	Initialize integer variables:integration time interval, day counter, minutes per cycle (day), limit on number of days, and printing time increment.
	2290	NDAY=0	
	2300	MINCYC=TMAX(NSTEPS)	
	2310	NDAYS=DAYS	
	2320	NPRINT=DPRINT	

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	2330	$US = \frac{(T\emptyset + 460)(386.7)(760)}{(530)(VOLUME)(60)(44.01)}$	Calculate proportionality constant between net CO ₂ removal (Lb/Hr) and cabin pCO ₂ change rate (mm Hg/Min).
	2340	MAXDEX=0	Determine the names (HDG) of the variables to be printed out in the table versus time, and find largest subscript (MAXDEX).
	2350	DO 110 MN=1,NDEX	
	2360	IN=INDEX(MN)	
	2370	HDG(MN)=HEAD(IN)	
	2380	110 IF (IN > MAXDEX)MAXDEX=IN	
	2390	IF (1 ≤ MAXDEX ≤ 52)KBASE=1	Calculate the parameter KBASE which indicates to the BASE subroutine which of its output variables must be calculated and which sections may be omitted for faster execution.
	2400	IF (53 ≤ MAXDEX ≤ 78)KBASE=2	
	2410	IF (79 ≤ MAXDEX ≤ 129)KBASE=3	
	2420	IF (130 ≤ MAXDEX ≤ 150)KBASE=4	
(3)	2470	QPRINT=.TRUE.	A line will be printed at time zero.
	2480	NT=0	
	2490	D0725 MN=1,NDEX	Clear the variable containing the average of the parameters, AVG.
	2500	725 AVG(MN)=0	
	2510	NDAY=NDAY + 1	Increment the day counter.
	2520	PCOI=PCO	Store the cabin pCO ₂ for the beginning of the cycle.

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	2530	IGEN=1	Initialize the CO ₂ generation rate step counter and the CO ₂ generation rate.
	2540	CO2GEN=CGEN(1)	
	2580	IF(QFOUT)PRINT, NDAY	If file output is being used, print the day counter on the terminal to indicate progress of the program to the operator.
	2590-2620	PRINT CYCLIC TABLE HEADINGS	
	2630	WRITE, 0,0	Print time at time zero.
	2640	CALL BASE(KMODE,KBASE,1,KERROR)	Call BASE to determine system parameters at time zero and to print any error messages.
	2650	IF(KERROR ≠ 0)BRANCH	If the variable KERROR indicates that conditions will not support the steady-state, then BRANCH to get the next set of input data.
	2700	IF (NOT QPRINT) BRANCH	Print a line in the cyclic table at the proper time.
	2710-2750	PRINT A LINE IN THE CYCLIC TABLE	
	2820	IF (NT < MINCYC) BRANCH	BRANCH if it is not the end of the day.
	2830	DO 726 MN=1,NDEX	Complete calculation of average system parameters.
	2840	726 AVG(MN)=AVG(MN). $\frac{DT}{MINCYC}$	
	2850-2870	PRINT AVERAGES	

Table 4 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
1	2880	IF (NDAY=NDAYS OR $\left \frac{PCO-PCOI}{PCO} \right < 0.0005$) BRANCH	Start a new cycle unless either steady-state has been reached or maximum number of cycles has been reached.
3	2940	NT=NT + NDT	Increment time.
5	2950	QPRINT=MOD(NT,NPRINT).EQ.0	Determine whether a table line will be printed at this time.
	2960	IF(NT > TMAX(IGEN)) IGEN=IGEN+1	Update CO ₂ generation rate.
C-8	2970	CO2GEN = CGEN(IGEN)	
	3010	IF(NOT QPRINT) BRANCH	Print the time if a line of table will be printed at this time.
	3020	NHRS = NT/60	
	3030	NMIN=NT - NHRS(60)	
	3040-3050	WRITE TIME	
	3100	XA=PCO	
	3110	SLOPEA=U5(CO2GEN-CTRANS)	
	3120	SLOPE=SLOPEA	
	3130	PCN=PCO + SLOPE x DT	
	3140	YA=XA - PCN	Calculate pCO ₂ at the new time. First assume that pCO ₂ has not changed during the latest time increment. Calculate the rate of pCO ₂ change at the beginning of the time increment (SLOPEA). Calculate average rate of pCO ₂ change during the time interval (SLOPE). Using the old pCO ₂ and the average slope, recalculate the new pCO ₂ . The error associated with the first trial is YA.

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	3150	XB=PCN	
	3160	PCO=PCN	
	3170	CALL BASE(KMODE,0,0,KERROR)	
①	3180	IF(KERROR ≠ 0)BRANCH	
	3190	SLOPEB=U5 x(CO2GEN-CTRANS)	
	3200	SLOPE = 0.5 x(SLOPEA+SLOPEB)	
	3210	PCN=XA + SLOPE x DT	
C-9	3220	YB = XB - PCN	
	3230	PCO= $\frac{YAxXB-YBxxA}{YA-YB}$	The cabin pCO ₂ at the end of the time increment is found with precision by finding the zero of the function defined by two points with coordinates (XA,YA), and (XB,YB). Linear interpolation is used because both points are already close to the root.
	3240	KPRINT=0	
	3250	IF(QPRINT)KPRINT=1	Calculate KPRINT, the parameter to BASE which determines when error messages can be printed by BASE. Error messages will not be printed unless it is time to print a line in the cyclic table.
	3290	CALL BASE(KMODE,KBASE,KPRINT, KERROR)	Call BASE to calculate system parameters at the new cabin pCO ₂ .

Table 1 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
① ↗	3300	IF (KERROR ≠ 0) BRANCH	
█	3310-3330		Update the average system parameters.
█	3360	SLOPEC=U5 x (CO2GEN-CTRANS)	
█	3370	SLOPE = 0.5 x (SLOPEA+SLOPEC)	Check for error in cabin pCO ₂ and BRANCH to print a line of data in the cyclic table.
█	3380	PCN=XA - SLOPE x DT	
█	3390	YC= PCO - PCN	

TABLE 2 BASE SUBROUTINE FLOW CHART

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
		START	
	3680	CPA = 1.0765	Initialize Constant Btu/Hr/Scfm-F
	3680	CPH = 1.0666	Initialize Constant Btu/Hr/Scfm-F
	3690	U1 = 51.7	Initialize Constant mm Hg/Psi
	3690	U2 = 386.7	Initialize Constant Scfm/Lb-Mol/Hr
	3690	U3 = 3.419	Initialize Constant Btu/Hr/Watt
	3690	U4 = 28.32	Initialize Constant 1/Ft ³
	3700	C782 = 2.25 x 10 ⁻⁵	
	3700	C562 = 1.303 x 10 ⁻⁵	Initialize constants for pressure drop equations
	3700	C561 = 1.01 x 10 ⁻²	
	3700	C6132 = 8.611 x 10 ⁻⁴	
	3710	C5132 = C562 + C6132	
	3710	C5131 = C561	
	3710	QA = CS132 - C782	
	3720	HRDWGT = 817.9 Lb	Initialize weight and power constants
	3720	PWRPC = 136 WATTS	
	3720	PWREC = 45 WATTS	
	3720	PWRDAU = 100 WATTS	

-continued-

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	3730	KERROR = 0	Initialize error indicator
(1)	3740	IF (KMODE + KBASE=0) BRANCH	
	3750	IF (KMODE=1) CALL BMODE	
	3790	V9MSL = (1.3)(N)(I)(7.058 x 10^{-3})	Calc. required H ₂ flow
	3800	IF V9MSL ≤ V9SL THEN BRANCH	Check for sufficient H ₂ Flow
	3810-3820	WRITE "INSUFFICIENT H ₂ ," V9MSL, "IS REQUIRED"	Write error message and required H ₂ flow
C-12	3830	KERROR = 1	Return in error condition
	3840	RETURN	
	3890	IF V1≤70 THEN BRANCH	Check that V1 is less than the process air blower capacity
	3900	V1 = 70	Set V1 to maximum blower capacity
	3910-3920	WRITE "AIRFLOW CHANGE TO 70 SCFM"	Print error message
	3970	V7M1 = V7 - V1	
	3980	QB = C5131 + 2(V7M1) ²	
	3990	QC = C782 (V7M1) ²	
	4000	V5MIN = $\frac{-QB + \sqrt{QB^2 + 4(QA)(QC)}}{2(QA)}$	Calculate bypass cooling air flow with cooling blowers off; i.e., calculate minimum cooling air flow rate

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
C-13	4040	DW1 = DW7	
	4050	T2 = DW1 + DELT1	Calculate cell temperature
	4060	T2INP = T2	Store input T2
	4070	E = 0.729 - 0.22 lnI + 0.008I + 0.005 (T2-78)	Calculate cell voltage
	4080	HEATLD = (1.25-E)(N)(I)(U3)	Calculate modules' heatload
	4090	T1 = T7	
	4100	T3 = T9	
	4110	V3 = V9SL/U4	
	4120	T5 = T1	
	4130	DHA = V1 (CPA) (T2 - T1)	Calculate heat removed by cathode air flow
	4140	DHH = V3 (CPH) (T2-T3)	Calculate heat removed by H ₂
	4150	DHC = HEATLD-DHA-DHH	Calculate heat removed by cooling air
	4190	If DHC > 0 THEN BRANCH	Check to see if cooling air is required
	4240	V5 = V5MIN	Set cooling air flow to minimum
	4250	VSA = (N)(V5MIN)/96	Calculate flow thru active cells

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	4260	CALL TDRIFT	Calculate T2 for subcooled condition
	4270	DROP = T2INP-T2	Calculate temperature, T2, drop
(6)	4280	IF (DROP ≤ 3) BRANCH	
(6)	4290	IF (KPRINT = 0) BRANCH	
	4300-4320	WRITE "V5MIN," V5MIN "COOLING BLOWERS OFF," "MODULE TEMPERATURE FALLS," DROP, "NEW T2," T2	Print out new conditions
(6)	4390	IF T2-T5 ≥ $\frac{(0.376)DHC}{N}$ THEN BRANCH	Check if there is sufficient ΔT to conduct heat up fins
(4)	4440	V5 = 440	Set V5 to maximum blower capacity
	4450	V5A = V5(N)/96	Calculate flow thru active cells
	4460	Call TDRIFT	Calculate T2
	4470	RISE = T2-T2INP	Call rise in module temperature
(6)	4480	IF (RISE ≤ 3) BRANCH	
(6)	4490	IF (KPRINT = 0) BRANCH	
	4500-4520	WRITE "COOLING BLOWERS ON FULL," "MODULE TEMPERATURE RISES," RISE, "NEW T2," T2	Print out new conditions
(6)			
(7)			

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	4580	VA = 1.01 x DHC/CPA (N)(T2-T5)	
	4590	VB = 2(VA)	
	4600	VSA = (N) · ROOT (VA, VB, ERT, 0, 0.005, 0.001, 20)	Calculate cooling air flow past active cells
	4610	VS = 96(VSA)/N	Calculate total cooling air flow
	4620	V5INP = VS	
(5) ← C-15	4660	If VS < V5MIN THEN BRANCH	Check for subcooling
(8) ←	4670	If VS > 440 THEN BRANCH	Check for heatup
(6) →	4720	V10 = V7-V1-V5	Calculate plenum bypass flow
	4760	IF V10 ≥ 0.05 (V8) THEN BRANCH	Check for sufficient plenum bypass
	4770	IF (KPRINT = 0) BRANCH	
	4780-4810	WRITE "INSUFFICIENT AIR FLOW, RECIRCULATION OF AIR FROM OUTLET TO INLET"	Print error message
(1) →	4880	IF(KBASE = 0) BRANCH	
	4890	COR34 = $\frac{(14.1)}{P4PSA} 0.8$	
	4900	P4 = P4PSA (V1)	
	4910	V3SL = V9SL	
	4920	DP34 = (0.3822) (COR34) (V3SL)	Calculate module H ₂ cavity pressure drop

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	4930	IF V3SL ≤ 22 THEN BRANCH	
	4930	$DP34 = COR34 \left(\frac{8.3183}{0.4187} (V3SL - 21.5801) \right)^{1.75}$	
	4940	$P3 = P4 + DP34$	Calculate module H ₂ inlet pressure
	4950	$P3PSA = P3/U1$	
	4960	$COR93 = \frac{(14.1)^0.8}{P3PSA}$	
	4970	$DP93 = (COR93)(10.64)(V3SL)$	Calculate H ₂ distribution block pressure drop
	4980	IF V3SL ≤ 6.2 THEN BRANCH	
	4980	$DP93 = COR93 \left[\frac{35.64}{195.25 + e^{(0.75 - 0.6537V3SL)}} \right]$	
	4990	$P9 = P3 + DP93$	Calculate H ₂ inlet pressure
	5000	$P9PSA = P9/U1$	
	5010	$DP78 = 2.25 \times 10^{-5} (V10)^2$	Calculate process air inlet pressure using plenum pressure drop correlation
	5020	$P8 = P8PSA(U1)$	
	5030	$P7 = P8 + DP78$	
	5040	$P7PSA = P7/U1$	
	5050	$DP12 = 0.001903(V1)^2 + 0.04877(V1)$	Calculate cathode air pressure drop
	5060	$P1 = P7$	

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5070	P2 = P1-DP12	Calculate cathode air out pressure
(14)	5080	CURDEN = I/0.244	Calculate current density
	5090	DELT1E = T2-DW1	Calculate actual humidity ΔT
(13)	5110	PC1 = PCO $\frac{P7PSA}{POPSA}$	Calculate cathode inlet pCO ₂
	5120	TI = TICOR (PC1, V1/96, CURDEN, DELTIE)	Calculate TI
	5130	OCON = $6.5803 \times 10^{-4} (N)(I)$	Calculate O ₂ consumed
	5140	CTRANS = TI (OCON)	Calculate CO ₂ transferred
C-17	5150	IF(KBASE ≤ 1) RETURN	
	5160	HCON = OCON $\frac{2.016}{16}$	Calculate H ₂ consumed
	5170	WPROD = HCON + OCON	Calculate water produced
	5180	VC4 = CTRANS $\frac{V2}{44.01 \times 60}$	
	5190	PW9 = PHTO (DW9)	
	5200	PW3 = P3 $\frac{PW9}{P9}$	Calculate anode gas stream parameters
	5210	VH3 = V3(1 - $\frac{PW3}{P3}$)	
	5220	VH4 = VH3-HCON $\frac{U2}{2.016 \times 60}$	
	5240	PW4 = PHTO (T2-6)	
	5250	VW4 = $\frac{PW4}{P4-PW4} (VC4 + VH4)$	

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5260	$DW1 = DW7$	
	5270	$PW1 = PHTO (DW1)$	Calculate cathode air water balance parameters
	5280	$VW1 = V1 \frac{PW1}{P1}$	
	5290	$VW3 = V3-VH3$	
	5300	$VWPROD = WPROD \frac{V2}{18.01 \times 60}$	
	5310	$VW2 = VW1 + VW3 - VW4$	
	5320	$POO = POOPSA/U1$	
	5330	$PO7 = POO (P7/PO)$	
	5340	$PO1 = PO7$	Calculate cathode air inlet stream parameters
	5350	$PN1 = P1-PO1-PW1-PC1$	
	5360	$VN1 = V1 (PN1/P1)$	
	5370	$VO1 = V1 (PO1/P1)$	
	5380	$VC1 = V1 (PC1/P1)$	
	5390	$VN2 = VN1$	
	5400	$VO2 = VO1 - OCON (U2/32 \times 60)$	
	5410	$VC2 = VC1 - VC4$	Calculate cathode air outlet stream parameters

C-18



Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5420	$V2 = V02 + VN2 + VW2 + VC2$	
	5430	$PW2 = \frac{VW2}{V2} P2$	
	5440	$DW2 = DEWT(PW2)$	
(q) ← { }	5500	IF $T1-DW1 = 11.25 \pm 1.75$ AND $T2-DW2 = 11.25 \pm 1.75$ THEN BRANCH	
{ } ← (q)	5510	IF $T1-DW1 \geq 4$ THEN BRANCH	
C-19	5640-5650	WRITE "INLET AIR HUMIDITY OUT-OF-RANGE"	
(10) ← { }	5520	IF $T1-DW1 \leq 14$ THEN BRANCH	
{ } ← (10)	5530	IF $T2-DW2 \geq 7$ THEN BRANCH	Perform moisture balance checks
C-19	5670-5680	WRITE "OUTLET AIR HUMIDITY OUT-OF-RANGE"	
(12) ← { }	5540	IF $T2-DW2 \leq 19$ THEN BRANCH	
{ } ← (12)	5550	$DPTDAV = \frac{1}{2} (T1-DW1+T2-DW2)$	
(q) ← { }	5560	IF $DPTDAV = 11 \pm 1.5$ AND EITHER $T2-DW2 \geq 13$ OR $DPTDAV \geq 0$ THEN BRANCH	
{ } ← (q)	5570-5580	WRITE "AVE DEW PT DEPRESSION OUT OF-RANGE"	
(11) ← { }	5590-5610	WRITE "ELECTROLYTE MOISTURE BALANCE NOT MAINTAINED"	

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
C>20	5620	KERROR = 3	
	5630	IF NFLAG = 1 THEN RETURN	Check NFLAG for program abort
	5740	IF (KBASE = 2) RETURN	
	5750	DELT1P = 22-T1 + DW2	Calculate preferred ΔT
	5760	T2P = DP1 + DELT1P	
	5770	PW7 = PW1	
	5780	PN7 = PN1	
	5790	PC7 = PC1	Complete definition of process air inlet stream
	5800	VC7 = $\frac{PC7}{P7}$ (V7)	
	5810	VW7 = $\frac{PW7}{P7}$ (V7)	
	5820	PO7 = PO1	
	5830	VO7 = $\frac{PO7}{P7}$ (V7)	
	5840	VN7 = $\frac{PN7}{P7}$ (V7)	
	5850	RH7 = 100 $\frac{PW7}{PHTO(T7)}$	
	5860	FC1 = VC1 $\frac{44.01 \times 60}{U2}$	Complete cathode air inlet stream definition

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	5870	$FW1 = VW1 \frac{18.01 \times 60}{U2}$	
	5880	$RH1 = RH7$	Complete cathode air inlet def.
	5890	$PH3 = P3 - PW3$	Complete definition of H_2 inlet
	5900	$FH3 = VH3 \frac{2.016 \times 60}{U2}$	
	5910	$EMOD = 16(E)$	
	5920	$POWER = (N)(I)(E)$	Calculate remaining module parameters
	5930	$TE = TI/0.0275$	
	5940	$PC2 = VC2 \frac{P2}{V2}$	
	5950	$FC2 = FC1 - CTRANS$	
	5960	$FW2 = VW2 \frac{18.01 \times 60}{U2}$	Complete definition of cathode air outlet
	5970	$RH2 = 100 \frac{PW2}{PHTO(T2)}$	
	5980	$T4 = T2$	
	5990	$V9 = V3$	
	6000	$DW4 = 0.77 \frac{DW1 + DW2}{2} + 0.23T2$	Refined H_2 dew point correlation
	6010	$PW4 = PHTO(DW4)$	
	6020	$VW4 = \frac{PW4}{P4-PW4} (VH4 + VC4)$	Complete definition of anode gas outlet
	6030	$V4 = VH4 + VC4 + VW4$	

C-21



Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	6040	V4SL = V4(U4)	
	6050	VC4SL = VC4(U4)	
	6060	VH4SL = VH4(U4)	
	6070	FC4 = CTRANS	
	6080	FH4 = VH4 $\frac{2.016 \times 60}{U2}$	
	6090	FW4 = VW4 $\frac{18.01 \times 60}{U2}$	
	6100	F4 = FC4 + FH4 + FW4	
	6110	CHWRTO = FC4/FH4	
	6120	HCVRTO = VHR/VC4	
	6130	P5 = P7	
	6140	DP56 = $(V5)^2 C562 + V5(C561)$	Calculate cooling air pressure drop
	6150	P6 = P5-DP56	Calculate cooling air outlet pressure
	6160	T6 = $\frac{(V5A)T6A + (V5-V5A)T5}{V5}$	Calculate cooling air out temperature
	6170	IF VI ≤ 62 THEN PWRCTB = 2.8V + 153.8	
	6180	IF 62 < V1 ≤ 65 THEN PWRCTB = 40V1 - 2150	Calculate cathode air blower power
	6190	IF 65 < V1 ≤ 70 THEN PWRCTB = -34V1 + 2660	

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	6200	$T11 = T2 + \frac{PWRCTB(U3)}{V1 \cdot CPA}$	
	6210	$V11 = V2$	Define stream after cathode blower
	6220	$P11 = P8$	
	6240-6250	IF $V5-V5MIN < 0.001(V5MIN)$ THEN PWRCLB = 0, $DP1213=C12132(V5)^2$ AND BRANCH	Check if cooling blower is off
C-23	6260	$DP1213 = C12132 (V5MIN)^2$	
	6270	$TR = (\frac{DP78}{1.869} + 0.05)/1.3$	
	6280	$TR = TR (0.128 + 0.102(\frac{DP78}{1.869}))$	Calculate cooling blower power
	6290	$PWH = 410 - 0.00396 (V5-368)^2$	
	6300	$PWL = 410 - 0.00178 (V5 - 306)^2$	
	6310	$PWRCLB = TR (PWH) + (1-TR) (PWL)$	
	6330	$P12 = P8 + DP1213$	
	6340	$T12 = T6 + \frac{PWRCTB(U3)}{V5(CPA)}$	
	6350	$T13 = T12$	Define cooling blower exit stream
	6360	$V12 = V5$	
	6370	$P13 = P8$	
	6380	$V13 = V5$	

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	6390	$V8 = V10 + V2 + V5$	
	6400	$VW8 = VW7 + VW2 - VW1$	
	6410	$VC8 = VC7 - VC4$	
	6420	$PC8 = \frac{VC8}{V8} P8$	Calculate plenum exit conditions
	6430	$VN8 = VN7$	
	6440	$PN8 = \frac{VN8}{V8} P8$	
	6450	$VO8 = VO7 - \frac{1}{2}(VH3 - VH4)$	
	6460	$PW8 = \frac{VW8}{V8} P8$	
	6470	$DW8 = DEWT(PW8)$	
C-24	6480	$T8 = \frac{T11(V11) + T13(V13)}{V8} + \frac{T7(V10) + (\text{POWER } \frac{U3}{CPA})}{V8}$	
	6490	$RH8 = \frac{100 \times PW8}{PHTO(T8)}$	
	6500	IF (KBASE = 3) RETURN	
	6510	$AV7 = \frac{V7(T7 + 460)}{P7} \frac{760}{530}$	
	6520	$AV1 = V1 (AV7/V7)$	
	6530	$AV2 = \frac{V2(T2 + 460)}{P2} \times 1.434$	

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	6540	$AV11 = \frac{V11(T11 + 460)}{P11}$ (1.434)	
	6550	$AV9 = \frac{V9(T9 + 460)}{P9}$ (1.434)	
	6560	$AV3 = \frac{V3(T3 + 460)}{P3}$ (1.434)	
	6570	$AV4 = \frac{V4(T4 + 460)}{P4}$ (1.434)	
	6580	$AV5 = V5 AV7/V7$	Calculate actual stream flow rates
	6590	$AV6 = \frac{V6(T6 + 460)}{P6}$ (1.434)	
	6600	$V6A = V5A$	
	6610	$AV6A = \frac{V6A(T6A + 460)}{P6}$ (1.434)	
	6620	$AV12 = \frac{V12(T12 + 460)}{P12}$ (1.434)	
	6630	$AV13 = \frac{V13(T13 + 460)}{P13}$ (1.434)	
	6640	$AV10EX = \frac{V10(T7 + 460)}{P8}$ (1.434)	
	6650	$AV8 = \frac{V8(T8 + 460)}{P8}$ (1.434)	
	6690	$PWRTOT = PWRPC + PWREC + PWRCLB + PWRCTB + PWRDAU$	
	6700	$HTTOT = HEATLD + U3(PWRTOT + POWER)$	
	6710	$PWRWGT = PWOPEN(PWRTOT)$	Calculate equivalent weight penalty
	6720	$HTWGT = HTPEN(HTTOT)$	
	6730	$H2OWGT = H2OPEN(WPROD)$	

C-25

Table 2 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	6740	OXWGT = OXOPEN(OCON)	
	6750	EQWGT = PWRWGT + HTWGT + H ₂ OWGT + OXWGT + HRDWGT	
	6760	IF (KBASE = 4) RETURN	
	6770-7510	WRITE OUT ALL OUTPUTS	
	7520	RETURN	

TABLE 3 WATER VAPOR PRESSURE FUNCTION

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	7550	FUNCTION PHTO(TF)	The input parameter is the Fahrenheit dew point temperature. The output parameter is pH ₂ O, in millimeters of mercury.
	7560-7570		Initialize constants A-G.
	7580	TC=(TF-32) 1.8	Calculate Centigrade dew point temperature.
	7590	X = 374.11 - TC	Calculate the temperature span from the dew point to the critical temperature.
	7600	PHTO=10 ^(EE-$\frac{X}{TC+F} \times \frac{A+BX+CX^3}{1+DX}$)	Calculate water vapor pressure
	7610	RETURN	

C-27

TABLE 4 DEW POINT TEMPERATURE FUNCTION

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	7640	FUNCTION DEWT(P)	The input parameter P is the water vapor pressure in millimeters of mercury. The output parameter DEWT is the Fahrenheit dew point temperature
	7650	EXTERNAL ROOT, PHTO	Functions ROOT and PHTO are used by function DEWT
	7660	X=ALOG(P)	Calculate two trial values for the dew point temperature
	7670	TA=-2.4 + 20.25X + 1.522X ²	
	7680	TB=TA + 0.1	
C-28	4890	DEWT=ROOT(TA,TB,PHTO,P, 0.005, 0.005, 5)	Function ROOT will call function PHTO starting with dew points equal to TA and TB until the water vapor pressure is equal to P with temperature and vapor pressure tolerances of point .005 but not exceeding five trials.
	7700	RETURN	

TABLE 5 TRANSFER INDEX FUNCTION

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
C-29	7730	FUNCTION TICOR(PC,AF,CD,DEL)	Input parameters are CO ₂ partial pressure in millimeters of mercury, cathode air flow in Cfm/cell, current density in Amp/Ft ² , and module temperature - inlet cathode air dew point temperature. The output parameter is TICOR in Lb CO ₂ /Lb O ₂ .
	7740-7810		Initialize the correlation parameters in array S.
	7820	P=AMIN1(PC,10)	pCO ₂ should not exceed 10.
	7830	PA= PC ($\frac{AF}{44}$) $(1+0.84P)^{-0.84P}$	PA is the effective inlet pCO ₂ corrected for nonbaseline cathode air flow.
	7840	J= $\frac{CD}{5} - 1$	Calculate the J index which corresponds to current density.
	7850	IF(J < 1)J=1	For current densities less than 10 ASF, extrapolate from 15 and 10 ASF.
	7860	TI1= $\sum_{i=1}^5 S_{ij} PA^i$	Calculate TI at the current density just below the actual current density.
	7870	If (J < 7) BRANCH	Current density should not exceed 40 ASF.
	7880	TICOR = TI1	
	7900	J = J + 1	
	7910	TI2 = $\sum_{i=1}^5 S_{ij} PA^i$	
	7920	AII=J	Interpolate between the two current densities.

-continued-

Table 5 - continued



<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	7930	TERP = $\frac{CD}{5}$ - AII	
	7940	TICOR=TI2xTERP+TI1(1-TERP)	
	7950	TICOR=TICOR(1+0.03536(DEL-18.33))Correct TI for moisture conditions.	
	7960	RETURN	

TABLE 6 ROOT FUNCTION

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	7990	FUNCTION ROOT(X1,X2,YFCN,W,XTOL, YTOL,K)	Input parameters are the first and second trial root values, the function to be called which returns the function of X, the value of the function at the desired root, X tolerance, Y tolerance, and maximum trials. The output value, ROOT, is the value of X when the function equals W.
	8000-8010		Initialize common and external statements.
	8020	XA=X1	[Isolate X1 and X2.
	8030	XB=X2	
	8040	FA=YFCN(XA) - W	[Find the error values at XA and XB.
	8050	FB=YFCN(XB)-W	
	8060	BEGIN LOOP	
	8070	XN= $\frac{FA \cdot XB - FB \cdot XA}{FA - FB}$	Extrapolate from the previous two trial values.
	8080	FN=YFCN(XN)-W	Calculate the error at the next X value.
(1)	8090-8100	IF (FN < YTOL and XN-XB < XTOL) BRANCH	BRANCH when the X and Y values are within tolerance.
	8110-8130	IF(Kth TIME THRU LOOP) DUMP VARIABLES & PRINT MESSAGE "NONCONVERGENCE IN LOOP"	If the root has not been found within K trials, print a message.
	8140	XA=XB	[Drop the oldest trial value and add the new trial value.

-continued-

Table 6 - continued





<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	8150	XB=XN	
	8160	FA=FB	
	8170	FB=FN	
	8180	IF(<Kth TIME THRU LOOP) BRANCH	
	5260	ROOT=XN	The root of the function returned is the latest trial value.
	8190	RETURN	

TABLE 7 MODULE TEMPERATURE SUBROUTINE

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	8220	SUBROUTINE TDRIFT	Subroutine TDRIFT calculates the module temperature when the cooling air flow rate is specified. All inputs are through common storage. All outputs except P2 are also through common storage.
	8230-8280		Initialize type, common, and external statements.
	8290	ENTHPR=VI·CPA·T1+V3·CPH·T3	Calculate enthalpy entering the modules in the cathode air and inlet hydrogen streams.
	8300	T2HIGH= $\frac{\text{ENTHPR} + .99 \cdot \text{HEATLD}}{\text{V1} \cdot \text{CPA} + \text{V3} \cdot \text{CPH}}$	Calculate maximum possible module temperature. This is the temperature the module would rise to with no cooling air.
	8310	T2LOW= $\frac{\text{ENTHPR} + \text{V5A} \cdot \text{CPA} \cdot \text{T5} + \text{HEATLD}}{\text{V1} \cdot \text{CPA} + \text{V3} \cdot \text{CPA} + \text{V5A} \cdot \text{CPA}}$	Calculate the minimum module temperature which would occur with no heat transfer resistance.
	8320	T2=T2HIGH	Call subroutine ERT to determine values of the heat transfer coefficient and the cooling fin efficiency, neither of which depends upon module temperature but only upon cooling air flow rate which is constant when subroutine TDRIFT is called.
	8330	DUMMY=ERT (V5A/N)	
	8340	T2=ROOT(T2HIGH,T2LOW,ERT1,0,	Start with trial values T2HIGH and T2LOW and use function ERT1 to find the module temperature which yields a heat balance for the specified cooling air flow rate.
	8350	RETURN	

C-33

TABLE 8 HEAT BALANCE FUNCTION WITH VARIABLE MODULE TEMPERATURE

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	8380	FUNCTION ERT1(T)	The input parameter is the module temperature. The output parameter, ERT1, is the difference between the available module cooling air temperature drop and the required module cooling air temperature drop.
	8390-8430		Initialize type, common statements.
	8440	$E = 0.729 - 0.221nI + 0.008I + 0.005(T-78)$	Calculate module voltage and heat load at the given temperature.
	8450	$HEATLD=N \cdot I \cdot (1.25-E) \cdot 3.419$	
C-34	8460	$DHA=V1(CPA)(T-T1)$	Calculate the enthalpy change for the cathode air process hydrogen and cooling air flow, respectively, at the given module temperature.
	8470	$DHH=V3(CPH)(T-T3)$	
	8480	$DHC=HEATLD-DHA-DHH$	
	8490	$T6A=T5 + \frac{DHC}{V5A(CPA)}$	Calculate the outlet cooling air temperature from the inlet cooling air temperature and the enthalpy increase.
	8500	$DTREQ=DHC(0.376 + 3.876 \frac{BC \cdot ETA}{N})$	The required module cooling air temperature difference depends upon the cooling air enthalpy change x the resistance in the fin roots + the gas film resistance.
(1)	8510	IF($T6A < T$) BRANCH	If the cooling air temperature at the exit is less than the module temperature, then the log mean temperature difference can be calculated.

-continued-

Table 8 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	8520	ERT1 = -DTREQ	If it is not, then assume that the available temperature difference is zero and the error is equal to the required temperature difference.
	8530	RETURN	
①	8540	$DTAVA = \frac{T6A - T5}{\ln \frac{T - T5}{T - T6A}}$	The available temperature drop is the log mean of the module cooling air temperature difference at the inlet and the outlet of the cooling air passages.
	8550	ERT1 = DTAVA-DTREQ	
	8560	RETURN	

C-35

TABLE 9 HEAT BALANCE FUNCTION WITH VARIABLE COOLING AIR FLOW RATE

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	8590	FUNCTION ERT(V)	The input parameter is the cooling air flow rate, Cfm/cell. The output parameter ERT is the difference between the available and required module-cooling air temperature differences. Inputs taken from common storage include the inlet cooling air and cathode air temperature, the cooling air heat load, the cooling air specific heat, the number of active cells, and the module temperature. Outputs through common storage include the heat transfer coefficient, the fin efficiency, the outlet cooling air temperature, the available temperature difference, and the required temperature difference.
C-36	8600-8640		
	8650	IF ($V \leq 1$) HC = $1.97V^{0.3333}$	Calculate the heat transfer coefficient.
	8660	IF ($1 < V < 2.9883$) HC = $1.21 + 0.34V + 0.42V^2$	
	8670	IF ($2.9883 \leq V \leq 4$) HC = $2V$	
	8680	IF ($4 < V$) HC = $2.639016V^{0.8}$	
	8690	ETA = 1	Calculate the fin efficiency.
	8700	IF ($0.32194 < V \leq 24.72$) ETA = $1.0644 - 0.1135V^{0.5}$	
	8710	IF ($24.72 \leq V$) ETA = $2.486V^{-5}$	
	8720	T6A = T5 + $\frac{DHC}{V(CPA)N}$	

-continued-

Table 9 - continued

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	8730	$DTREQ = \frac{DHC}{N} (0.376 + \frac{3.876}{HC(ETA)})$	Calculate the required temperature difference from the cooling air heat load, resistance in the fins, and resistance in the stagnant air film.
	8740	IF ($T_{6A} < T_2$) BRANCH	Branch and calculate the log mean temperature difference only if the outlet cooling air temperature is less than the module temperature.
	8750	ERT = -DTREQ	There is no available temperature difference. The error ERT is minus the required temperature difference.
	8760	RETURN	
	8770	$DTAVA = \frac{T_{6A}-T_5}{\ln \frac{T_2-T_5}{T_2-T_{6A}}}$	Log mean module cooling air temperature difference.
	8780	ERT=DTAVA-DTREQ	
	8790	RETURN	

C-37

TABLE 10 RANGE TEST SUBROUTINE

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	8820	SUBROUTINE T(VARNAM,VAR,BOT, TOP,I)	Subroutine input parameters are the variable, value, the lower and upper limits, and the out-of-range counter. The subroutine simply prints a message containing the first four parameters when the variable is out-of-range.
	8830	COMMON IOUT	The message is printed on output device IOUT.
	8840	IF (BOT ≤ VAR ≤ TOP) BRANCH	The subroutine ends immediately if the variable is in range.
	8840	RETURN	
	8850	WRITE, VARNAM, VAR, BOT, TOP	
	8860	I=I+1	
	8870	RETURN	

TABLE 11 MODE B CURRENT AND CATHODE AIR FLOW SUBROUTINE

<u>Symbol</u>	<u>Program Line Numbers</u>	<u>Description</u>	<u>Comments</u>
	8910	SUBROUTINE BMODE	Subroutine BMODE takes the cabin pCO ₂ and calculates the current and the cathode air flow based on BK, the Mode B parameters.
	8920-8940		Initialize type and common statements.
	8950	I = BK(1)	Calculate current.
	8960	IF (PCO ≤ BK(2)) BRANCH	
	8970	I = BK(4)	
	8980	IF (PCO ≥ BK(3)) BRANCH	
	8990	I = BK(9) · PCO + BK(10)	
	9000	V1 = BK(5)	Calculate cathode air flow.
	9010	IF (PCO ≤ BK(6)) BRANCH	
	9020	V1 = BK(8)	
	9030	IF (PCO ≥ BK(7)) BRANCH	
	9040	V1 = BK(11) · PCO + BK(12)	
	9050	RETURN	

C-39

TABLE 12 CYCLIC PROGRAM LISTING

```

100$SAV
110C *** CYCLIC PROGRAM *** CS-6 MATH MODEL ***
120C
130$TTY,84
140$NDM
150 LOGICAL QFIN,QFOUT,QCO2GT,QSUBS,QPRINT
160 REAL N,I,HEAD(150),CGEN(200),HDG(150),AO(150),TAB(150),AVG(150)
170 INTEGER INDEX(150),TMAX(200)
180 COMMON IOUT,CPA,CPH,N,V3,T5,T3,T1,BK(12),
190&POPSA,POOPSA,TO,VOLUME,P8PSA,T7,V7,
200&DW7,P4PSA,T9,V9SL,DW9,PWPEN,HTPEN,H2OPEN,OXOPEN,NFLAG,
210&PC0,I,V1,HEATLD,DHC,DHA,DHH,DTREQ,DTAVA,E,
220&HC,ETA,T2,V5A,T6A,DELT1,V9MSL,V7M1,V5MIN,V5,
230&DUM(5),YA,YB,YC,SLOPEC,C02GEN,
240&V5INP,V10,COR34,DP34,P3,P3PSA,COR93,DP93,P9,P9PSA,
250&DP78,P7,P7PSA,DP12,P1,P2,CURDEN,DELT1E,PC1,TI,
260&OC ON,CTRANS,HCON,WPROD,VC4,PW9,PW3,VH3,VH4,PW1,
270&VW1,VW3,VWPROD,VW2,P00,P07,PN1,VN1,V01,VC1,
280&V02,VC2,V2,PW2,DW2,DDP1,DDP2,DPTDAV,DELT1P,T2P,
290&VC7,VW7,V07,VN7,RH7,FC1,FW1,PH3,FH3,EMOD,
300&POWER,TE,PC2,FC2,FW2,RH2,DW4,PW4,VW4,V4,
310&V4SL,VC4SL,VH4SL,FC4,FH4,F4,CHWRTO,HCVRTO,DP56,
320&P6,T6,PWRCTB,T11,DP1213,PWRCLB,P12,T12,V8,VW8,
330&VC8,PC8,VN8,PN8,V08,PW8,DW8,T8,RH8,AV1,
340&AV2,AV3,AV4,AV5,AV6,AV6A,AV7,AV8,AV9,AV10EX,
350&AV11,AV12,AV13,PWRTOT,HTTOT,PWRWGT,HTWGT,H20WGT,OXWGT,EWGT
360 EQUIVALENCE(AO(1),PC0)
370 DATA IOUT,NSTEPS,(TMAX(MN),CGEN(MN),MN=1,21)/1,21,
380&405,.3530, 420,.4118, 435,.4706, 450,.5295, 465,.5687, 480,.7060,
390&705,.7452, 720,.6079, 780,.5295, 840,.5687, 900,.6667, 1020,.7452,
400&1080,.6667, 1140,.5295, 1200,.5687, 1290,.6471, 1320,.6079,
410&1365,.5295, 1380,.4706, 1395,.4118, 1440,.3530/
420 DATA HEAD/
430&" PC0"," I"," V1"," HEATLD"," DHC",
440&" DHA"," DHH"," DTREQ"," DTAVA"," E",
450&" HC"," ETA"," T2"," V5A"," T6A",
460&" DELT1"," V9MSL"," V7M1"," V5MIN"," V5",
470&" DUM1"," DUM2"," DUM3"," DUM4"," DUM5",
480&" YA"," YB"," YC"," SLOPEC"," C02GEN",
490&" V5INP"," V10"," COR34"," DP34"," P3",
500&" P3PSA"," COR93"," DP93"," P9"," P9PSA",
510&" DP78"," P7"," P7PSA"," DP12"," P1",
520&" P2"," CURDEN"," DELT1E"," PC1"," TI",
530&" OC ON"," CTRANS"," HCON"," WPROD"," VC4",
540&" PW9"," PW3"," VH3"," VH4"," PW1",
550&" VW1"," VW3"," VWPROD"," VW2"," P00",
560&" P07"," PN1"," VN1"," V01"," VC1",
570&" V02"," VC2"," V2"," PW2"," DW2",
580&" DDP1"," DDP2"," DPTDAV"," DELT1P"," T2P",
590&" VC7"," VW7"," V07"," VN7"," RH7",

```

continued-

Table 12 - continued

```

600&" FC1"," FW1"," PH3"," FH3"," EMOD",
610&" POWER"," TE"," PC2"," FC2"," FW2",
620&" RH2"," DW4"," PW4"," VW4"," V4",
630&" V4SL"," VC4SL"," VH4SL"," FC4"," FH4",
640&" FW4"," F4"," CHWRTO"," HCVRTO"," DP56",
650&" P6"," T6"," PWRCTB"," T11"," DP1213",
660&" PWRCLB"," P12"," T12"," V8"," VW8",
670&" VC8"," PC8"," VN8"," PN8"," V08",
680&" PW8"," DW8"," T8"," RH8"," AV1",
690&" AV2"," AV3"," AV4"," AV5"," AV6",
700&" AV6A"," AV7"," AV8"," AV9"," AV10EX",
710&" AV11"," AV12"," AV13"," PWRTOT"," HTTOT",
720&" PWRWGT"," HTWGT"," H20WGT"," OXWGT"," EQWGT"/
730C
740C DETERMINE I/O DEVICES:
750C
760 PRINT,"FILE INPUT (T OR F)",;*
770 READ,QFIN
780 INP=50
790 IF(QFIN)INP=2
800 IF(QFIN)CALL OPENF(2,"MATHIN")
810 PRINT,"FILE OUTPUT (T OR F)",;*
820 READ,QFOUT
830 IF(.NOT.QFOUT)IOUT=66
840 GOT06
850 99 PRINT," END OF INPUT DATA FILE"
860 CALL EXIT
870C
880C IF OUTPUT IS TO FILE, OBTAIN FILE NAME:
890C
900 1IF(.NOT.QFOUT)GOT06
910 IF(.NOT.QFIN)PRINT,"FILE FOR OUTPUT",;*
920 READ(INP,48,END=99)FNAME
930 48 FORMAT(14A6)
940C
950C IF THE FILE NAME IS "SAME", KEEP FILE OPEN FOR MORE OUTPUT,
960C OTHERWISE ASSIGN THE NAME AND CLOSE THE FILE:
970C
980 IF(FNAME.NE."SAME")CALL CLOSEF(1,FNAME,?)
990C
1000C READ AND WRITE PROBLEM IDENTIFIER:
1010C
1020 GWRITE(IOUT;4)
1030 4 FORMAT(////)
1040 IF(.NOT.QFIN)PRINT,"PROBLEM IDENTIFIER:"
1050 READ(INP,48,END=99)(HDG(J),J=1,14)
1060 IF(QFIN)WRITE(IOUT;48)(HDG(J),J=1,14)
1070C
1080C INPUT AND OUTPUT NEW CO2 GENERATION TABLE IF DESIRED:
1090C

```

continued-

Table 12 - continued

```

1100 IF(.NOT.QFIN)PRINT,"NEW CO2 GENERATION TABLE(T OR F)",*
1110 READ(INP,,END=99)QCO2GT
1120 IF(QCO2GT)READ(INP,,END=99)NSTEPS,(TMAX(MN),CGEN(MN),MN=1,NSTEPS)
1130 IF(QCO2GT)WRITE(IOUT;100)NSTEPS,(TMAX(MN),CGEN(MN),MN=1,NSTEPS)
1140 100 FORMAT("// CO2 GENERATION RATE TABLE://" NUMBER OF STEPS=",I3//"
1150// ENDING      CO2//" TIME GENERATION//" MINUTES      LB/HR//"
1160&(F8.0,F11.4))
1170C
1180C INPUT FOR BASE, MODE B, NO. OF DAYS, SIZES OF TIME INTERVALS
1190C FOR INTEGRATION AND PRINTING:
1200C
1210 IF(.NOT.QFIN)PRINT,"INPUT DATA",*
1220 READ(INP,,END=99)POPSA,PC0,POOPSA,T0,VOLUME,P8PSA,T7,V7,DW7,P4PSA,T9,V9SL,DnS,
1230&N,I,DELT1,V1,PWPEN,HTPEN,H2OPEN,OXOPEN,KMODE,NFLAG,(BK(MN),MN=1,8),DAYS,DT,DPINT
1240C
1250C DETERMINE WHETHER BASE OUTPUT IS TO BE PRINTED AND
1260C INPUT THE SUBSCRIPTS OF THE DESIRED CYCLIC TABLE OUTPUT ITEMS:
1270C
1280 IF(.NOT.QFIN)PRINT,"PRINT BASE OUTPUT(T OR F)",*
1290 READ(INP,,END=99)QPRINT
1300 KBASE=4
1310 IF(QPRINT)KBASE=5
1320 IF(.NOT.QFIN)PRINT,"NEW CYCLIC OUTPUT SUBSCRIPTS(T OR F)",*
1330 READ(INP,,END=99)QSUBS
1340 IF(QSUBS)READ(INP,,END=99)NDEX,(INDEX(MN),MN=1,NDEX)
1350 IF(QFOUT)PRINT," START PROBLEM"
1360C
1370C CALC. SLOPES AND INTERCEPTS FOR MODE B CURRENT AND AIRFLOW CURVES:
1380C
1390 BK(9)=(BK(1)-BK(4))/(BK(2)-BK(3))
1400 BK(10)=BK(1)-BK(9)*BK(2)
1410 BK(11)=(BK(5)-BK(8))/(BK(6)-BK(7))
1420 BK(12)=BK(5)-BK(11)*BK(6)
1430C
1440C IF MODE B IS IN EFFECT, DETERMINE INITIAL VALUES OF I AND V1
1450C BY CALLING SUBROUTINE "BMODE":
1460C
1470 IF(KMODE.EQ.1)CALL BMODE
1480C
1490C INPUT DATA PLAYBACK:
1500C
1510 WRITE(IOUT;230)
1520 230FORMAT(" *****INPUT DATA*****")
1530 WRITE(IOUT;1017)
1540 1017FORMAT(" CABIN ATMOSPHERE:")
1550 944 FORMAT(5X,A6,G10.4,3(" ",A6,G10.4))
1560 WRITE(IOUT;944)"POPSA",POPSA,"PC0",PC0,"POOPSA",POOPSA,"TO ",T0,"VOLUME",VOLUME
1570 WRITE(IOUT;1032)
1580 1032FORMAT(" PROCESS AIR OUTLET/INLET:")
1590 WRITE(IOUT;944)"P8PSA",P8PSA,"T7 ",T7,"V7 ",V7,"DW7",DW7

```

Table 12 - continued

```

1600 WRITE(IOUT;1031)
1610 1031FORMAT(" H2 OUTLET/INLET:")
1620 WRITE(IOUT;944)"P4PSA",P4PSA,"T9 ",T9,"V9SL",V9SL,"DW9",DW9
1630 WRITE(IOUT;1020)
1640 1020FORMAT(" MODULES:")
1650 WRITE(IOUT;944)"N ",N,"I ",I,"DELT1",DELT1,"V1 ",V1
1660 WRITE(IOUT;1021)
1670 1021FORMAT(" PENALTY WEIGHT FACTORS:")
1680 WRITE(IOUT;944)"PWPEN",PWPEN,"HTPEN",HTPEN,"H2OPEN",H2OPEN,
1690 &"OXOPEN",OXOPEN
1700 WRITE(IOUT;1022)
1710 1022 FORMAT(" CONTROL:")
1720 WRITE(IOUT;944)"KMODE",KMODE,"NFLAG",NFLAG
1730 &,"IMIN",BK(1),"PCIMIN",BK(2),"PCIMAX",BK(3),"IMAX",BK(4),
1740 &,"VMIN",BK(5),"PCVMIN",BK(6),"PCVMAX",BK(7),"VMAX",BK(8)
1750 &,"DAYS",DAYS,"DT ",DT,"DPRINT",DPRINT
1760 WRITE(IOUT;4)
1770 WRITE(IOUT;220)
1780 220 FORMAT(" *****RESULTS*****")
1790C
1800C   CHECK INPUTS:
1810C
1820 IR=0
1830 CALLT("POPSA ",POPSA,13.7,15.7,IR)
1840 CALLT("PC0",PC0,.0001,10.,IR)
1850 CALLT("POOPSA",POOPSA,2.,4.,IR)
1860 CALLT("TO ",TO,44.,80.,IR)
1870 CALLT("VOLUME",VOLUME,100.,100000.,IR)
1880 CALLT("P8PSA ",P8PSA,13.7,15.7,IR)
1890 CALLT("T7 ",T7,44.,80.,IR)
1900 CALLT("V7 ",V7,0.,600.,IR)
1910 CALLT("DW7 ",DW7,41.,70.,IR)
1920 CALLT("P4PSA ",P4PSA,14.8,21.2,IR)
1930 CALLT("T9 ",T9,65.,75.,IR)
1940 CALLT("V9SL ",V9SL,0.,18.,IR)
1950 CALLT("DW9 ",DW9,10.,75.,IR)
1960 CALLT("N ",N,90.,96.,IR)
1970 CALLT("I ",I,2.44,9.76,IR)
1980 CALLT("DELT1 ",DELT1,10.,25.,IR)
1990 CALLT("V1 ",V1,5.,76.8,IR)
2000 CALLT("PWPEN ",PWPEN,0.,2.,IR)
2010 CALLT("HTPEN ",HTPEN,0.,2.,IR)
2020 CALLT("H2OPEN",H2OPEN,0.,500.,IR)
2030 CALLT("OXOPEN ",OXOPEN,0.,3000.,IR)
2040 FLAG=NFLAG
2050 CALLT("NFLAG ",FLAG,0.,1.,IR)
2060 AMODE=KMODE
2070 CALLT("KMODE ",AMODE,0.,1.,IR)
2080 CALLT("IMIN",BK(1),2.44,9.76,IR)
2090 CALLT("PCIMIN",BK(2),.0001,10.,IR)

```

continued-

Table 12 - continued

```

2100 CALLT("PCIMAX",BK(3),.0001,10.,IR)
2110 CALLT("IMAX",BK(4),2.44,9.76,IR)
2120 CALLT("VMAX",BK(5),5.,76.8,IR)
2130 CALLT("PCVMIN",BK(6),.0001,10.,IR)
2140 CALLT("PCVMAX",BK(7),.0001,10.,IR)
2150 CALLT("VMAX",BK(8),5.,76.8,IR)
2160 CALLT("DAYS",DAYS,0.,10.,IR)
2170 CALLT("DT ",DT,1.,15.,IR)
2180 CALLT("DPRINT",DPRINT,1.,100.,IR)
2190 IF(IR.GT.0)GOTO1
2200C
2210C PRINT FULL BASE PROGRAM OUTPUT IF DESIRED:
2220C
2230 CALL BASE(KMODE,KBASE,1,KERROR)
2240 IF(KERROR.NE.0 .OR. DAYS.EQ.0.)GOTO1
2250C
2260C INITIALIZE CONSTANTS:
2270C
2280 NDT=DT
2290 NDAY=0
2300 MINCYC=TMAX(NSTEPS)
2310 NDAYS=DAYS
2320 NPRINT=DPRINT
2330 US=(T0+460.)*386.72*760./(530.*VOLUME*60.*44.01)
2340 MAXDEX=0
2350 DO 110 MN=1,NDEX
2360 IN=INDEX(MN)
2370 HDG(MN)=HEAD(IN)
2380 110 IF(IN.GT.MAXDEX)MAXDEX=IN
2390 KBASE=1
2400 IF(MAXDEX.GT.52)KBASE=2
2410 IF(MAXDEX.GT.78)KBASE=3
2420 IF(MAXDEX.GT.129)KBASE=4
2430C
2440C START A NEW CYCLE (DAY):
2450C
2460 ?800CONTINUE
2470 OPRINT=.TRUE.
2480 NT=0
2490 DO ?25 MN=1,NDEX
2500 ?25AVG(MN)=0.
2510 NDAY=NDAY+1
2520 PCOI=PCO
2530 IGEN=1
2540 COGEN=CGEN(1)
2550C
2560C PRINT CYCLIC TABLE HEADINGS:
2570C
2580 IF(QFOUT)PRINT,NDAY
2590 WRITE(IOUT;120)NDAY,(HDG(MN),MN=1,NDEX)

```

continued-

Table 12 - continued

```

2600 120FORMAT( ///* *****DAY*,I3,* *****// TIME/(7(5X,A6)))
2610 WRITE(IOUT;121)
2620 121FORMAT( /* ********** */
2630 WRITE(IOUT;135)0,0
2640 CALL BASE(KMODE,KBASE,1,KERROR)
2650 IF(KERROR.NE.0)GOTO1
2660C
2670C PRINT A LINE IN THE TABLE:
2680C
2690 7900CONTINUE
2700 IF(.NOT.QPRINT)GOT08000
2710 DO 130 MN=1,NDEX
2720 IN=INDEX(MN)
2730 130 TAB(MN)=A0(IN)
2740 WRITE(IOUT;140)(TAB(MN),MN=1,NDEX)
2750 140FORMAT(7(G11.4))
2760C
2770C START A NEW CYCLE AT THE END OF THE CURRENT CYCLE
2780C UNLESS EITHER STEADY STATE HAS BEEN REACHED
2790C OR MAXIMUM NUMBER OF CYCLES HAS BEEN REACHED
2800C
2810 8000CONTINUE
2820 IF(NT.LT.MINCYC)GOT08100
2830 DO 726MN=1,NDEX
2840 726AVG(MN)=AVG(MN)*DT/MINCYC
2850 WRITE(IOUT;122)
2860 122FORMAT(" AVERAGES:")
2870 WRITE(IOUT;140)(AVG(MN),MN=1,NDEX)
2880 IF(NDAY.GE.NDAYS .OR. ABS((PC0-PC0I)/PC0).LE..0005)GOT01
2890 GOT07800
2900C
2910C INCREMENT TIME AND UPDATE CO2 GENERATION RATE
2920C
2930 8100CONTINUE
2940 NT=NT+NDT
2950 QPRINT=MOD(NT,NPRINT).EQ.0
2960 IF(NT.GT.TMAX(IGEN))IGEN=IGEN+1
2970 CO2GEN=CGEN(IGEN)
2980C
2990C WRITE THE TIME:
3000C
3010 IF(.NOT.QPRINT)GOT08200
3020 NHRS=NT/60
3030 NMIN=NT-NHRS*60
3040 WRITE(IOUT;135)NHRS,NMIN
3050 135FORMAT(1X,I2,":",I2)
3060C
3070C UPDATE CABIN CO2 PARTIAL PRESSURE
3080C
3090 8200 CONTINUE

```

continued-

Table 12 - continued

```

3100 XA=PC0
3110 SLOPEA=U5*(C02GEN-CTRANS)
3120 SLOPE=SLOPEA
3130 PCN=PC0+SLOPE*DT
3140 YA=XA-PCN
3150 XB=PCN
3160 PC0=PCN
3170 CALL BASE(KMODE,0,0,KERROR)
3180 IF(KERROR.NE.0)GOTO1
3190 SLOPEB=U5*(C02GEN-CTRANS)
3200 SLOPE=.5*(SLOPEA+SLOPEB)
3210 PCN=XA+SLOPE*DT
3220 YB=XB-PCN
3230 PC0=(YA*XB-YB*XA)/(YA-YB)
3240 KPRINT=0
3250 IF(QPRINT)KPRINT=1
3260C
3270C CALL BASE TO CALC. SYSTEM PARAMETERS AT NEW CABIN PC02
3280C
3290 CALL BASE(KMODE,KBASE,KPRINT,KERROR)
3300 IF(KERROR.NE.0)GOTO1
3310 DO 728MN=1,NDEX
3320 IN=INDEX(MN)
3330 728AVG(MN)=AVG(MN)+AO(IN)
3340C CHECK ACCURACY OF INTEGRATION:
3350C
3360 SLOPEC=U5*(C02GEN-CTRANS)
3370 SLOPE=.5*(SLOPEA+SLOPEC)
3380 PCN=XA+SLOPE*DT
3390 YC=PC0-PCN
3400C YC IS THE INACCURACY IN PC0
3410 GOTO7900
3420 END
3430C
3440 SUBROUTINE BASE(KMODE,KBASE,KPRINT,KERROR)
3450C
3460C     *** CS-6 MATH MODEL BASE PROGRAM ***
3470C
3480 REALN,I
3490 COMMONIOUT,CPA,CPH,N,V3,T5,T3,T1,BK(12),
3500&POPSA,POOPSA,TO,VOLUME,P8PSA,T7,V7,
3510&DW7,P4PSA,T9,V9SL,DW9,PWPEN,HTPEN,H2OPEN,OXOPEN,NFLAG,
3520&PC0,I,V1,HEATLD,DHC,DHA,DHH,DTREQ,DTAVA,E,
3530&HC,ETA,T2,V5A,T6A,DELT1,V9MSL,V7M1,V5MIN,V5,
3540&DUM(5),YA,YB,YC,SLOPEC,C02GEN,
3550&V5INP,V10,COR34,DP34,P3,P3PSA,COR93,DP93,P9,P9PSA,
3560&DP78,P7,P7PSA,DP12,P1,P2,CURDEN,DELT1E,PC1,TI,
3570&OC ON,CTRANS,HCON,WPROD,VC4,PW9,PW3,VH3,VH4,PW1,
3580&VW1,VW3,VWPROD,VW2,P00,P07,PN1,VN1,VO1,VC1,
3590&V02,VC2,V2,PW2,DW2,DDP1,DDP2,DPTDAV,DELT1P,T2P,

```

Table 12 - continued

3600&VC7,VW7,V07,VN7,RH7,FC1,FW1,PH3,FH3,EMOD,
 3610&POWER,TE,PC2,FC2,FW2,RH2,DW4,PW4,VW4,V4,
 3620&V4SL,VC4SL,VH4SL,FC4,FH4,FW4,F4,CHWRTO,HCVRTO,DP56,
 3630&P6,T6,PWRCTB,T11,DP1213,PWRCLB,P12,T12,V8,V88,
 3640&VC8,PC8,VN8,PN8,V08,PW8,DW8,T8,RH8,AV1,
 3650&AV2,AV3,AV4,AV5,AV6,AV6A,AV7,AV8,AV9,AV10EX,
 3660&AV11,AV12,AV13,PWRTOT,HTTOT,PWRWGT,HTWGT,H2OWGT,OXWGT,EQWGT
 3670 EXTERNAL PHTO,DEWT,TICOR,ROOT,TDRIFT,ERT1,ERT,BMODE
 3680 DATA CPA,CPH/1.0765,1.0666/
 3690&,U1,U2,U3,J4/51.7007,386.7,3.419,28.32/
 3700&,C782,C562,C561,C12132/2.25E-5,1.303E-5,.0101,8.6118E-4/
 3710&,C5132,C5131,QA/B.742E-4,.0101,8.517E-4/
 3720&,HRDWGT,PWRPC,PWRE, PWRDAU/817.9,136.,45.,100./
 3730 KERROR=0
 3740 IF(KMODE+KBASE.EQ.0) GOTO 7700
 3750 IF(KMODE.EQ.1) CALL BMODE
 3760C
 3770C CHECK FOR SUFFICIENT H2:
 3780C
 3790 V9MSL=1.3*N*I*7.508E-3
 3800 IF(V9SL.GE.V9MSL) GOTO1213
 3810 WRITE(IOUT;213)V9MSL
 3820 213 FORMAT(" INSUFFICIENT H2.",G10.4," SLPM IS REQUIRED")
 3830 KERROR=1
 3840 RETURN
 3850 1213 CONTINUE
 3860C
 3870C CHECK CATHODE AIR CAPACITY:
 3880C
 3890 IF(V1.LE.70) GOTO9001
 3900 V1=70.
 3910 WRITE(IOUT;9000)
 3920 9000FORMAT(" V1 HAS BEEN CHANGED TO 70 SCFM, BLOWER CAPACITY.")
 3930 9001 CONTINUE
 3940C
 3950C CALC. COOLING AIR FLOW WITH COOLING BLOWERS OFF:
 3960C
 3970 V7M1=V7-V1
 3980 QB=C5131+2.*C782*V7M1
 3990 QC=C782*V7M1**2
 4000 V5MIN=(-QB+SQRT(QB*QB+4.*QA*QC))/(2.*QA)
 4010C
 4020C CALC. COOLING AIR HEAT LOAD, ETC. FOR INPUT MODULE TEMP:
 4030C
 4040 DW1=DW7
 4050 T2=DW1+DELT1
 4060 T2INP=T2
 4070 E=-.729-.22*ALOG(I)+.008*I+.005*(T2-78.)
 4080 HEATLD=N*I*(1.25-E)*U3
 4090 T1=T7

continued-

Table 12 - continued

```
4100 T3=T9
4110 V3=V9SL/U4
4120 T5=T1
4130 DHA=V1*CPA*(T2-T1)
4140 DHH=V3*CPH*(T2-T3)
4150 DHC=HEATLD-DHA-DHH
4160C
4170C     CHECK NEED FOR COOLING:
4180C
4190 IF(DHC.GT.0)GOT0898
4200C
4210C     CALC. NEW MODULE TEMP IF COOLING BLOWERS ARE OFF:
4220C
4230 888 CONTINUE
4240 V5=V5MIN
4250 V5A=N*V5MIN/96.
4260 CALL TDRIIFT
4270 DROP=T2INP-T2
4280 IF(DROP.LE.3.)GOT0766
4290 IF(KPRINT.EQ.0)GOT0766
4300 WRITE(IOUT;469)DROP,T2INP,T2
4310 469 FORMAT(" COOLING BLOWERS ARE OFF."// " MODULE TEMPERATURE FALLS",
4320&F6.2,"F BELOW THE DESIRED",F6.2,"F TO",F6.2,"F.")
4330 GOT0766
4340C
4350C     CHECK THAT MODULE TEMP IS HIGH ENOUGH TO TRANSFER HEAT
4360C     AT LEAST TO COOLING FIN ROOTS:
4370C
4380 898 CONTINUE
4390 IF(T2-T5.GE..376*DHC/N)GOT0765
4400C
4410C     CALC. NEW MODULE TEMP IF COOLING BLOWERS ARE ON FULL:
4420C
4430 886 CONTINUE
4440 V5=440.
4450 V5A=V5*N/96.
4460 CALL TDRIIFT
4470 RISE=T2-T2INP
4480 IF(RISE.LE.3)GOT0766
4490 IF(KPRINT.EQ.0)GOT0766
4500 WRITE(IOUT;479)RISE,T2INP,T2
4510 479 FORMAT(" COOLING BLOWERS ARE ON FULL."// " MODULE TEMPERATURE RISES",
4520&F6.2,"F ABOVE THE DESIRED",F6.2,"F TO",F6.2,"F.")
4530 GOT0766
4540C
4550C     CALC. COOLING AIR FLOW FOR INPUT MODULE TEMPERATURE:
4560C
4570 765 CONTINUE
4580 VA=1.01*DHC/(CPA*N*(T2-T5))
4590 VB=2.*VA
```

continued-

Table 12 - continued

```

4600 V5=N*ROOT(VA,VB,ERT,0.,.005,.001,20)
4610 V5=96.*V5A/N
4620 V5INP=V5
4630C
4640C ARE COOLING BLOWERS OUT OF RANGE:
4650C
4660 IF(V5.LT.V5MIN)GOT0888
4670 IF(V5.GT.440.)GOT0886
4680C
4690C MODULE HEAT BALANCE IS MAINTAINED WITH COOLING BLOWERS IN RANGE:
4700C
4710 766 CONTINUE
4720 V10=V7-V1-V5
4730C
4740C CHECK PLENUM BYPASS FLOW:
4750C
4760 IF(V10.GE..05*V7)GOT0244
4770 IF(KPRINT.EQ.0)GOT0244
4780 WRITE(LOUT;242)
4790 WRITE(LOUT;944)"V10",V10
4800 242FORMAT(" INSUFFICIENT INLET PROCESS AIR TO ",
4810;"PREVENT BACKMIXING THROUGH PLENUM BYPASS.")
4820 KERROR=2
4830 RETURN
4840C
4850C CALC. STREAM PARAMETERS REQUIRED FOR MOISTURE BALANCE CHECKS:
4860C
4870 244 CONTINUE
4880 IF(KBASE.EQ.0)GOT07107
4890 COR34=(14.1/P4PSA)**.8
4900 P4=P4PSA*U1
4910 V3SL=V9SL
4920 DP34=.3822*COR34*V3SL
4930 IF(V3SL.GT.22.)DP34=COR34*(8.3183+.4187*(V3SL-21.5801)**1.75)
4940 P3=P4+DP34
4950 P3PSA=P3/U1
4960 COR93=(14.1/P3PSA)**.8
4970 DP93=COR93*10.64*V3SL
4980 IF(V3SL.GT.6.2)DP93=COR93*(36.14*V3SL-196.25+EXP(7.75-.6537*V3SL))
4990 P9=P3+DP93
5000 P9PSA=P9/U1
5010 DP78=0782*V10*V10
5020 P8=P8PSA*U1
5030 P7=P8+DP78
5040 P7PSA=P7/U1
5050 DP12=V1*(.001903*V1+.04877)
5060 P1=P7
5070 P2=P1-DP12
5080 T107CURDEN=I/.244
5090 DELT1E=T2-DW1

```

continued-

Table 12 - continued

```

5100 7700 CONTINUE
5110 PC1=PC0*P7PSA/POPSA
5120 TI=TICOR(PC1,V1/96.,CURDEN,DELT1E)
5130 OC0N=6.5803E-4*N*I
5140 CTRANS=TI*OC0N
5150 IF(KBASE.LE.1)RETURN
5160 HCON=OC0N*2.016/16.
5170 WPROD=OC0N+HCON
5180 VC4=CTRANS*U2/(44.01*60.)
5190 PW9=PHT0(DW9)
5200 PW3=P3*PW9/P9
5210 VH3=V3*(1.-PW3/P3)
5220 VH4=VH3-HCON*U2/(2.016*60.)
5230C TRIAL VALUE OF H2+CO2 OUTLET WATER VAPOR PRESSURE:
5240 PW4=PHT0(T2-6.)
5250 VW4=PW4*(VC4+VH4)/(P4-PW4)
5260 DW1=DW7
5270 PW1=PHT0(DW1)
5280 VW1=V1*PW1/P1
5290 VW3=V3-VH3
5300 VWPROD=WPROD*U2/(18.01*60.)
5310 VW2=VW1+VW3-VW4+VWPROD
5320 P00=PO0PSA*U1
5330 P07=P00*P7PSA/POPSA
5340 P01=P07
5350 PN1=P1-P01-PW1-PC1
5360 VN1=V1*PN1/P1
5370 VO1=V1*P01/P1
5380 VC1=V1*PC1/P1
5390 VN2=VN1
5400 V02=VO1-OC0N*U2/(32.*60.)
5410 VC2=VC1-VC4
5420 V2=V02+VN2+VW2+VC2
5430 PW2=VW2*P2/V2
5440 DW2=DEWT(PW2)
5450C CHECK MODULE MOISTURE BALANCE:
5470C
5480 DDP1=T1-DW1
5490 DDP2=T2-DW2
5500 IF(ABS(DDP1-11.25).LE.1.75 .AND.ABS(DDP2-11.25).LE.1.75)GOTO30
5510 IF(DDP1.LT.4.)GOTO1210
5520 IF(DDP1.GT.14.)GOTO1210
5530 IF(DDP2.LT.7.)GOTO1211
5540 IF(DDP2.GT.19.)GOTO1211
5550 DPTDAV=.5*(DDP1+DDP2)
5560 IF(ABS(DPTDAV-11.).LE.1.5 .AND. (DDP2.GE.13. .OR. DPTDAV.GE.10.))GOTO30
5570 IF(KPRINT.EQ.1)WRITE(IOUT;654)
5580 654FORMAT(" AVERAGE CATHODE AIR DEWPOINT DEPRESSION OUT OF RANGE.")
5590 28 IF(KPRINT.EQ.1)WRITE(IOUT;543)

```

continued-

Table 12 - continued

```

5600 543FORMAT(" ELECTROLYTE MOISTURE BALANCE IS NOT MAINTAINED.")
5610 IF(NFLAG.EQ.0)GOTO30
5620 KERROR=3
5630 RETURN
5640 1210 IF(KPRINT.EQ.1)WRITE(IOUT;432)
5650 432FORMAT(" INLET CATHODE AIR DEWPOINT DEPRESSION OUT OF RANGE.")
5660 GOTO28
5670 1211 IF(KPRINT.EQ.1)WRITE(IOUT;321)
5680 321FORMAT(" OUTLET CATHODE AIR DEWPOINT DEPRESSION OUT OF RANGE.")
5690 GOTO28
5700C
5710C COMPLETE ALL STREAM DEFINITIONS:
5720C
5730 30 CONTINUE
5740 IF(KBASE.EQ.2)RETURN
5750 DELT1P=22.-T1+DW2
5760 T2P=DW1+DELT1P
5770 PW7=PW1
5780 PN7=PN1
5790 PC7=PC1
5800 VC7=PC7*V7/P7
5810 VW7=PW7*V7/P7
5820 PC7=P01
5830 V07=P07*V7/P7
5840 VN7=PN7*V7/P7
5850 RH7=100.*PW7/PHTO(T7)
5860 FC1=VC1*44.01*60./U2
5870 FW1=VW1*18.01*60./U2
5880 RH1=RH7
5890 PH3=P3-PW3
5900 FH3=VH3*2.016*60./U2
5910 EMOD=16.*E
5920 POWER=N*I*E
5930 TE=TI/.0275
5940 PC2=VC2*P2/V2
5950 FC2=FC1-CTRANS
5960 FW2=VW2*18.01*60./U2
5970 RH2=100.*PW2/PHTO(T2)
5980 T4=T2
5990 V9=V3
6000 DW4=.77*(DW1+DW2)/2. + .23*T2
6010 PW4=PHTO(DW4)
6020 VW4=PW4*(VH4+VC4)/(P4-PW4)
6030 V4=VH4+VC4+VW4
6040 V4SL=V4*U4
6050 VC4SL=VC4*U4
6060 VH4SL=VH4*U4
6070 FC4=CTRANS
6080 FH4=VH4*2.016*60./U2
6090 FW4=VW4*18.01*60./U2

```

Life Systems, Inc.

Table 12 - continued

```
6100 F4=FC4+FH4+FW4
6110 CHWRTO=FC4/FH4
6120 HCVRTO=VH4/VC4
6130 P5=P7
6140 DP56=V5*( V5*C562+C561)
6150 P6=P5-DP56
6160 T6=(V5A*T6A+( V5-V5A)*T5)/V5
6170 IF(V1.LE.62.)PWRCTB=2.8*V1+153.8
6180 IF(V1.GT.62. .AND. V1.LE.65.)PWRCTB=40.*V1-2150.
6190 IF(V1.GT.65.)PWRCTB=-34.*V1+2660.
6200 T11=T2+PWRCTB*U3/( V1*CPA)
6210 V11=V2
6220 P11=P8
6230 PWRCLB=0.
6240 DP1213=C12132*V5*V5
6250 IF(V5.LT.1.01*V5MIN)GOTO14
6260 DP1213=C12132*V5MIN*V5MIN
6270 TR=(DP78/1.869+.05)/1.3
6280 TR=TR**(.128+.102*DP78/1.869)
6290 PWH=410.-.00396*( V5-368)**2
6300 PWL=410.-.00178*( V5-306.)**2
6310 PWRCLB=TR#PWH+(1.-TR)*PWL
6320 14CONTINUE
6330 P12=P8+DP1213
6340 T12=T6+PWRCLB*U3/( V5*CPA)
6350 T13=T12
6360 V12=V5
6370 P13=P8
6380 V13=V5
6390 V8=V10+V2+V5
6400 VW8=VW7+VW2-VW1
6410 VC8=VC7-VC4
6420 PC8=VC8*P8/V8
6430 VN8=VN7
6440 PN8=VN8*P8/V8
6450 VO8=VO7-.5*( VH3-VH4)
6460 PW8=P8*VW8/V8
6470 DW8=DEWT(PW8)
6480 T8=( T11*V11+T13*V13+T7*V10+POWER*U3/CPA)/V8
6490 RH8=100.*PW8/PHTO(T8)
6500 IF(KBASE.EQ.3)RETURN
6510 AV7=V7*( T7+460.)*1.434/P7
6520 AV1=V1*AV7/V7
6530 AV2=V2*( T2+460.)*1.434/P2
6540 AV11=V11*( T11+460.)*1.434/P11
6550 AV9=V9*( T9+460.)*1.434/P9
6560 AV3=V3*( T3+460.)*1.434/P3
6570 AV4=V4*( T4+460.)*1.434/P4
6580 AV5=V5*AV7/V7
6590 AV6=V5*( T6+460.)*1.434/P6
```

Table 12 - continued

```

6600 V6A=V5A
6610 AV6A=V6A*(T6A+460.)*1.434/P6
6620 AV12=V12*(T12+460.)*1.434/P12
6630 AV13=V13*(T13+460.)*1.434/P13
6640 AV10EX=V10*(T7+460.)*1.434/P8
6650 AV8=V8*(T8+460.)*1.434/P8
6660C
6670C EQUIVALENT WEIGHT CALCULATIONS:
6680C
6690 PWRTOT=PWRPC+PWREC+PWRCLB+PWRCTB+PWRDAU
6700 HTTOT=HEATLD+U3*(PWRTOT+POWER)
6710 PWRWGT=PWPEN*PWRTOT
6720 HTWGT=HTOPEN*HTTOT
6730 H2OWGT=H2OPEN*WPROD
6740 OXWGT=OXOPEN*OCON
6750 EQWGT=PWRWGT+HTWGT+H2OWGT+OXWGT+HRDWGT
6760 IF(KBASE.EQ.4)RETURN
6770C
6780C
6790C MAJOR OUTPUT STATEMENTS
6800C
6810 WRITE(IOUT;456)DELT1P,T2P,DW1,DELT1P
6820 456 FORMAT(" PREFERRED VALUE OF DELT1 IS",F6.2,
6830&" UNDER THESE CONDITIONS"/" SO THAT",F6.2,
6840&" = T2 = DW1 + DELT1 =",F6.2," +",F6.2,".")
6850C
6860 944FORMAT(5X,A6,G10.4,3(" ",A6,G10.4))
6870C
6880 WRITE(IOUT;1020)
6890 1020 FORMAT(" MODULES:")
6900 WRITE(IOUT;944)"TI ",TI,"TE ",TE,"E ",E,"EMOD",EMOD,
6910&"CTRANS",CTRANS,"OCON",OCON,"HCON",HCON,"WPROD",WPROD,
6920&"CURDEN",CURDEN,"HEATLD",HEATLD,"POWER",POWER
6930C
6940 WRITE(IOUT;1014)
6950 1014FORMAT(" CATHODE AIR INLET:")
6960 WRITE(IOUT;944)"P1 ",P1,"PC1",PC1,
6970&"PW1",PW1,"FC1",FC1,"FW1",FW1,"VC1",VC1,"VW1",VW1,
6980&"V01",V01,"VN1",VN1,"T1 ",T1,"DW1",DW1,"RH1",RH1
6990C
7000 WRITE(IOUT;1024)
7010 1024FORMAT(" CATHODE AIR OUTLET:")
7020 WRITE(IOUT;944)"P2 ",P2,"DP12",DP12,"PC2",PC2,
7030&"PW2",PW2,"V2 ",V2,"VC2",VC2,"VW2",VW2,
7040&"V02",V02,"VN2",VN2,"FC2",FC2,"FW2",FW2,"T2 ",T2,"DW2",DW2,"RH2",RH2
7050&,"P11",P11,"V11",V11,"T11",T11
7060C
7070 WRITE(IOUT;1010)
7080 1010FORMAT(" PROCESS AIR INLET:")
7090 WRITE(IOUT;944)"P7 ",P7,"PW7",PW7,"PN7",PN7,"VC7",VC7,"VW7",VW7,"V07",V07,

```

Table 12 - continued

```

?100&"VN7",VN7,"DW7",DW7,"RH7",RH7
?110C
?120 WRITE(IOUT;1015)
?130 1015FORMAT(" PROCESS AIR OUTLET:")
?140 WRITE(IOUT;944)"P8 ",P8,"PC8",PC8,"V10",V10,"DP78",DP78,
?150&"V8 ",V8,"VW8",VW8,"VC8",VC8,"V08",V08,"PW8",PW8,"T8 ",T8,
?160&"DW8",DW8,"RH8",RH8
?170C
?180 WRITE(IOUT;1019)
?190 1019FORMAT(" H2 INLET:")
?200 WRITE(IOUT;944)"P9 ",P9,"PW9",PW9,"DP93",DP93,"P3 ",P3
?210&,"PW3",PW3,"PH3",PH3,"V3 ",V3,"VH3",VH3,"VW3",VW3,"FH3",FH3,"V9MSL",V9MSL
?220C
?230 WRITE(IOUT;1013)
?240 1013FORMAT(" H2 OUTLET:")
?250 WRITE(IOUT;944)"P4 ",P4,"DP34",DP34,"PW4",PW4,"V4 ",V4,"VC4",VC4,
?260&"VH4",VH4,"VW4",VW4,"V4SL",V4SL,"VC4SL",VC4SL,"VH4SL",VH4SL,"F4 ",F4,
?270&"FC4",FC4,"FH4",FH4,"FW4",FW4,"DW4",DW4,"CHWRTO",CHWRTO,"HCVRTO",HCVRTO
?280C
?290 WRITE(IOUT;1023)
?300 1023FORMAT(" HEAT BALANCE, MODULES:")
?310 WRITE(IOUT;944)"HEATLD",HEATLD,"DHA",DHA,"DHH",DHH,"DHC",DHC
?320C
?330 WRITE(IOUT;1012)
?340 1012FORMAT(" COOLING AIR:")
?350 WRITE(IOUT;944)"P5 ",P5,"DP56",DP56,"P6 ",P6
?360&,"V5 ",V5,"T5 ",T5,"T6 ",T6,"HC ",HC,"ETA",ETA
?370&,"V5A",V5A,"T6A",T6A
?380&,"P12",P12,"V12",V12,"T12",T12,"DP1213",DP1213,"V5MIN",V5MIN
?390C
?400 WRITE(IOUT;1041)
?410 1041FORMAT(" ACTUAL VOLUMETRIC FLOW RATES:")
?420 WRITE(IOUT;944)"AV1",AV1,"AV2",AV2,"AV3",AV3,"AV4",AV4,"AV5",AV5,
?430&"AV6",AV6,"AV6A",AV6A,"AV7",AV7,"AV8",AV8,"AV9",AV9,
?440&"AV10EX",AV10EX,"AV11",AV11,"AV12",AV12,"AV13",AV13
?450C
?460 WRITE(IOUT;1016)
?470 1016FORMAT(" EQUIVALENT WEIGHT:")
?480 WRITE(IOUT;944)"PWRCLB",PWRCLB,"PWRCTB",PWRCTB,"PWRPC",PWRPC,
?490&"PWREC",PWREC,"PWRDAU",PWRDAU,"PWRTOT",PWRTOT,"HTTOT",HTTOT,
?500&"PWRWGT",PWRWGT,"HTWGT",HTWGT,"H20WGT",H20WGT,"OXWGT",OXWGT,
?510&"HRDWGT",HRDWGT,"EQWGT",EQWGT
?520 RETURN
?530 END
?540C
?550 FUNCTIONPH TO(TF)
?560 DATA A,B,C,D,EE,F,G/3.2437814,.00586826,1.1702379E-8,
?570& .0021878462.5.219603,273.16,2.3025851/
?580 TC=(TF-32.)/1.8
?590 X=374.11-TC

```

Table 12 - continued

```

7600 PHTO=EXP(G*(EE-(X/(TC+F))*(A+B*X+C*X**3)/(1.0+D*X)))
7610 RETURN
7620 END
7630C
7640 FUNCTION DEWT(P)
7650 EXTERNAL ROOT,PHTO
7660 XX=ALOG(P)
7670 TA=-2.4+20.25*XX+1.522*XX**2
7680 TB=TA+.1
7690 DEWT=ROOT(TA,TB,PHTO,P,.005,.005,5)
7700 RETURN
7710 END
7720C
7730 FUNCTION TICOR(PC,AF,CD,DEL)
7740 REAL S(5,7)
7750 DATA S/1.75187,-.511449,.0775073,-.00592584,.000179862,
7760& 1.42306,-.271935,.0210187,-.00034839,-1.8475E-5,
7770& 1.08190,-.110821,-.0081408,.00196359,-8.5832E-5,
7780& .90258,-.105068,.0025161,.00028694,-1.3673E-5,
7790& .71551,-.072213,.0024297,9.08E-6,-3.48E-7,
7800& .61612,-.055237,.0003803,.00028605,-1.5623E-5,
7810& .52087,-.035109,-.0014939,.00035115,-1.4808E-5/
7820 P=AMIN1(PC,10.)
7830 PA=P*(AF/.44)**((.84*P+1.)*EXP(-.84*P))
7840 J=CD/5.-1.
7850 IF(J.LT.1)J=1
7860 TI1=PA*(S(1,J)+PA*(S(2,J)+PA*(S(3,J)+PA*(S(4,J)+PA*S(5,J))))) )
7870 IF(J.LT.7)GO TO 8
7880 TICOR=TI1
7890 GOT09
7900 8 J=J+1
7910 TI2=PA*(S(1,J)+PA*(S(2,J)+PA*(S(3,J)+PA*(S(4,J)+PA*S(5,J))))) )
7920 AII=J
7930 TERP=CD/5.-AII
7940 TICOR=TI2*TERP+TI1*(1.-TERP)
7950 9 TICOR=TICOR*(1.+.03536*(DEL-18.33))
7960 RETURN
7970 END
7980C
7990 FUNCTION ROOT(X1,X2,YFCN,W,XTOL,YTOL,K)
8000 COMMON IOUT
8010 EXTERNAL YFCN
8020 XA=X1
8030 XB=X2
8040 FA=YFCN(XA)-W
8050 FB=YFCN(XB)-W
8060 DO 91 IROOT=1,K
8070 ROOT=(FA*XB-FB*X1)/(FA-FB)
8080 FN=YFCN(ROOT)-W
8090 IF(ABS(FN).LT.YTOL .AND.

```

Life Systems, Inc.

Table 12 - continued

```
8100&ABS(ROOT-XB).LT.XTOL)RETURN
8110 IF(IROOT.GE.K)WRITE(IOUT,200)X1,X2,W,XTOL,YTOL,IROOT,
8120& XA,XB,ROOT,FA,FB,FN
8130 200 FORMAT( " NONCONVERGENCE IN ROOT",5G11.4,I3/7G11.4)
8140 XA=XB
8150 XB=ROOT
8160 FA=FB
8170 FB=FN
8180 91 CONTINUE
8190 RETURN
8200 END
8210C
8220 SUBROUTINE TDRIFT
8230 REAL N,I
8240 COMMON IOUT,CPA,CPH,N,V3,T5,T3,T1,BK(12),
8250&BLANK(16),NBLANK,
8260&PC0,I,V1,HEATLD,DHC,DHA,DHH,DTREQ,DTAVA,E,
8270&HC,ETA,T2,V5A,T6A
8280 EXTERNAL ERT,ROOT,ERT1
8290 ENTHPR=V1*CPA*T1+V3*CPH*T3
8300 T2HIGH=(ENTHPR+.99*HEATLD)/(V1*CPA+V3*CPH)
8310 T2LOW=(ENTHPR+V5A*CPA*T5+HEATLD)/(V1*CPA+V3*CPH+V5A*CPA)
8320 T2=T2HIGH
8330 DUMMY=ERT(V5A/N)
8340 T2=ROOT(T2HIGH,T2LOW,ERT1,0.,.005,.005,20)
8350 RETURN
8360 END
8370C
8380 FUNCTION ERT1(T)
8390 REAL N,I
8400 COMMON IOUT,CPA,CPH,N,V3,T5,T3,T1,BK(12),
8410&BLANK(16),NBLANK,
8420&PC0,I,V1,HEATLD,DHC,DHA,DHH,DTREQ,DTAVA,E,
8430&HC,ETA,T2,V5A,T6A
8440 E=.729-.22*ALOG(I)+.008*I+.005*(T-78.)
8450 HEATLD=N*I*(1.25-E)*3.419
8460 DHA=V1*CPA*(T-T1)
8470 DHH=V3*CPH*(T-T3)
8480 DHC=HEATLD-DHA-DHH
8490 T6A=T5+DHC/(V5A*CPA)
8500 DTREQ=DHC*(.376+3.876/(HC*ETA))/N
8510 IF(T6A.LT.T)GOTO 1086
8520 ERT1=-DTREQ
8530 RETURN
8540 1086 DTAVA=(T6A-T5)/ALOG((T-T5)/(T-T6A))
8550 ERT1=DTAVA-DTREQ
8560 RETURN
8570 END
8580C
8590 FUNCTION ERT(V)
```

Table 12 - continued

```

8600 REAL N,I
8610 COMMON IOUT,CPA,CPH,N,V3,T5,T3,T1,BK(12),
8620&BLANK(16),NBLANK,
8630&PC0,I,V1,HEATLD,DHC,DHA,DHH,DTREQ,DTAVA,E,
8640&HC,ETA,T2,V5A,T6A
8650 IF(V.LE.1.)HC=1.97*V**(.3333)
8660 IF(V.GT.1. .AND. V.LT.2.9883)HC=1.21+V*(.34+.42*V)
8670 IF(V.GE.2.9883 .AND. V.LE.4.)HC=2.*V
8680 IF(V.GT.4.)HC=2.639016*V**(.8)
8690 ETA=1.
8700 IF(V.GT..32194 .AND. V.LT.24.72)ETA=1.0644-.1135*SQRT(V)
8710 IF(V.GE.24.72)ETA=2.486/SQRT(V)
8720 T6A=T5+DHC/(V*CPA*N)
8730 DTREQ=DHC*(.376+3.876/(HC*ETA))/N
8740 IF(T6A.LT.T2)GO TO 86
8750 ERT=-DTREQ
8760 RETURN
8770 86 DTAVA=(T6A-T5)/ ALOG((T2-T5)/(T2-T6A))
8780 ERT=DTAVA-DTREQ
8790 RETURN
8800 END
8810C
8820 SUBROUTINET(VARNAM,VAR,BOT,TOP,I)
8830 COMMON IOUT
8840 IF(VAR.GE.BOT.AND.VAR.LE.TOP)RETURN
8850 WRITE(IOUT;10)VARNAM,VAR,BOT,TOP
8860 I=I+1
8870 RETURN
8880 10FORMAT(1X,A6,"=",G10.4," RANGE: ",2G10.4)
8890 END
8900C
8910 SUBROUTINE BMODE
8920 REAL N,I
8930 COMMON IOUT,CPA,CPH,N,V3,T5,T3,T1,BK(12),
8940&BLANK(16),NBLANK,PC0,I,V1
8950 I=BK(1)
8960 IF(PC0.LE.BK(2))GOTO10
8970 I=BK(4)
8980 IF(PC0.GE.BK(3))GOTO10
8990 I=BK(9)*PC0+BK(10)
9000 10 V1=BK(5)
9010 IF(PC0.LE.BK(6))RETURN
9020 V1=BK(8)
9030 IF(PC0.GE.BK(7))RETURN
9040 V1=BK(11)*PC0+BK(12)
9050 RETURN
9060 END

```

TABLE 13 CHECKS AND MESSAGES

1. CONDITION: An input variable is out of the prediction range.
MESSAGE: VARIABLE = XX.XX RANGE: XX.XX XX.XX
2. CONDITION: Less than 1.3 times stoichiometric amount of H₂ is supplied.
MESSAGE: INSUFFICIENT HYDROGEN. XXX.XX SLPM IS REQUIRED.
3. CONDITION: Cathode air blowers cannot supply the requested flow rate. Program sets the flow equal to blower capacity.
MESSAGE: V1 HAS BEEN CHANGED TO 70 SCFM, BLOWER CAPACITY.
4. CONDITION: Not enough heat is generated in the modules to attain the setpoint module temperature.
MESSAGE: COOLING BLOWERS ARE OFF. MODULE TEMPERATURE FALLS X.XXF BELOW THE DESIRED XX.XXF TO XX.XXF.
5. CONDITION: Process streams and cooling air cannot remove enough heat to maintain the setpoint module temperature.
MESSAGE: COOLING BLOWERS ARE ON FULL. MODULE TEMPERATURE RISES X.XXF ABOVE THE DESIRED XX.XXF TO XX.XXF.
6. CONDITION: Normal heat balance is attained.
MESSAGE: DESIRED MODULE TEMPERATURE IS MAINTAINED WITH COOLING BLOWERS AT PARTIAL CAPACITY.
7. CONDITION: Process air flow does not exceed cathode air plus cooling air flow by at least 5%.
MESSAGE: INSUFFICIENT PROCESS AIR TO PREVENT BACKMIXING THROUGH PLENUM BYPASS.
8. CONDITION: Inlet process air moisture conditions are out of tolerance and will not support steady state cell operation.
MESSAGE: INLET PROCESS AIR DEW POINT DEPRESSION OUT OF RANGE. ELECTROLYTE MOISTURE BALANCE IS NOT MAINTAINED.
9. CONDITION: Outlet process air moisture conditions are out of tolerance and will not support steady state cell operation.
MESSAGE: OUTLET PROCESS AIR DEW POINT DEPRESSION OUT OF RANGE. ELECTROLYTE MOISTURE BALANCE IS NOT MAINTAINED.

C-3

Table 13 - continued

10. CONDITION: Average of inlet and outlet process air moisture condition is out of tolerance and will not support steady state cell operation.

MESSAGE: AVERAGE PROCESS AIR DEW POINT DEPRESSION OUT OF RANGE.
ELECTROLYTE MOISTURE BALANCE IS NOT MAINTAINED.

11. CONDITION: Convergence subroutine (ROOT) did not approach a solution within the specified number of iterations.

MESSAGE: NONCONVERGENCE IN ROOT (PRINT ROOT PARAMETERS)

TABLE 14 NOMENCLATURE AND UNITS

Composite Variable Names

First Prefix	P - (Partial) Pressure, mm Hg V - Volume Flow Rate, Scfm 70F, 760 mm Hg AV - Volume Flow Rate, Cfm F - Mass Flow Rate, Lb/Hr DP - Pressure Drop DW - Dew Point, F T - Temperature, F RH - Relative Humidity, %
Second Prefix	C - Carbon Dioxide (CO_2) O - Oxygen (O_2) N - Nitrogen (N_2) H - Hydrogen (H_2) W - Water (H_2O) (None) - Total Stream
Stream Number	\emptyset - Cabin Atmosphere 1 - Cathode Air Modules Inlet 2 - Cathode Air Modules Outlet 3 - H_2 Modules Inlet 4 - H_2 Modules Outlet 5 - Cooling Air Inlet 5A - Cooling Air Inlet, Active Cells 6 - Cooling Air Outlet 6A - Cooling Air Outlet, Active Cells 7 - Process Air Inlet 8 - Process Air Outlet 9 - H_2 System Inlet 10 - Plenum Bypass 11 - Cathode Blowers Outlet 12 - Cooling Blowers Outlet 13 - Cooling Dampers Outlet
Units Suffix	(None) - Units of First Prefix PSA - Psia PSG - Psig SL - Slpm
Additional Variable Names	A, B, C, D, EE, F, G A11, J CD CHWRTO Constants in H_2O Dew Point Equation Indices Determine S Constants Current Density CO_2/H_2 Weight Ratio, Lb CO_2 /Lb H_2

continued-

Table 14 - continued

CJKN	Coefficient in Pressure Drop Equation
	J = Inlet Stream Subscript
	K = Outlet Stream Subscript
	N = Degree of Term
COR34,COR93	ΔP Correction Factors for Absolute Pressure
CPA	Volumetric Specific Heat, Air, Btu/Hr-Scfm-F
CPH	Volumetric Specific Heat, H_2 , Btu/Hr-Scfm-F
CTRANS	CO_2 Transferred, Lb/Hr
CURDEN	Current Density, A/Ft ²
DELT1	Input Control Variable = T2-DP1, F
DELT1P	Preferred Value Control Variable = T2-DP1, F
DELIE	Actual Control Variable = T2-DP1, F
DHA	Enthalpy Gain of Inlet Process Air, Btu/Hr
DHC	Enthalpy Gain of Cooling Air, Btu/Hr
DHH	Enthalpy Gain of Inlet H_2 , Btu/Hr
DDP1,DDP2	Dew Point Depression, Streams 1 and 2
DPTDAV	Process Air Dew Point Depression, Average, F
DROP,RISE	T2-(DWI + DELT1), Absolute Value of Module Temperature Offset
DTAVA	Log Mean Available Temperature Drop, F
DTREQ	Required Module - Cooling Air Temperature Drop, F
E	Cell Voltage, Volt
EMOD	Module (16 Cells) Voltage
EQWGT	Total System Equation Weight
ERT,ERT1	Difference Between DTREQ and DTAVA
ESTACK	Stack Voltage, Volt
ETA	Cooling Fin Efficiency, Dimensionless, 0-1
FA,FB,FN	Dependent Values Corresponding to XA,XB,XN
FNAME	Variable Equal to Output File Name
HC	Cooling Fin Heat Transfer Coefficient, Btu/Hr-Ft ² -F
HCON	H_2 Consumption, Lb/Hr
HCVRTO	H_2/CO_2 Volume Ratio, Scfm H_2 /Scfm CO_2
HEATLD	Net Heat Produced, Btu/Hr
HTPEN	Heat Rejection Penalty, Lb/Btu/Hr
HTTOT	Total Heat Rejection
HTWGT	Heat Rejection Penalty Weight
H2OPEN	H_2O Vapor Rejection Penalty, Lb/Lb/Hr
H2OWGT	H_2O Rejection Penalty Weight
I	Current, Amp
INP	Input Device Code: 2=File, 50=Terminal
IOUT	Output Device Code: 1=File, 66=Terminal
MATHIN	Name of Input Data File
N	Number of Cells in Circuit
NERROR	Check Violation Indicator
	0 - No Violation
	1 - Violation

continued-

Table 14 - continued

NFLAG, FLAG	Program Option Integer = 0 or 1
OCON	O ₂ Consumption, Lb/Hr
OXOPEN	O ₂ Consumption Penalty, Lb/Lb/Hr
OXWGT	O ₂ Consumption Penalty Weight
P	Inlet pCO ₂
PA	Inlet pCO ₂ Corrected for Effect of Air Flow
POWER	Electrical Power Produced, Watt
PWPEN	Power Penalty, Lb/Watt
PWRCLB	Cooling Blower Power, Watt
PWRCTB	Cathode Blower Power, Watt
PWRDAU	Data Acquisition Unit Power, Watt
PWREC	Emergency Controller Power, Watt
PWRPC	Primary Controller Power, Watt
PWRTOT	Total Power, Watt
PWRWGT	Power Penalty Weight
QA,QB,QC	Coefficients of V5 in Quadratic Formula
S	Array containing Coefficients of PA in TI
TA,TB	Correlation
TC,TF	Trial Values of Dew Point, F
TE	Dew Point, C, F, respectively
TERP	Current Efficiency, %
TI	Current Density Interpolation Variable
T2INP	Transfer Index, Lb CO ₂ /Lb O ₂
T2P	Set Point Value of T2
T11	Preferred Value of T2
T12	TI at one of the seven current densities just below the desired current density
U1	TI at one of the seven current densities just above the desired current density
U2	Conversion Factor, mm Hg/Psi
U3	Conversion Factor, Scf/Lb Mol
U4	Conversion Factor, Btu/Hr-Watt
V,TR	Conversion Factor, 1/Ft ³
VA,VB	Dummy and Interpolation Variables
V5INP	Trial Values for V5
V5MIN	Cooling Flow for Set Point Module Temperature
V7M1	Cooling Flow with Blowers Off
V9MSL	Plenum Inlet Flow less Cathode Air Flow
WPROD	Minimum Flow of H ₂ Required
X1,X2,XA,XB,XN	Water Production, Lb/Hr
	Trial Values of Independent Variable in Subroutine Root

Additional Variables, Main Program Only

AØ	Output Variable Array
AVG	Array Containing Average TAB Values
BK	Mode B Parameters
CGEN	Numeric Array, CO ₂ Generation Rates, Lb/Hr

continued-

Table 14 - continued

HEAD	Alphabetic Constant Array, Containing Output Variable Names
HDG	Array Containing Selected Values of HEAD
IGEN	CO ₂ Generation Step Subscript
INDEX	Subscripts of Selected Output Variables
IR	Out-of-Range Input Variable Counter
KBASE	Variable Indicating Range of BASE to be Executed
KERROR	Non-Steady State Indicator
KMODE	Mode Indicator, 0=Mode A, 1=Mode B
KPRINT,NPRINT, DPRINT,QPRINT	Output Indicators
MINCYC	Length of One Cycle, Min
NDAY	Day Counter
NDT,DT	Integration Increment, Min
NDAYS,DAYS	Maximum Number of Days to be Simulated
NDEX	Number of Selected Output Variables
NSTEPS	Number of Steps in CO ₂ Generation Table
NT	Time, Min
QC02GT	New CO ₂ Generation Table Indicator
QFIN	File Input Indicator
QFOUT	File Output Indicator
QPRINT	Base Program Output Table Indicator
QSUBS	New Subscript Indicator
SAME	Dummy File Name to Prevent Closing Output File
SLOPE,SLOPEA, SLOPEB,SLOPEC	pCO ₂ Rate of Change, mm Hg/Min
TAB	Array Containing Selected Values of A ₀
TMAX	Ending Times for CO ₂ Generation Rates, Min
U5	Conversion Factor, <u>mm</u> Hg/Min Lb/Hr
XA,YA,XB,YB,XC,YC	Successive Values of Cabin pCO ₂ Approximation and Error

TABLE 15 KEY TO SELECTIVE OUTPUT VARIABLES

AV1	130	FC1	86	RH8	129
AV10EX	140	FC2	94	SLOPEC	29
AV11	141	FC4	104	T11	114
AV12	142	FH3	89	T12	118
AV13	143	FH4	105	T2	13
AV2	131	FW1	87	T2P	80
AV3	132	FW2	95	T6	112
AV4	133	FW4	106	T6A	15
AV5	134	H2OWGT	148	T8	128
AV6	135	HC	11	TE	92
AV6A	136	HCON	53	TI	50
AV7	137	HCVRTO	109	V1	3
AV8	138	HEATLD	4	V10	32
AV9	139	HTTOT	145	V2	73
CHWRTO	108	HTWGT	147	V4	100
C02GEN	30	I	2	V4SL	101
COR34	33	OCON	51	V5	20
COR93	37	OXWGT	149	V5A	14
CTRANS	52	P1	45	V5INP	31
CURDEN	47	P12	117	V5MIN	19
DDP1	76	P2	46	V7M1	18
DDP2	77	P3	35	V8	119
DELT1	16	P3PSA	36	V9MSL	17
DELT1E	48	P6	111	VC1	70
DELT1P	79	P7	42	VC2	72
DHA	6	P7PSA	43	VC4	55
DHC	5	P9	39	VC4SL	102
DHH	7	P9PSA	40	VC7	81
DP12	44	PC0	1	VC8	121
DP1213	115	PC1	49	VH3	58
DP34	34	PC2	93	VH4	59
DP56	110	PC8	122	VH4SL	103
DP78	41	PH3	88	VN1	68
DP93	38	PN1	67	VN7	84
DPTDAV	78	PN8	124	VN8	123
DTAVA	9	PO0	65	VO1	69
DTREQ	8	PO7	66	VO2	71
DUM1	21	POWER	91	VO7	83
DUM2	22	PW1	60	VO8	125
DUM3	23	PW2	74	VW1	61
DUM4	24	PW3	57	VW2	64
DUM5	25	PW4	98	VW3	62
DW2	75	PW8	126	VW4	99
DW4	97	PW9	56	VW7	82
DW8	127	PWRCLB	116	VW8	120
E	10	PWRCTB	113	VWPROD	63
EMOD	90	PWRTOT	144	WPROD	54
EQWGT	150	PWRWGT	146	YA	26
ETA	12	RH2	96	YB	27
F4	107	RH7	85	YC	28

continued-

Table 15 - continued

1	PC0	51	OCON	101	V4SL
2	I	52	CTRANS	102	VC4SL
3	V1	53	HCON	103	VH4SL
4	HEATLD	54	WPROD	104	FC4
5	DHC	55	VC4	105	FH4
6	DHA	56	PW9	106	FW4
7	DHH	57	PW3	107	F4
8	DTREQ	58	VH3	108	CHWRTO
9	DTAVA	59	VH4	109	HCVRTO
10	E	60	PW1	110	DP56
11	HC	61	VW1	111	P6
12	ETA	62	VW3	112	T6
13	T2	63	VWPROD	113	PWRCTB
14	V5A	64	VW2	114	T11
15	T6A	65	P00	115	DP1213
16	DELT1	66	P07	116	PWRCLB
17	V9MSL	67	PN1	117	P12
18	V7M1	68	VN1	118	T12
19	V5MIN	69	V01	119	V8
20	V5	70	VC1	120	VW8
21	DUM1	71	V02	121	VC8
22	DUM2	72	VC2	122	PC8
23	DUM3	73	V2	123	VN8
24	DUM4	74	PW2	124	PN8
25	DUM5	75	DW2	125	V08
26	YA	76	DDP1	126	PW8
27	YB	77	DDP2	127	DW8
28	YC	78	DPTDAV	128	T8
29	SLOPEC	79	DELT1P	129	RH8
30	C02GEN	80	T2P	130	AV1
31	V5INP	81	VC7	131	AV2
32	V10	82	VW7	132	AV3
33	COR34	83	V07	133	AV4
34	DP34	84	VN7	134	AV5
35	P3	85	RH7	135	AV6
36	P3PSA	86	FC1	136	AV6A
37	COR93	87	FW1	137	AV7
38	DP93	88	PH3	138	AV8
39	P9	89	FH3	139	AV9
40	P9PSA	90	EMOD	140	AV10EX
41	DP78	91	POWER	141	AV11
42	P7	92	TE	142	AV12
43	P7PSA	93	PC2	143	AV13
44	DP12	94	FC2	144	PWRTOT
45	P1	95	FW2	145	HTTOT
46	P2	96	RH2	146	PWRWGT
47	CURDEN	97	DW4	147	HTWGT
48	DELT1E	98	FW4	148	H2OWGT
49	PC1	99	VW4	149	OXWGT
50	TI	100	V4	150	EQWGT

APPENDIX D CS-6 CABIN pCO_2 SIMULATION PROGRAM SAMPLE OUTPUTS

TABLE 1 Output Examples D-2 PAGE

TABLE 1 OUTPUT EXAMPLES

**** MODE B ZERO TO STEADY STATE PCO2 LIMITS 1 & 2 MMHG ****
*****INPUT DATA*****

CABIN ATMOSPHERE:

POPSA	14.70	!	PCO	0.1000E-02	!	POOPSA	3.100	!	T0		70.00
VOLUME	8000.	!									

PROCESS AIR OUTLET/INLET:

PPOPSA	14.75	!	T7	55.00	!	V7	265.0	!	DW7		50.00
H2 OUTLET/INLET:											
P4PSA	20.00	!	T9	72.00	!	V9SL	10.00	!	DW9		69.00

MODULES:

N	96.00	!	I	2.586	!	DELT1	22.00	!	V1		20.00
---	-------	---	---	-------	---	-------	-------	---	----	--	-------

PENALTY WEIGHT FACTORS:

PWPEN	0.5910	!	HTOPEN	0.1280	!	H2OPEN	134.0	!	OKOPEN		1536.
-------	--------	---	--------	--------	---	--------	-------	---	--------	--	-------

CONTROL:

KMODE	1.000	!	NFLAG	1.000	!	IMIN	2.586	!	PCIMIN		1.000
PCIMAX	2.000	!	IMAX	6.600	!	VMIN	20.00	!	PCVMIN		1.000
PCVMAX	2.000	!	VMAX	60.00	!	DAYS	10.00	!	DT		15.00
DPRINT	60.00	!									

*****RESULTS*****

PREFERRED VALUE OF DELT1 IS 23.58 UNDER THESE CONDITIONS
SO THAT 73.58 = T2 = DW1 + DELT1 = 50.00 + 23.58.

MODULES:

TI	0.8810E-03	!	TE	0.3204E-01	!	E	0.5038	!	EMOD		8.061
CTRANSO	0.1439E-03	!	OCON	0.1634	!	HCON	0.2058E-01	!	WPROD		0.1839
CURDEN	10.60	!	HEATLD	633.3	!	POWER	125.1	!			

CATHODE AIR INLET:

P1	763.6	!	PC1	0.1004E-02	!	PW1	9.212	!	FC1		0.1797E-03
FW1	0.6742	!	VC1	0.2632E-04	!	VW1	0.2413	!	VO1		4.218
VN1	15.54	!	T1	55.00	!	DW1	50.00	!	RH1		83.20

CATHODE AIR OUTLET:

P2	761.9	!	DP12	1.737	!	PC2	0.1992E-03	!	PW2		11.73
V2	20.03	!	VC2	0.5239E-05	!	VW2	0.3083	!	VO2		4.185
VN2	15.54	!	FC2	0.3577E-04	!	FW2	0.8616	!	T2		70.64
DW2	56.58	!	RH2	61.11	!	P11	762.6	!	V11		20.03
T11	104.0	!									

PROCESS AIR INLET:

P7	763.6	!	PW7	9.212	!	PN7	593.4	!	VC7		0.3487E-03
VW7	3.197	!	VO7	55.88	!	VN7	205.9	!	DW7		50.00
RH7	83.20	!									

PROCESS AIR OUTLET:

P8	762.6	!	PC8	0.9426E-03	!	V10	215.7	!	DP78		1.047
V8	265.0	!	VW8	3.264	!	VC8	0.3276E-03	!	VO8		55.85
PW8	9.391	!	T8	61.24	!	DW8	50.52	!	RH8		67.80

continued-

Table 1 continued

H2 INLET:

P9	1157.	!	PW9	18.15	!	DP93	120.3	!	P3	1037.
PW3	16.26	!	PH3	1021.	!	V3	0.3531	!	VH3	0.3476
VW3	0.5537E-02	!	FH3	0.1087	!	V9MSL	2.423	!		

H2 OUTLET:

P4	1034.	!	DP34	2.890	!	PW4	12.02	!	V4	0.2851
VC4	0.2108E-04	!	VH4	0.2818	!	VW4	0.3315E-02	!	V4SL	8.074
VC4SL	0.5969E-03	!	VH4SL	7.980	!	F4	0.9755E-01	!	FC4	0.1439E-03
FH4	0.8814E-01	!	FW4	0.9264E-02	!	DW4	57.28	!	CHWRTOO	1.633E-02
HCVRTOO	1.337E+05	!								

HEAT BALANCE, MODULES:

HEATLD	633.3	!	DHA	336.6	!	DHH	-5140	!	DHC	297.2
--------	-------	---	-----	-------	---	-----	-------	---	-----	-------

COOLING AIR:

P5	763.6	!	DP56	0.3072	!	P6	763.3	!	V5	29.31
T5	55.00	!	T6	64.42	!	HC	1.327	!	ETA	1.000
V5A	29.31	!	T6A	64.42	!	P12	763.3	!	V12	29.31
T12	64.42	!	DP1213	0.7396	!	V5MIN	29.31	!		

ACTUAL VOLUMETRIC FLOW RATES:

AV1	19.34	!	AV2	20.01	!	AV3	0.2598	!	AV4	0.2098
AV5	28.34	!	AV6	28.87	!	AV6A	28.87	!	AV7	256.3
AV8	259.8	!	AV9	0.2328	!	AV10EX	208.9	!	AV11	21.25
AV12	28.87	!	AV13	28.90	!					

EQUIVALENT WEIGHT:

PWRCLB	0.0000	!	PWRCTB	209.8	!	PWRPC	136.0	!	PWREC	45.00
PWRDAU	100.0	!	PWRTOT	490.8	!	HTTOT	2739.	!	PWRWT	290.1
HTWGT	350.6	!	H2ONGT	24.65	!	OXWGT	250.9	!	HWDWGT	817.9
EQWGT	1734.	!								

*****DAY 1 *****

TIME	PCO	I	V1	TI	OCON	CTRANS	EQWGT
------	-----	---	----	----	------	--------	-------

0: 0							
0.1000E-02	2.586	20.00	0.8810E-03	0.1634	0.1439E-03		1734.
1: 0							
0.2788	2.586	20.00	0.2408	0.1634	0.3933E-01		1734.
2: 0							
0.5259	2.586	20.00	0.4545	0.1634	0.7425E-01		1734.
3: 0							
0.7451	2.586	20.00	0.6490	0.1634	0.1060		1734.
4: 0							
0.9391	2.586	20.00	0.8246	0.1634	0.1347		1734.

continued -

Life Systems, Inc.

Table 1 continued

5: 0	1.098	2.979	23.92	1.079	0.1882	0.2031	1808.
6: 0	1.196	3.373	27.84	1.236	0.2131	0.2633	1903.
7: 0	1.265	3.652	30.62	1.337	0.2307	0.3084	1980.
8: 0	1.444	4.367	37.75	1.513	0.2759	0.4174	2197.
9: 0	1.659	5.232	46.36	1.650	0.3305	0.5452	2458.
10: 0	1.794	5.775	51.78	1.684	0.3648	0.6145	2605.
11: 0	1.886	6.141	55.43	1.687	0.3879	0.6546	2700.
12: 0	1.922	6.286	56.87	1.688	0.3971	0.6703	2736.
13: 0	1.823	5.890	52.92	1.687	0.3721	0.6275	2635.
14: 0	1.782	5.726	51.29	1.683	0.3617	0.6087	2592.
15: 0	1.822	5.887	52.89	1.687	0.3719	0.6272	2634.
16: 0	1.905	6.219	56.20	1.688	0.3928	0.6631	2719.
17: 0	1.963	6.451	58.51	1.686	0.4075	0.6872	2777.
18: 0	1.948	6.392	57.93	1.687	0.4038	0.6813	2763.
19: 0	1.842	5.964	53.66	1.687	0.3768	0.6357	2654.
20: 0	1.795	5.777	51.79	1.684	0.3649	0.6146	2605.
21: 0	1.817	5.867	52.69	1.686	0.3706	0.6250	2629.
22: 0	1.818	5.869	52.71	1.686	0.3707	0.6252	2630.
23: 0	1.740	5.556	49.60	1.675	0.3510	0.5880	2547.
24: 0	1.590	4.955	43.60	1.616	0.3130	0.5057	2380.
AVERAGES:							
	1.501	4.910	43.16	1.400	0.3102	0.4724	2361.

continued -

Table 1 - continued

*****DAY 2 *****

TIME	PCO	I	V1	TI	OCON	CTRANS	EWGT

0: 0	1.690	4.955	43.60	1.616	0.3130	0.5057	2380.
1: 0	1.490	4.552	39.59	1.549	0.2875	0.4453	2259.
2: 0	1.429	4.309	37.17	1.501	0.2722	0.4086	2178.
3: 0	1.393	4.165	35.71	1.469	0.2630	0.3863	2132.
4: 0	1.371	4.075	34.84	1.449	0.2574	0.3730	2104.
5: 0	1.358	4.023	34.32	1.436	0.2541	0.3650	2088.
6: 0	1.360	3.991	34.00	1.429	0.2521	0.3602	2079.
7: 0	1.357	4.019	34.28	1.435	0.2539	0.3644	2087.
8: 0	1.499	4.587	39.94	1.555	0.2898	0.4507	2271.
9: 0	1.693	5.367	47.71	1.662	0.3390	0.5635	2495.
10: 0	1.817	5.864	52.66	1.686	0.3704	0.6246	2628.
11: 0	1.901	6.203	56.04	1.688	0.3918	0.6614	2715.
12: 0	1.933	6.329	57.30	1.688	0.3998	0.6748	2747.
13: 0	1.831	5.920	53.22	1.687	0.3740	0.6309	2643.
14: 0	1.787	5.746	51.49	1.683	0.3630	0.6111	2597.
15: 0	1.826	5.901	53.03	1.687	0.3728	0.6288	2638.
16: 0	1.907	6.229	56.30	1.688	0.3935	0.6642	2722.
17: 0	1.965	6.458	58.58	1.686	0.4079	0.6879	2779.
18: 0	1.949	6.397	57.98	1.687	0.4041	0.6818	2764.
19: 0	1.842	5.967	53.70	1.687	0.3770	0.6361	2655.
20: 0	1.795	5.779	51.82	1.684	0.3651	0.6149	2606.

continued -

Life Systems, Inc.

Table 1 continued

21: 0							
	1.818	5.868	52.71	1.686	0.3707	0.6251	2629.
22: 0							
	1.818	5.870	52.72	1.686	0.3708	0.6253	2630.
23: 0							
	1.740	5.557	49.61	1.675	0.3510	0.5881	2547.
24: 0							
	1.590	4.955	43.61	1.616	0.3130	0.5058	2380.
AVERAGES:							
	1.686	5.339	47.43	1.613	0.3372	0.5491	2474.

*****INPUT DATA*****

CABIN ATMOSPHERE:

POPSA	14.70	!	PCO	10.00	!	POOPSA	3.100	!	T0	70.00
VOLUME	8000.	!								

PROCESS AIR OUTLET/INLET:

P8PSA	14.75	!	T7	55.00	!	V7	265.0	!	DW7	50.00
-------	-------	---	----	-------	---	----	-------	---	-----	-------

H2 OUTLET/INLET:

P4PSA	20.00	!	T9	72.00	!	V9SL	10.00	!	DW9	69.00
-------	-------	---	----	-------	---	------	-------	---	-----	-------

MODULES:

N	96.00	!	I	6.600	!	DELT1	22.00	!	V1	60.00
---	-------	---	---	-------	---	-------	-------	---	----	-------

PENALTY WEIGHT FACTORS:

PUPEN	0.5910	!	HTPEN	0.1280	!	H2OPEN	134.0	!	OXOPEN	1536.
-------	--------	---	-------	--------	---	--------	-------	---	--------	-------

CONTROL:

KMODE	1.000	!	NFLAG	1.000	!	IMIN	2.536	!	PCIMIN	2.500
PCIMAX	2.800	!	IMAX	6.600	!	VMIN	20.00	!	PCVMIN	2.500
PCVMAX	2.800	!	VMAX	60.00	!	DAY5	10.00	!	DT	15.00
DPRINT	60.00	!								

*****RESULTS*****

continued -

Table 1 continued

*****DAY 1 *****

TIME	PC0	I	V1
0: 0	10.00	6.600	60.00
1: 0	9.318	6.600	60.00
2: 0	8.641	6.600	60.00
3: 0	7.967	6.600	60.00
4: 0	7.300	6.600	60.00
5: 0	6.642	6.600	60.00
6: 0	5.999	6.600	60.00
7: 0	5.388	6.600	60.00
8: 0	4.968	6.600	60.00
9: 0	4.712	6.600	60.00
10: 0	4.471	6.600	60.00
11: 0	4.246	6.600	60.00
12: 0	4.008	6.600	60.00
13: 0	3.645	6.600	60.00
14: 0	3.344	6.600	60.00
15: 0	3.149	6.600	60.00
16: 0	3.037	6.600	60.00
17: 0	2.936	6.600	60.00
18: 0	2.786	6.415	58.16
19: 0	2.623	4.232	36.41

continued -

Life Systems, Inc.

Table 1 - continued

20: 0		
	2.599	3.912
21: 0		33.21
	2.628	4.292
22: 0		37.00
	2.622	4.219
23: 0		36.27
	2.573	3.556
24: 0		29.67
	2.513	2.764
AVERAGES:		21.78
	4.620	5.953
		53.55

*****DAY 2 *****

TIME	PCO	I	V1
------	-----	---	----

0: 0		
	2.513	2.764
1: 0		21.78
	2.505	2.660
2: 0		20.73
	2.505	2.649
3: 0		20.63
	2.505	2.648
4: 0		20.62
	2.505	2.648
5: 0		20.62
	2.505	2.648
6: 0		20.62
	2.505	2.648
7: 0		20.62
	2.514	2.776
8: 0		21.89
	2.599	3.909
9: 0		33.18
	2.670	4.861
10: 0		42.67
	2.688	5.104
11: 0		45.09
	2.694	5.188
12: 0		45.93
	2.672	4.882
13: 0		42.88
	2.593	3.825
		32.35

continued -

Table 1 - continued

14: 0		
	2.593	3.829
15: 0		32.38
	2.635	4.388
16: 0		37.95
	2.678	4.972
17: 0		43.77
	2.691	5.141
18: 0		45.46
	2.657	4.682
19: 0		40.89
	2.589	3.783
20: 0		31.93
	2.592	3.820
21: 0		32.30
	2.626	4.273
22: 0		36.81
	2.622	4.215
23: 0		36.23
	2.572	3.556
24: 0		29.66
	2.513	2.764
AVERAGES:		21.78
	2.593	3.827
		32.37